

**Kummiisolatsiooniga kaablid
nimipinge kuni 450/750 V. Osa 12:
Kuumuskindlad
eteenpropeenikummiisolatsioonigapaind
kaablid**

Cables of rated voltages up to and including 450/750 V and having crosslinked insulation Part 12: Heat resistant EPR cords and flexible cables

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-HD 22.12 S2:2007 sisaldab Euroopa standardi HD 22.12 S2:2007 ingliskeelset teksti. Käesolev dokument on jõustatud 27.04.2007 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes. Standard on kättesaadav Eesti standardiorganisatsioonist.	This Estonian standard EVS-HD 22.12 S2:2007 consists of the English text of the European standard HD 22.12 S2:2007. This document is endorsed on 27.04.2007 with the notification being published in the official publication of the Estonian national standardisation organisation. The standard is available from Estonian standardisation organisation.
--	---

Käsitlusala: This part Part 12 of the HD details the particular specifications for heat-resistant EPR or equivalent synthetic elastomer insulated and heat-resistant EPR or CSP or equivalent synthetic elastomer sheathed cords and flexible cables, of rated voltages up to and including 450/750 V, for use with a conductor temperature not exceeding 90 °C.	Scope: This part Part 12 of the HD details the particular specifications for heat-resistant EPR or equivalent synthetic elastomer insulated and heat-resistant EPR or CSP or equivalent synthetic elastomer sheathed cords and flexible cables, of rated voltages up to and including 450/750 V, for use with a conductor temperature not exceeding 90 °C.
---	---

ICS 29.060.20

Võtmesõnad:

English version

**Cables of rated voltages up to and including 450/750 V
and having cross-linked insulation –
Part 12: Heat resistant EPR cords and flexible cables**

Conducteurs et câbles isolés
avec des matériaux réticulés
de tension assignée
au plus égale à 450/750 V –
Partie 12: Câbles souples à isolation EPR
résistant à la chaleur

Starkstromleitungen mit vernetzter
Isolierhülle für Nennspannungen
bis 450/750 V –
Teil 12: Wärmebeständige
Schlauchleitungen mit EPR-Isolierhülle

This Harmonization Document was approved by CENELEC on 2006-12-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This Harmonization Document was prepared by the Technical Committee CENELEC TC 20, Electric cables.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as HD 22.12 S2 on 2006-12-01.

This Harmonization Document supersedes HD 22.12 S1:1996 + A1:1999.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the existence of the HD has to be announced at national level | (doa) | 2007-06-01 |
| – latest date by which the HD has to be implemented at national level by publication of a harmonized national standard or by endorsement | (dop) | 2007-12-01 |
| – latest date by which the national standards conflicting with the HD have to be withdrawn | (dow) | 2008-12-01 |

HD 22, Cables of rated voltages up to and including 450/750 V and having cross-linked insulation, now has the following parts:

HD 22.1 S4	General requirements
HD 22.2 S3 ¹⁾	Test methods
HD 22.3 S4	Heat resistant silicone rubber insulated cables
HD 22.4 S4	Cords and flexible cables
HD 22.5	(Spare)
HD 22.6 S2	Arc welding cables
HD 22.7 S2	Cables with increased heat resistance for internal wiring for a conductor temperature of 110 °C
HD 22.8 S2	Polychloroprene or equivalent synthetic elastomer sheathed cable for decorative chains
HD 22.9 S3	Single core halogen-free non-sheathed cables for fixed wiring having low emission of smoke
HD 22.10 S2	EPR insulated and polyurethane sheathed flexible cables
HD 22.11 S2	EVA cords and flexible cables
HD 22.12 S2	Heat resistant EPR cords and flexible cables
HD 22.13 S2	Halogen-free flexible cables having low emission of smoke
HD 22.14 S3	Cords for applications requiring high flexibility
HD 22.15 S2	Multicore cables insulated and sheathed with heat resistant silicone rubber
HD 22.16 S2	Water resistant polychloroprene or equivalent synthetic elastomer sheathed cables

¹⁾ HD 22.2 is superseded by EN 50395 and EN 50396.

Contents

	Page
1 Scope	5
2 Normative references	5
3 Ordinary heat-resistant and low temperature resistant EPR or equivalent synthetic elastomer insulated and sheathed cord and cable for a maximum conductor temperature of 90 °C.....	5
3.1 Code designation	5
3.2 Rated voltage	5
3.3 Construction	5
3.4 Tests	6
3.5 Guide to use (informative)	6
4 Heavy heat-resistant and low temperature resistant EPR or equivalent synthetic elastomer insulated and sheathed cord and cable for a maximum conductor temperature of 90 °C	9
4.1 Code designation	9
4.2 Rated voltage	9
4.3 Construction	9
4.4 Tests	10
4.5 Guide to use (informative)	10
5 Ordinary heat-resistant EPR or equivalent synthetic elastomer insulated and CSP or equivalent synthetic elastomer sheathed cord and cable for a maximum conductor temperature of 90 °C.....	15
5.1 Code designation	15
5.2 Rated voltage	15
5.3 Construction	15
5.4 Tests	16
5.5 Guide to use (informative)	16
6 Heat-resistant EPR or equivalent synthetic elastomer insulated heavy CSP or equivalent synthetic elastomer sheathed cord and cable for a maximum conductor temperature of 90 °C.....	18
6.1 Code designation	18
6.2 Rated voltage	18
6.3 Construction	18
6.4 Tests	19
6.5 Guide to use (informative)	19
7 Heat-resistant EPR or equivalent synthetic elastomer insulated heavy CSP or equivalent synthetic elastomer sheathed cable for a maximum conductor temperature of 90 °C (multicore cables).....	24
7.1 Code designation	24
7.2 Rated voltage	24
7.3 Construction	24
7.4 Tests	25
7.5 Guide to use (informative)	25
Annex A (normative) Requirements for compatibility test	28
Bibliography	29

Table 1 – Dimensions of type H05BB-F.....	7
Table 2 – Tests for types H05BB-F	8
Table 3 – Dimensions of type H07BB-F.....	11
Table 4 – Tests for types H07BB-F	14
Table 5 – Dimensions of type H05BN4-F	16
Table 6 – Tests for types H05BN4-F	17
Table 7 – Dimensions of type H07BN4-F	20
Table 8 – Tests for types H07BN4-F	23
Table 9 – Dimensions of type H07BN4-F	26
Table 10 – Tests for types H07BN4-F	27
Table A.1 – Requirements	28

This document is a preview generated by EVS

1 Scope

This Part 12 of the HD details the particular specifications for heat-resistant EPR or equivalent synthetic elastomer insulated and heat-resistant EPR or CSP or equivalent synthetic elastomer sheathed cords and flexible cables, of rated voltages up to and including 450/750 V, for use with a conductor temperature not exceeding 90 °C.

Each cable shall comply with the appropriate requirements given in Part 1 of this HD and the particular requirements of this part.

NOTE The overall dimensions of the cables in this part of HD 22 have been calculated in accordance with EN 60719.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50334	Marking by inscription for the identification of cores of electric cables
EN 50363-1	Insulating, sheathing and covering materials for low voltage energy cables – Part 1: Cross-linked elastomeric insulating compounds
EN 50363-2-1	Insulating, sheathing and covering materials for low voltage energy cables – Part 2-1: Cross-linked elastomeric sheathing compounds
EN 50395	Electrical test methods for low voltage energy cables
EN 50396	Non electrical test methods for low voltage energy cables
EN 60228	Conductors of insulated cables (IEC 60228)
EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame (IEC 60332-1-2)
EN 60811 series	Insulating and sheathing materials of electric and optical fibre cables - Common test methods (IEC 60811 series)

3 Ordinary heat-resistant and low temperature resistant EPR or equivalent synthetic elastomer insulated and sheathed cord and cable for a maximum conductor temperature of 90 °C

3.1 Code designation

H05BB-F.

3.2 Rated voltage

300/500 V.

3.3 Construction

3.3.1 Conductor

Number of conductors: 2, 3, 4 or 5.

The conductors shall be in accordance with the requirements given in EN 60228 for Class 5 conductors. The wires may be plain or tinned.