

**Kummiisolatsiooniga kaablid
nimipingega kuni 450/750 V. Osa 15:
Mitmesoonelised kuumuskindla
silikoonkummiisolatsiooni ja -mantliga
kaablid**

Cables of rated voltages up to and including 450/750 V and having cross-linked insulation Part 15:
Multicore cables insulated and sheathed with heat resistant silicone rubber

EESTI STANDARDI EESSÖNA**NATIONAL FOREWORD**

Käesolev Eesti standard EVS-HD 22.15 S2:2007 sisaldb Euroopa standardi HD 22.15 S2:2007 ingliskeelset teksti.	This Estonian standard EVS-HD 22.15 S2:2007 consists of the English text of the European standard HD 22.15 S2:2007.
Käesolev dokument on jõustatud 27.04.2007 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.	This document is endorsed on 27.04.2007 with the notification being published in the official publication of the Estonian national standardisation organisation.
Standard on kätesaadav Eesti standardiorganisatsioonist.	The standard is available from Estonian standardisation organisation.

Käsitlusala:

This Part 15 of the HD details the specifications for multicore cables of rated voltage 300/500 V, insulated and sheathed with heat resistance silicone rubber, with or without strain-bearing element. The maximum permissible conductor temperature is 180 °C.

Scope:

This Part 15 of the HD details the specifications for multicore cables of rated voltage 300/500 V, insulated and sheathed with heat resistance silicone rubber, with or without strain-bearing element. The maximum permissible conductor temperature is 180 °C.

ICS 29.060.20

Võtmesõnad:

HARMONIZATION DOCUMENT
DOCUMENT D'HARMONISATION
HARMONISIERUNGSDOKUMENT

HD 22.15 S2

February 2007

ICS 29.060.20

Supersedes HD 22.15 S1:1999

English version

**Cables of rated voltages up to and including 450/750 V
and having cross-linked insulation -**

**Part 15: Multicore cables insulated and sheathed
with heat resistant silicone rubber**

Conducteurs et câbles isolés avec
des matériaux réticulés de tension
assignée au plus égale à 450/750 V -
Partie 15: Câbles multiconducteurs
à isolant et gaine en silicium résistant
à la chaleur

Starkstromleitungen mit vernetzter
Isolierhülle für Nennspannungen
bis 450/750 V -
Teil 15: Wärmebeständige mehradrige
Silikon-Schlauchleitungen

This Harmonization Document was approved by CENELEC on 2006-12-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This Harmonization Document was prepared by the Technical Committee CENELEC TC 20, Electric cables.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as HD 22.15 S2 on 2006-12-01.

This Harmonization Document supersedes HD 22.15 S1:1999.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the existence of the HD has to be announced at national level | (doa) | 2007-06-01 |
| – latest date by which the HD has to be implemented at national level by publication of a harmonized national standard or by endorsement | (dop) | 2007-12-01 |
| – latest date by which the national standards conflicting with the HD have to be withdrawn | (dow) | 2008-12-01 |

HD 22, *Cables of rated voltages up to and including 450/750 V and having cross-linked insulation*, now has the following parts:

HD 22.1 S4	General requirements
HD 22.2 S3 ¹⁾	Test methods
HD 22.3 S4	Heat resistant silicone rubber insulated cables
HD 22.4 S4	Cords and flexible cables
HD 22.5	(Spare)
HD 22.6 S2	Arc welding cables
HD 22.7 S2	Cables with increased heat resistance for internal wiring for a conductor temperature of 110 °C
HD 22.8 S2	Polychloroprene or equivalent synthetic elastomer sheathed cable for decorative chains
HD 22.9 S3	Single core halogen-free non-sheathed cables for fixed wiring having low emission of smoke
HD 22.10 S2	EPR insulated and polyurethane sheathed flexible cables
HD 22.11 S2	EVA cords and flexible cables
HD 22.12 S2	Heat resistant EPR cords and flexible cables
HD 22.13 S2	Halogen-free flexible cables having low emission of smoke
HD 22.14 S3	Cords for applications requiring high flexibility
HD 22.15 S2	Multicore cables insulated and sheathed with heat resistant silicone rubber
HD 22.16 S2	Water resistant polychloroprene or equivalent synthetic elastomer sheathed cables

¹⁾ HD 22.2 has been superseded by EN 50395 and EN 50396

Contents

	Page
1 Scope	4
2 Normative references	4
3 Heat resistant silicone rubber sheathed multicore flexible cables without strain-bearing element	4
3.1 Code designation	4
3.2 Rated voltage	4
3.3 Construction	5
3.4 Tests	6
3.5 Guide to use (informative)	6
4 Heat resistant silicone rubber sheathed multicore cables with strain-bearing element	8
4.1 Code designation	8
4.2 Rated voltage	8
4.3 Construction	8
4.4 Tests	9
4.5 Guide to use (informative)	9
Annex A (normative) Requirements for compatibility test	12
Bibliography	13
Table 1 - Dimensions of Type H05SS-F and H05SST-F	6
Table 2 - Tests for Type H05SS-F and H05SST-F	7
Table 3 - Dimensions of Type H05SSD3-K and H05SSD3T-K	10
Table 4 - Tests for Type H05SSD3-K and H05SSD3T-K	11
Table A.1 - Requirements	12

1 Scope

This Part 15 of the HD details the specifications for multicore cables of rated voltage 300/500 V, insulated and sheathed with heat resistance silicone rubber, with or without strain-bearing element.

The maximum permissible conductor temperature is 180 °C.

Each cable shall comply with the appropriate requirements given in Part 1 of this HD and the particular requirements of this part.

NOTE The overall dimensions of the cables of this part of HD 22 have been calculated in accordance with EN 60719.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 10002-1	Metallic materials – Tensile testing – Part 1: Method of test at ambient temperature
EN 50363-1	Insulating, sheathing and covering materials for low voltage energy cables – Part 1: Cross-linked elastomeric insulating compounds
EN 50363-2-1	Insulating, sheathing and covering materials for low voltage energy cables – Part 2-1: Cross-linked elastomeric sheathing compounds
EN 50395	Electrical test methods for low voltage energy cables
EN 50396	Non-electrical test methods for low voltage energy cables
EN 60228	Conductors of insulated cables (IEC 60228)
EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame (IEC 60332-1-2)
EN 60811 series	Insulating and sheathing materials of electric and optical fibre cables – Common test methods (IEC 60811 series)

3 Heat resistant silicone rubber sheathed multicore flexible cables without strain-bearing element

3.1 Code designation

H05SS-F for unbraided cables without strain-bearing element.

H05SST-F for braided cables without strain-bearing element.

3.2 Rated voltage

300/500 V.