Ambient air quality - Standard method for measurement of benzene concentrations - Part 2: Pumped sampling followed by solvent desorption and gas chromatography

Ambient air quality - Standard method for measurement of benzene concentrations - Part 2: Pumped sampling followed by solvent desorption and gas chromatography



EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 14662-2:2005 sisaldab Euroopa standardi EN 14662-2:2005 ingliskeelset teksti.

Käesolev dokument on jõustatud 15.07.2005 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 14662-2:2005 consists of the English text of the European standard EN 14662-2:2005.

This document is endorsed on 15.07.2005 with the notification being published in the official publication of the Estonian national standardisation organisation.

The standard is available from Estonian standardisation organisation.

Käsitlusala:

This part of EN 14662 is in accordance with the generic methodology for the determination of benzene in ambient air [1] for the purpose of comparison of measurement results with limit values with a one-year reference period.

Scope:

This part of EN 14662 is in accordance with the generic methodology for the determination of benzene in ambient air [1] for the purpose of comparison of measurement results with limit values with a one-year reference period

ICS 13.040.20

Võtmesõnad: air, ambient air, benzene, carcinogens, concentration

EUROPEAN STANDARD NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 14662-2

May 2005

ICS 13.040.20

English version

Ambient air quality - Standard method for measurement of benzene concentrations - Part 2: Pumped sampling followed by solvent desorption and gas chromatography

Qualité de l'air ambiant - Méthode pour le mesurage des concentrations en benzène - Partie 2 : Echantillonnage par pompage suivi d'une désorption au solvant et d'une chromatographie en phase gazeuse Luftbeschaffenheit - Standardverfahren zur Messung von Benzolkonzentrationen - Teil 2: Probenahme mit einer Pumpe mit anschließender Lösemitteldesorption und Gaschromatographie

This European Standard was approved by CEN on 21 March 2005.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Scope Normative References Terms and definitions	
Terms and definitions	4
	4
Method description	6
Principle	6
Reagents and Materials	6
Apparatus	9
Setting of sampling flow rate	
Sampling	10
Procedure	11
Calculation of mass concentration of benzene	12
Report	13
Determination of measurement uncertainty	
Introduction	13
Parameters contributing to measurement uncertainty	14
Recommendations for use	15
A (informative) Determination of breakthrough volume	16
B (informative) Assessment of performance indicators and uncertainty contributions	18
C (informative) Performance characteristics	
raphy	30
	Apparatus Setting of sampling flow rate Sampling. Procedure Calculation of mass concentration of benzene Report Determination of measurement uncertainty Introduction Parameters contributing to measurement uncertainty Recommendations for use A (informative) Determination of breakthrough volume B (informative) Assessment of performance indicators and uncertainty contributions

Foreword

This European Standard (EN 14662-2:2005) has been prepared by Technical Committee CEN/TC 264 "Air quality", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2005, and conflicting national standards shall be withdrawn at the latest by November 2005.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive 2000/69/EC and EU Directive 96/62 EC.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, ings kia, Slov Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

1 Scope

This part of EN 14662 is in accordance with the generic methodology for the determination of benzene in ambient air [1] for the purpose of comparison of measurement results with limit values with a one-year reference period.

This part of EN 14662 gives general guidance for the sampling and analysis of benzene in air by pumped sampling, solvent desorption and capillary gas chromatography.

This part of EN 14662 is valid for the measurement of benzene in a concentration range of approximately 0,5 μg/m³ to 50 μg/m³ in an air sample of 1 m³ volume, typically collected over a period of 24 hours.

The upper limit of the useful range is set by the sorptive capacity of the sorbent and by the linear dynamic range of the gas chromatograph column and detector or by the sample splitting capability of the analytical instrumentation used. The lower limit of the useful range depends on the noise level of the detector and on blank levels of benzene and/or interfering artefacts on the sorbent and in the desorption solvent.

The method described here is based on sampling on sample tubes typically containing 100 mg of activated charcoal and desorption using carbon disulphide.

Alternative sorbents to activated charcoal may be used provided that the equivalence in performance characteristics of the procedure is demonstrated.

Alternative desorption solvents to carbon disulphide may be used provided that the equivalence in performance characteristics of the procedure is demonstrated.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ENV 13005, Guide to the expression of uncertainty in measurement

EN ISO/IEC 17025, General requirements for the competence of testing and calibration laboratories (ISO/IEC 17025:1999)

ISO 6144, Gas analysis - Preparation of calibration gas mixtures - Static volumetric method

ISO 6145, Gas analysis – Preparation of calibration gas mixtures using dynamic volumetric methods

3 Terms and definitions

For the purposes of this European standard the following terms and definitions apply.

NOTE. Attention is drawn to the fact that the terms Ambient Air and Limit Value are defined in Directive 96/62/EC [2].

3.1

Certified reference material

A reference material [3.5], accompanied by a certificate, one or more of whose property values are certified by a procedure which establishes its traceability to an accurate realisation of the unit in which the property values are expressed, and for which each certified value is accompanied by an uncertainty at a stated level of confidence.

[ISO Guide 30:1992]