
**Fire resistance of timber door
assemblies — Method of determining
the efficacy of intumescent seals**

*Résistance au feu d'assemblages de portes en bois — Méthode de
détermination de l'efficacité des joints en renflage*



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

This document is a preview generated by EVS

© ISO 2003

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	2
3 Terms and definitions	2
4 Apparatus	2
5 Test specimen	5
6 Pre-test analysis and installation	6
7 Test procedure	8
8 Performance criteria	8
9 Expression of results	8
10 Test report	8
11 Field of direct application	9
Annex A (informative) Guidance and information on the role of intumescent seals and operation and limitations of the test	10

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 12472 was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 2, *Fire containment*.

Introduction

This test method has been developed for a number of reasons, the primary one being the recognition of the need to have a repeatable and reproducible test procedure by which the performance of intumescent products can be evaluated, particularly so as to ascertain any change in performance resulting from “real time” ageing.

It is a common requirement under any critical product certification scheme that durability be able to be quantified. There are no recognized accelerated ageing methods suitable for use with intumescent sealing products and, as a consequence, real time ageing tests are carried out. It was considered that over a period of twenty years, manufacturing variations would probably occur on any type of proprietary fire-resisting door. The effect of such variations would be to mask any performance changes. The testing apparatus specified here is capable of being built to reproducible and repeatable specification, which will allow even small variations in performance to be identified.

The fact that the method has eradicated most of the variables, making it repeatable and reproducible, also makes it suitable for quality control purposes. As a quality control test it has the added advantage of heating the intumescent seals in the same manner as they would be in practice; in the case of pressure-forming intumescent materials, the method also allows the pressure-forming characteristics of the materials to be characterized for their shear resistance in a comparative manner. This is not measured by any other known technique.

Finally, because the test heats the specimen in a characteristic way and applies typical movement or shear forces, repeatable product-by-product comparisons can be made. This permits a restricted amount of product interchangeability covering the least onerous door modes and configurations. Even under these conditions, the intumescent material proposed to replace the existing material must itself have been the subject of a full-scale test on another door design, if confidence is to be gained in its performance at large scale.

This document is a preview generated by EVS

Fire resistance of timber door assemblies — Method of determining the efficacy of intumescent seals

SAFETY PRECAUTIONS — The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing can be hazardous and that there is a possibility that toxic and/or harmful smoke and gases could be evolved during the test. Mechanical and operational hazards can also arise during the construction of the test elements or structures, their testing, and disposal of test residues.

An assessment of all potential hazards and risks to health shall be made and safety precautions shall be identified and provided. Written safety instructions shall be issued. Appropriate training shall be given to relevant personnel. Laboratory personnel shall ensure that they follow written safety instructions at all times.

IMPORTANT — During fire resistance testing, the leaves shall not deflect more than half their thickness. The distortion shall be measured between the top of the opening edge and the frame of a full-sized door when tested opening into the furnace during a test in accordance with ISO 3008. If the door leaf undergoes distortion greater than this during the test, then the method is unsuitable for evaluating alternative sealing methods.

1 Scope

This International Standard specifies a test method for determining the effective sealing capability of intumescent materials or systems in the context of sealing door-to-frame clearances in timber door assemblies. Intumescent seals extend the duration for which the gap between the leaf edge and the frame will satisfy the integrity criteria of the fire resistance test, and sealing systems can be compared using this method. The method is suitable for evaluating the efficacy of exposed intumescent sealing systems used in conjunction with timber fire resisting doors of up to 1 h fire resistance. It is not suitable for comparing concealed intumescent seals. The results can be applied to proven, single-acting, single-leaf, latched, timber door assemblies of sizes up to that given in the field of direct application.

This International Standard is applicable to timber door assemblies whose intumescent seals have been tested in accordance with ISO 3008 and have satisfied the integrity and — if appropriate — the insulation criterion, whilst incorporating another form of heat-activated seal for a period appropriate to the application. The suitability of any sealing system for use on timber door assemblies of any other configuration (i.e. unlatched single doors, double leaf assemblies etc., or doors constructed of other materials) can only be evaluated by subjecting a full-sized door assembly, complete with seals, to testing in accordance with ISO 3008.

The method does not provide any measure of the ability of the seal to resist the flow of smoke (although a gap that is sealed will provide a reduction in the flow of hot products of combustion) or any information as to the additional protection that could be needed at hardware/ironmongery positions.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 834-1, *Fire-resistance tests — Elements of building construction — Part 1: General requirements*

ISO 3008, *Fire resistance tests — Door and shutter assemblies*

ISO 8302, *Thermal insulation — Determination of steady-state thermal resistance and related properties — Guarded hot plate apparatus*

ISO 13943, *Fire safety — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 13943 and the following apply.

3.1

intumescent seal

seal comprising material or combination of materials with the property of swelling or foaming when exposed to heat, intended to improve the fire performance of the element of construction in which it is incorporated

3.2

concealed intumescent seal

seal where the material is fitted below a timber lipping of at least 4 mm thickness by a thermally softening adhesive and not visible from the outside

3.3

exposed intumescent seal

seal either set into a groove in the edge of the leaf or face of the frame, or applied directly to the face and visible when installed

3.4

integrity

ability of a separating element of building construction, when exposed to fire on one side, to prevent the passage through it of flames and hot gases or the occurrence of flames on the unexposed side

3.5

supporting construction

construction that may be required for the testing of some building elements and into which the test specimen is installed

EXAMPLE The wall into which a door is fitted.

3.6

test construction

complete assembly of the test specimen together with its supporting construction

3.7

timber fire-resisting door assembly

door assembly intended, when closed, to resist the passage of fire or combustion products or both, where the leaf edge incorporates a combustible edging not less than 5 mm thick and where the construction materials are not of metal