

Power transformers -- Part 14: Liquid-immersed power transformers using high-temperature insulation materials

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 60076-14:2013 sisaldab Euroopa standardi EN 60076-14:2013 ingliskeelset teksti.	This Estonian standard EVS-EN 60076-14:2013 consists of the English text of the European standard EN 60076-14:2013.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 25.10.2013.	Date of Availability of the European standard is 25.10.2013.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.180

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English version

**Power transformers -
Part 14: Liquid-immersed power transformers
using high-temperature insulation materials
(IEC 60076-14:2013)**

Transformateurs de puissance -
Partie 14: Transformateurs de puissance
immergés dans du liquide utilisant des
matériaux d'isolation haute température
(CEI 60076-14:2013)

Leistungstransformatoren -
Teil 14: Flüssigkeitsgefüllte
Leistungstransformatoren mit
Hochtemperatur-Isolierstoffen
(IEC 60076-14:2013)

This European Standard was approved by CENELEC on 2013-10-21. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 14/755/FDIS, future edition 1 of IEC 60076-14, prepared by IEC/TC 14 "Power transformers" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60076-14:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-07-21
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-10-21

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60076-14:2013 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60076-4	NOTE	Harmonized in EN 60076-4.
IEC 60216-1	NOTE	Harmonized as EN 60216-1.
IEC 60317	NOTE	Harmonized in EN 60317 series.
IEC 60422	NOTE	Harmonized as EN 60422.
IEC 60505	NOTE	Harmonized as EN 60505.
IEC 60567	NOTE	Harmonized as EN 60567.
IEC 60599	NOTE	Harmonized as EN 60599.
IEC 60641-3	NOTE	Harmonized in EN 60641-3 series.
IEC 60674-3	NOTE	Harmonized in EN 60674-3 series.
IEC 60819-3	NOTE	Harmonized in EN 60819-3 series.
IEC 60851-4	NOTE	Harmonized as EN 60851-4.
IEC 60867	NOTE	Harmonized as EN 60867.
IEC 60893-3	NOTE	Harmonized in EN 60893-3 series.

IEC 60970	NOTE	Harmonized as EN 60970.
IEC 61039	NOTE	Harmonized as EN 61039.
IEC 61100	NOTE	Harmonized as EN 61100.
IEC 61203	NOTE	Harmonized as EN 61203.
IEC 61212-3	NOTE	Harmonized in EN 61212-3 series.
IEC 61629-1	NOTE	Harmonized as EN 61629-1.

This document is a preview generated by EVS

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60076-1	-	Power transformers - Part 1: General	EN 60076-1	-
IEC 60076-2	-	Power transformers - Part 2: Temperature rise for liquid- immersed transformers	EN 60076-2	-
IEC 60076-5	-	Power transformers - Part 5: Ability to withstand short circuit	EN 60076-5	-
IEC 60076-7	-	Power transformers - Part 7: Loading guide for oil-immersed power transformers	-	-
IEC 60076-16	-	Power transformers - Part 16: Transformers for wind turbines applications	EN 60076-16	-
IEC 60085	-	Electrical insulation - Thermal evaluation and designation	EN 60085	-
IEC 60137	-	Insulated bushings for alternating voltages above 1 000 V	EN 60137	-
IEC 60214-1	-	Tap-changers - Part 1: Performance requirements and test methods	EN 60214-1	-
IEC 60296	-	Fluids for electrotechnical applications - Unused mineral insulating oils for transformers and switchgear	EN 60296	-
IEC 60836	-	Specifications for unused silicone insulating liquids for electrotechnical purposes	EN 60836	-
IEC 61099	-	Insulating liquids - Specifications for unused synthetic organic esters for electrical purposes	EN 61099	-
IEC 61378-1	-	Convertor transformers - Part 1: Transformers for industrial applications	EN 61378-1	-
IEC 61378-2	-	Convertor transformers - Part 2: Transformers for HVDC applications	EN 61378-2	-

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 Insulation systems.....	11
4.1 General.....	11
4.2 Winding insulation types	12
4.2.1 General	12
4.2.2 Summary of winding/system insulation types	13
4.2.3 Hybrid winding types	13
4.2.4 High-temperature insulation winding	16
5 Temperature rise limits	17
5.1 General.....	17
5.2 Thermally upgraded paper (TUP)	19
5.3 Cellulose used in ester liquid	19
6 Components and materials	19
6.1 General.....	19
6.2 Leads and cables.....	19
7 Special design considerations	20
7.1 Short-circuit considerations.....	20
7.2 Dielectric requirements	20
7.3 Temperature requirements.....	20
7.4 Overload.....	22
8 Required information	23
8.1 Information to be provided by the purchaser	23
8.1.1 Ambient temperatures and loading cycle.....	23
8.1.2 Other unusual service conditions	23
8.2 Information to be provided by the manufacturer	23
8.2.1 Thermal characteristics.....	23
8.2.2 Guarantees.....	23
9 Rating plate and additional information.....	23
9.1 Rating plate	23
9.2 Transformer manual.....	24
10 Test requirements.....	24
10.1 Routine, type and special tests	24
10.2 Dissolved gas analysis.....	24
10.3 OD cooled compact transformers	24
10.4 Evaluation of temperature-rise tests for windings with multiple hot-spots	24
10.5 Dielectric type tests	26
11 Supervision, diagnostics, and maintenance	27
11.1 General.....	27
11.2 Transformers filled with mineral insulating oil.....	27
11.3 Transformers filled with high-temperature insulating liquids	27
Annex A (informative) Insulation materials	28

Annex B (informative) Rapid temperature increase and bubble generation	35
Annex C (informative) Ester liquid and cellulose	38
Annex D (normative) Insulation system coding	52
Bibliography.....	55
Figure 1 – Example of semi-hybrid insulation windings	14
Figure 2 – Example of a mixed hybrid insulation winding	15
Figure 3 – Example of full hybrid insulation windings	16
Figure 4 – Example of high-temperature insulation system	17
Figure 5 – Temperature gradient conductor to liquid	21
Figure 6 – Modified temperature diagram for windings with mixed hybrid insulation system	26
Figure A.1 – Example of a thermal endurance graph.....	29
Figure B.1 – Bubble evolution temperature chart.....	36
Figure C.1 – Tensile strength ageing results of TUP in mineral oil and natural ester liquid.....	39
Figure C.2 – Composite tensile strength ageing results of TUP in mineral oil and natural ester liquid	40
Figure C.3 – DP ageing results of TUP in mineral oil and natural ester liquid	41
Figure C.4 – Composite DP ageing results of TUP in mineral oil and natural ester liquid.....	42
Figure C.5 – Tensile strength ageing results of kraft paper in mineral oil and natural ester liquid.....	42
Figure C.6 – Composite tensile strength ageing results of kraft paper in mineral oil and natural ester liquid	43
Figure C.7 – DP ageing results of kraft paper in mineral oil and natural ester liquid	43
Figure C.8 – Composite DP ageing results of kraft paper in mineral oil and natural ester liquid.....	44
Figure C.9 – Infrared spectra of kraft paper aged in liquid at 110 °C for 175 days	46
Figure C.10 – Unit life versus temperature of TUP ageing data (least squares fit).....	48
Figure C.11 – Unit life versus temperature of kraft paper ageing data (least squares fit)	48
Table 1 – Preferred insulation system thermal classes	12
Table 2 – Winding/system insulation comparison	13
Table 3 – Maximum continuous temperature rise limits for transformers with hybrid insulation systems	18
Table 4 – Maximum continuous temperature rise limits for transformers with high-temperature insulation systems.....	19
Table 5 – Suggested maximum overload temperature limits for transformers with hybrid insulation systems.....	22
Table 6 – Suggested maximum overload temperature limits for transformers with high-temperature insulation systems.....	22
Table A.1 – Typical properties of solid insulation materials	32
Table A.2 – Typical enamels for wire insulation	33
Table A.3 – Typical performance characteristics of unused insulating liquids	34
Table C.1 – Effect of moisture solubility limits on cellulose moisture reduction.....	46
Table C.2 – Comparison of ageing results.....	47

Table C.3 – Maximum temperature rise for ester liquid/cellulose insulation systems 49

Table C.4 – Suggested maximum overload temperature limits for ester liquid/cellulose insulation systems 49

This document is a preview generated by EVS

INTRODUCTION

This part of IEC 60076 standardizes liquid-immersed transformers that use high-temperature insulation. As a system, the solid insulation may encompass a broad range of materials with varying degrees of thermal capability. The insulating and cooling liquids also vary substantially, ranging from mineral oil to a number of liquids that also have a range of thermal capability.

This international standard is not intended to stand alone, but rather builds on the information and guidelines documented in other parts of the IEC 60076 series. Accordingly, this document follows two guiding principles. The first principle is that liquid-immersed transformers are well known and are well defined in other parts of this series and therefore, the details of these transformers are not repeated in this international standard, except where reference has value, or where repetition is considered appropriate for purposes of emphasis or comparison.

The second principle is that the materials used in normal liquid-immersed transformers, typically kraft paper, pressboard, wood, mineral oil, paint and varnish, which operate within temperature limits given in IEC 60076-2, are well known and are considered normal or conventional. All other insulation materials, either solid or liquid that have a thermal capability higher than the materials used in this well-known system of insulation materials are considered high-temperature. Consequently, this standard or normal insulation system is defined as the “conventional” insulation system for comparison purposes and these normal thermal limits are presented for reference to illustrate the differences between other higher-temperature systems.

This international standard addresses loading, overloading, testing and accessories in the same manner. Only selected information for the “conventional” transformers is included for comparison purposes or for emphasis. All other references are directed to the appropriate IEC document.

POWER TRANSFORMERS –

Part 14: Liquid-immersed power transformers using high-temperature insulation materials

1 Scope

This part of IEC 60076 applies to liquid-immersed power transformers employing either high-temperature insulation or combinations of high-temperature and conventional insulation, operating at temperatures above conventional limits.

It is applicable to:

- power transformers in accordance with IEC 60076-1;
- convertor transformers according to IEC 61378 series;
- transformers for wind turbine applications in accordance with IEC 60076-16;
- arc furnace transformers;
- reactors in accordance with IEC 60076-6.

This part of IEC 60076 may be applicable as a reference for the use of high-temperature insulation materials in other types of transformers and reactors.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-1, *Power transformers – Part 1: General*

IEC 60076-2, *Power transformers – Part 2: Temperature rise*

IEC 60076-5, *Power transformers – Part 5: Ability to withstand short-circuit*

IEC 60076-7, *Power transformers – Part 7: Loading guide for oil-immersed power transformers*

IEC 60076-16, *Power transformers – Part 16: Transformers for wind turbine applications*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60137, *Insulated bushings for alternating voltages above 1 000 V*

IEC 60214-1, *Tap-changers – Part 1: Performance requirements and test methods*

IEC 60296, *Fluids for electrotechnical applications – Unused mineral insulating oils for transformers and switchgear*

IEC 60836, *Specifications for unused silicone insulating liquids for electrotechnical purposes*

IEC 61099, *Specifications for unused synthetic organic esters for electrical purposes*

IEC 61378-1, *Convertor transformers – Part 1: Transformers for industrial applications*

IEC 61378-2, *Convertor transformers – Part 2: Transformers for HVDC applications*

3 Terms and definitions

For the purposes of this document, the following terms and definitions, as well as those given in IEC 60076-1 and IEC 60076-2 apply.

3.1

insulation system

system composed of solid insulating materials and an insulating liquid

3.2

temperature index

TI

numerical value of the temperature in degrees Celsius derived from the thermal endurance relationship at a time of 20 000 h (or other specified time)

[SOURCE: IEC 60050-212:2010, 212-12-11, modified – Notes 1 and 2 have been deleted]

3.3

thermal class

designation of Electrical Insulation Materials (EIM) or Electrical Insulation Systems (EIS) equal to the numerical value of the maximum used temperature in degrees Celsius for which the EIM/EIS is appropriate

Note 1 to entry: See IEC 60085.

3.4

conventional

modifier applied to temperature-rise limits, insulation materials or insulation systems operating at temperature limits defined by IEC 60076-2

3.5

kraft paper

paper made almost entirely from pulp of high mechanical strength, manufactured from soft-wood by the sulphate process

[SOURCE: IEC 60050-212:2010, 212-16-03]

3.6

thermally upgraded paper

TUP

cellulose-based paper which has been chemically modified to reduce the rate at which the paper decomposes

Note 1 to entry: See IEC 60076-2 for the complete definition.

Note 2 to entry: This note applies to the French language only.

3.7

high-temperature

temperature rise limits and/or insulation materials applied in systems consisting of solid materials and/or liquid, capable of operating at higher temperatures than conventional