

**Measuring relays and protection equipment -- Part 127:
Functional requirements for over/under voltage
protection**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 60255-127:2014 sisaldab Euroopa standardi EN 60255-127:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 60255-127:2014 consists of the English text of the European standard EN 60255-127:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 10.01.2014.	Date of Availability of the European standard is 10.01.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.120.70

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English version

**Measuring relays and protection equipment -
Part 127: Functional requirements for over/under voltage protection
(IEC 60255-127:2010)**

Relais de mesure et dispositifs de protection -
Partie 127: Exigences fonctionnelles pour les
protections à minimum et maximum de tension
(CEI 60255-127:2010)

Messrelais und Schutzeinrichtungen -
Teil 127: Funktionsnorm für Über-
/Unterspannungsschutz
(IEC 60255-127:2010)

This European Standard was approved by CENELEC on 2013-09-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 95/254/CDV, future edition 1 of IEC 60255-127, prepared by IEC/TC 95 "Measuring relays and protection equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60255-127:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-07-10
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-09-19

This document supersedes EN 60255-3:1998.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60255-127:2010 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61850	NOTE	Harmonized in EN 61850 series.
IEC 61850-7-4	NOTE	Harmonized as EN 61850-7-4.
IEC 61850-9-2	NOTE	Harmonized as EN 61850-9-2.

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60044	series	Instrument transformers	EN 60044	series
IEC 60255-1	-	Measuring relays and protection equipment Part 1: Common requirements	EN 60255-1	-

CONTENTS

FOREWORD.....	4
1 Scope and object.....	6
2 Normative references	6
3 Terms and definitions	6
4 Specification of the function.....	8
4.1 General.....	8
4.2 Input energising quantities/Energising quantities	8
4.3 Binary input signals	9
4.4 Functional logic	9
4.4.1 Operating characteristics	9
4.4.2 Reset characteristics	13
4.5 Binary output signals	14
4.5.1 Start (pick-up) signal	14
4.5.2 Operate (trip) signal.....	15
4.5.3 Other binary output signals.....	15
5 Performance specification	15
5.1 Accuracy related to the characteristic quantity.....	15
5.2 Accuracy related to the operate time	15
5.3 Accuracy related to the reset time	16
5.4 Transient performance	16
5.4.1 Overshoot time	16
5.4.2 Response to time varying value of the characteristic quantity	16
5.5 Voltage transformer requirements	16
6 Functional test methodology.....	16
6.1 General.....	16
6.2 Determination of steady state errors related to the characteristic quantity	17
6.2.1 Accuracy of setting (start) value	17
6.2.2 Reset ratio determination.....	18
6.3 Determination of steady state errors related to the start and operate time	18
6.4 Determination of steady state errors related to the reset time	19
6.5 Determination of transient performance	20
6.5.1 Overshoot time for undervoltage protection	20
6.5.2 Response to time varying value of the characteristic quantity for dependent time relays	20
7 Documentation requirements	21
7.1 Type test report.....	21
7.2 Other user documentation	22
Annex A (informative) Reset time determination for relays with trip output only.....	23
Bibliography.....	24
Figure 1 – Simplified protection function block diagram.....	8
Figure 2 – Overvoltage independent time characteristic	9
Figure 3 – Undervoltage independent time characteristic	10
Figure 4 – Dependent time characteristic for overvoltage protection	11
Figure 5 – Dependent time characteristic for undervoltage protection	12

Figure 6 – Definite time reset characteristic	14
Figure 7 – Definite time reset characteristic (alternative solution with instantaneous reset after relay operation).....	14
Figure 8 – Test waveform	21
Figure A.1 – Dependent reset time determination	23
Table 1 – Test points for overvoltage elements	19
Table 2 – Test points for undervoltage elements	19
Table 3 – Test points for overvoltage elements	20
Table 4 – Test points for undervoltage elements	20
Table 5 – Recommended values for the test	21

MEASURING RELAYS AND PROTECTION EQUIPMENT –

Part 127: Functional requirements for over/under voltage protection

1 Scope

This part of IEC 60255 specifies minimum requirements for over/under voltage relays. The standard includes specification of the protection function, measurement characteristics and time delay characteristics.

This standard defines the influencing factors that affect the accuracy under steady state conditions and performance characteristics during dynamic conditions. The test methodologies for verifying performance characteristics and accuracy are also included in this standard.

The over/under voltage functions covered by this standard are as follows:

	IEEE/ANSI C37.2 Function numbers	IEC 61850-7-4 Logical nodes
Phase undervoltage protection	27	PTUV
Positive sequence undervoltage protection	27D	PTUV
Phase overvoltage protection	59	PTOV
Residual/zero-sequence overvoltage protection	59N/59G	PTOV
Negative sequence/ unbalance overvoltage protection	47	PTOV

The general requirements for measuring relays and protection equipment are specified in IEC 60255-1.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60044 (all parts), *Instrument transformers*

IEC 60255-1, *Measuring relays and protection equipment – Part 1: Common requirements*

3 Terms and definitions

For the purposes of this document, the following terms and definition apply

3.1

theoretical curve of time versus characteristic quantity

curve which represents the relationship between the theoretical specified operate time and the characteristic quantity