

VALGUSTID. OSA 1: ÜLDNÕUDED JA KATSETUSED

Luminaires - Part 1: General requirements and tests

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 60598-1:2015 sisaldab Euroopa standardi EN 60598-1:2015 ingliskeelset teksti.	This Estonian standard EVS-EN 60598-1:2015 consists of the English text of the European standard EN 60598-1:2015.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 23.01.2015.	Date of Availability of the European standard is 23.01.2015.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.140.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Aru 10, 10317 Tallinn, Eesti; koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Luminaire -
Part 1: General requirements and tests
(IEC 60598-1:2014 , modified)

Luminaire -
Partie 1: Exigences générales et essais
(IEC 60598-1:2014 , modifiée)

Leuchten -
Teil 1: Allgemeine Anforderungen und Prüfungen
(IEC 60598-1:2014 , modifiziert)

This European Standard was approved by CENELEC on 2014-10-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 34D/1110/FDIS, future edition 8 of IEC 60598-1, prepared by SC 34D "Luminaires" of IEC/TC 34 "Lamps and related equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60598-1:2015.

A draft amendment, which covers common modifications to IEC 60598-1 (34D/1110/FDIS), was prepared by CLC/TC 34Z "Luminaires and associated equipment" and approved by CENELEC.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-10-20
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-10-20

This document supersedes EN 60598-1:2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

Clauses, subclauses, notes, tables, figures and annexes which are additional to those in IEC 60598-1:2014 are prefixed "Z".

Endorsement notice

The text of the International Standard IEC 60598-1:2014 was approved by CENELEC as a European Standard with agreed common modifications.

CONTENTS

FOREWORD.....	9
SECTION 0: GENERAL INTRODUCTION.....	11
0.1 Scope	11
0.2 Normative references	12
0.3 General requirements.....	15
0.4 General test requirements and verification.....	15
0.5 Components of luminaires	16
0.6 List of parts of IEC 60598-2.....	17
SECTION 1: TERMS AND DEFINITIONS	18
1.1 General.....	18
1.2 Terms and definitions.....	18
SECTION 2: CLASSIFICATION OF LUMINAIRES.....	31
2.1 General.....	31
2.2 Classification according to type of protection against electric shock	31
2.3 Classification according to degree of protection against ingress of dust, solid objects and moisture.....	31
2.4 Classification according to material of supporting surface for which the luminaire is designed	31
2.5 Classification according to the circumstances of use	32
SECTION 3: MARKING	32
3.1 General.....	32
3.2 Marking on luminaires	32
3.3 Additional information.....	37
3.4 Test of marking.....	39
SECTION 4: CONSTRUCTION.....	40
4.1 General.....	40
4.2 Replaceable components	40
4.3 Wireways	40
4.4 Lampholders	40
4.5 Starterholders	42
4.6 Terminal blocks.....	42
4.7 Terminals and supply connections	43
4.8 Switches	45
4.9 Insulating linings and sleeves	45
4.10 Double and reinforced insulation.....	46
4.11 Electrical connections and current-carrying parts	47
4.12 Screws and connections (mechanical) and glands	48
4.13 Mechanical strength	51
4.14 Suspensions, fixings and means of adjustment.....	54
4.15 Flammable materials	58
4.16 Luminaires for mounting on normally flammable surfaces	59
4.17 Drain holes.....	60
4.18 Resistance to corrosion.....	60
4.19 Ignitors.....	61
4.20 Rough service luminaires – Vibration requirements.....	61
4.21 Protective shield.....	61

4.22	Attachments to lamps	62
4.23	Semi-luminaires	63
4.24	Photobiological hazards	63
4.25	Mechanical hazard	64
4.26	Short-circuit protection	64
4.27	Terminal blocks with integrated screwless earthing contacts	64
4.28	Fixing of thermal sensing controls	64
4.29	Luminaire with non replaceable light source	65
4.30	Luminaires with non-user replaceable light sources	65
4.31	Insulation between circuits	65
4.32	Overvoltage protective devices	68
SECTION 5: EXTERNAL AND INTERNAL WIRING		68
5.1	General	68
5.2	Supply connection and other external wiring	68
5.3	Internal wiring	73
SECTION 6: Not used		76
SECTION 7: PROVISION FOR EARTHING		76
7.1	General	76
7.2	Provision for earthing	76
SECTION 8: PROTECTION AGAINST ELECTRIC SHOCK		78
8.1	General	78
8.2	Protection against electric shock	78
SECTION 9: RESISTANCE TO DUST, SOLID OBJECTS AND MOISTURE		82
9.1	General	82
9.2	Tests for ingress of dust, solid objects and moisture	82
9.3	Humidity test	86
SECTION 10: INSULATION RESISTANCE AND ELECTRIC STRENGTH, TOUCH CURRENT AND PROTECTIVE CONDUCTOR CURRENT		86
10.1	General	86
10.2	Insulation resistance and electric strength	87
10.3	Touch current, protective conductor current and electric burn	90
SECTION 11: CREEPAGE DISTANCES AND CLEARANCES		91
11.1	General	91
11.2	Creepage distances and clearances	91
SECTION 12: ENDURANCE TEST AND THERMAL TEST		94
12.1	General	94
12.2	Selection of lamps and ballasts	94
12.3	Endurance test	94
12.4	Thermal test (normal operation)	96
12.5	Thermal test (abnormal operation)	101
12.6	Thermal test (failed windings in lamp control gear)	105
12.7	Thermal test in regard to fault conditions in lamp control gear or electronic devices incorporated in thermoplastic luminaires	107
SECTION 13: RESISTANCE TO HEAT, FIRE AND TRACKING		110
13.1	General	110
13.2	Resistance to heat	110
13.3	Resistance to flame and ignition	110
13.4	Resistance to tracking	111

SECTION 14: SCREW TERMINALS	112
14.1 General	112
14.2 Terms and definitions	112
14.3 General requirements and basic principles	113
14.4 Mechanical tests	115
SECTION 15: SCREWLESS TERMINALS AND ELECTRICAL CONNECTIONS.....	118
15.1 General	118
15.2 Terms and definitions	119
15.3 General requirements	119
15.4 General instructions on tests	120
15.5 Terminal and connections for internal wiring	121
15.6 Terminals and connections for external wiring	123
Annex A (normative) Test to establish whether a conductive part may cause an electric shock.....	151
Annex B (normative) Test lamps.....	152
B.1 General	152
B.2 Filament lamps within the scope of IEC 60432-1 and IEC 60432-2	152
B.2.1 Principal modes of heat transfer and lamps used for testing	152
B.2.2 Filament test lamps.....	152
B.3 Halogen lamps within the scope of IEC 60432-3	154
B.4 Tubular fluorescent and other discharge lamps	154
B.5 LED modules within the scope of IEC 62031	154
Annex C (normative) Abnormal circuit conditions	155
Annex D (normative) Draught-proof enclosure	158
Annex E (normative) Determination of winding temperature rises by the increase-in-resistance method.....	161
Annex F (normative) Test for resistance to stress corrosion of copper and copper alloys	162
F.1 Test cabinet	162
F.2 Test solution	162
F.3 Test piece	162
F.4 Test procedure.....	163
Annex G (normative) Measurement of touch current and protective conductor current).....	164
Annex H (Void).....	168
Annex I (Void).....	169
Annex J (informative) Explanation of IP numbers for degrees of protection	170
Annex K (informative) Temperature measurement	172
K.1 Temperature measurements of the luminaire	172
K.2 Temperature measurement of the insulation parts of lampholders	173
Annex L (informative) Guide to good practice in luminaire design.....	175
L.1 General	175
L.2 Plastics in luminaires.....	175
L.3 Rust resistance	176
L.4 Corrosion resistance	176
L.5 Chemically corrosive atmospheres	177
L.6 Reflector design	177
L.7 Components in different kinds of luminaires.....	178
L.8 Recommendations for electromagnetic ballast protection for end of life phenomenon of HID lamps	179

L.9	Resistance against the effects of vibration	179
L.10	Flammability of components	179
Annex M (normative)	Determination of creepage distances and clearances	180
Annex N (informative)	Explanation of marking for luminaires that are not suitable for mounting on normally flammable surfaces and covering with insulation materials	181
N.0	General	181
N.1	Protection against flame	181
N.2	Protection against heat	181
N.2.1	Spacing	182
N.2.2	Temperature measurements of mounting surface under abnormal or failed ballast conditions	182
N.3	Thermal protectors	183
N.4	Deletion of the F mark requirements	184
Annex O (Void)	185
Annex P (normative)	Absorption requirements for the protective shield to be fitted to luminaires designed for metal halide lamps which emit a high level of UV radiation	186
P.1	General	186
P.2	Procedure A	186
P.3	Procedure B	187
Annex Q (informative)	Conformity testing during manufacture	188
Q.1	General	188
Q.2	Testing	188
Annex R (normative)	Schedule of amended subclauses containing more serious/critical requirements which require products to be retested	190
Annex S (normative)	Requirements for the identification of a family or range of luminaires for type testing	191
S.1	General	191
S.2	Range or family of luminaires	191
Annex T (informative)	Reference to Class 0	192
T.1	General	192
T.2	Definition	192
T.3	Requirements and tests	192
Annex U (informative)	Creepage and clearances distances for luminaires where a higher degree of availability (impulse withstand category III) may be requested	193
U.1	General	193
U.2	Requirements for impulse withstand category III	193
Annex V (normative)	Additional test requirements for terminal blocks with integrated screwless earthing contact for direct connection to the luminaire housing or to parts of the body	195
V.1	Additional requirements to 7.2.1	195
V.2	Additional requirements to 7.2.3	195
Annex W (normative)	Alternative thermal test for thermoplastic luminaires	197
W.1	Thermal test in regard to fault conditions in lamp controlgear or electronic devices without temperature sensing controls in thermoplastic luminaires for fluorescent lamps ≤ 70 W	197
Annex X (normative)	199
Bibliography	201
Figure 1 – Symbols (1 of 2)	128

Figure 2 – Terminal block arrangement for installation test for luminaires with connecting leads (tails)	129
Figure 3 – <i>This figure has been withdrawn from the present edition.</i>	129
Figure 4 – Illustration of the requirements of 4.15	130
Figure 5 – <i>This figure has been withdrawn from the present edition.</i>	130
Figure 6 – Apparatus for proving protection against dust.....	131
Figure 7 – Apparatus for testing protection against rain and splashing	132
Figure 8 – Nozzle for spray test.....	133
Figure 9 – Relation between winding temperature and mounting surface temperature	134
Figure 10 – Ball-pressure apparatus	135
Figure 11 – Arrangement and dimensions of the electrodes for the tracking test	135
Figure 12 – Pillar terminals.....	136
Figure 13 – Screw terminals and stud terminals (1 of 2).....	137
Figure 14 – Saddle terminals.....	139
Figure 15 – Lug terminals.....	140
Figure 16 – Mantle terminals	141
Figure 17 – Construction of electrical connections	142
Figure 18 – Examples of spring-type screwless terminals	142
Figure 19 – Further examples of screwless terminals.....	143
Figure 20 – Illustration of the terms “lopping-in” and “through wiring”	144
Figure 21 – Apparatus for ball impact tests.....	145
Figure 22 – Examples of self-tapping, thread-cutting and thread-forming screws (from ISO 1891)	145
Figure 23 – <i>This figure has been withdrawn from the present edition.</i>	145
Figure 24 – Illustration of creepage and clearance measurements at a supply terminal	146
Figure 25 – Tumbling barrel	146
Figure 26 – Test circuit for safety during insertion.....	147
Figure 27 – Ignition temperatures of wood as a function of time	147
Figure 28 – Example of permitted degree of soldering	148
Figure 29 – Test chain	148
Figure 30 – Example of a thread forming screw used in a groove of a metallic material.....	149
Figure 31 – Electro-mechanical contact system with plug/socket connection	150
Figure 32 – Test circuit for luminaires incorporating fluorescent lamp ≤ 70 W	150
Figure C.1 – Circuit for testing rectifying effect (some capacitive starterless ballasts only)	156
Figure C.2 – Circuit for testing rectifying effect (ballasts for single pin lamps)	156
Figure C.3 – Circuit for testing rectifying effect of some high pressure sodium and some metal halide lamps.....	157
Figure D.1 – Example of test recess where a luminaire comprises separate parts	159
Figure D.2 – Correct test box size (insulating ceilings) for settable and adjustable luminaires	160
Figure G.1 – Test configuration: single-phase equipment on star TN or TT system.....	166
Figure G.2 – Measuring network, touch current weighted for perception or reaction	166
Figure G.3 – Measuring network, touch current weighted for let-go (for portable class I luminaires).....	166

Figure G.4 – Measuring network, weighted for high frequency protective conductor currents	167
Figure K.1 – Placing of thermocouples on a typical lampholder	174
Figure V.1 – Arrangement for voltage drop test.....	196
Figure X.1 – Declaration of LV_{supply} and U_{out} and the insulation barriers between the light source and accessible parts.....	199
Table 3.1 – Marking	33
Table 4.1 – Torque tests on screws	49
Table 4.2 – Torque tests on glands.....	51
Table 4.3 – Impact energy and spring compression	52
Table 4.4 – Test on semi-luminaires	56
Table 4.5 – Test on adjusting devices.....	57
Table 5.1 – Supply cord.....	69
Table 5.2 – Tests for cord anchorage	72
Table 9.1 – Solid-object-proof luminaire test.....	84
Table 10.1 – Minimum insulation resistance.....	88
Table 10.2 – Electric strength.....	90
Table 10.3 – Limits of touch current or protective conductor current and electric burn	91
Table 11.1 – Minimum distances for a.c. (50/60 Hz) sinusoidal voltages (to be used in conjunction with Annex M).....	93
Table 11.2 – Minimum distances for sinusoidal or non-sinusoidal pulse voltages.....	94
Table 12.1 – Maximum temperatures under the test conditions of 12.4.2, for principal parts (1 of 2)	99
Table 12.2 – Maximum temperatures under the test conditions of 12.4.2, for common materials used in luminaires (1 of 2)	100
Table 12.3 – Maximum temperatures under the test conditions of 12.5.1.....	103
Table 12.4 – Maximum temperature of windings under abnormal operating conditions and at 110 % of rated voltage for lamp control gear	104
Table 12.5 – Maximum temperature of windings under abnormal operating conditions and at 110 % of rated voltage for lamp control gear marked “D6”	104
Table 12.6 – Temperature overshoot time limitation.....	106
Table 14.1 – Nominal cross-sectional areas of conductors according to terminal sizes.....	114
Table 14.2 – Nominal cross-sectional areas of conductors according to maximum current.....	114
Table 14.3 – Composition of conductors	115
Table 14.4 – Torque to be applied to screws and nuts	117
Table 14.5 – Pull to be applied to conductor	118
Table 15.1 – Conductor rating	124
Table 15.2 – Conductor pull force.....	124
Table F.1 – pH value of the test solution.....	162
Table G.1 – Position of switch e, n and p for the measurements of the different classes of luminaires	165
Table J.1 – Degrees of protection indicated by the first characteristic numeral	170
Table J.2 – Degrees of protection indicated by the second characteristic numeral	171
Table L.1 – Damaging influences.....	175

Table M.1 – Determination of creepage distances and clearances (see Table 11.1)	180
Table N.1 – Guidance on when to use the symbol and its explanation on the luminaire or in the manufacturer’s instructions provided with the luminaire	181
Table N.2 – Thermal protection operation	183
Table Q.1 – Minimum values for electrical tests	189
Table U.1 – Minimum distances for a.c. (50/60 Hz) sinusoidal voltages impulse withstand category III	194
Table X.1 – Insulation requirements between active parts and accessible conductive parts	200

This document is a preview generated by EVS

LUMINAIRES –

Part 1: General requirements and tests

SECTION 0: GENERAL INTRODUCTION

0.1 Scope

This Part 1 of IEC 60598 specifies general requirements for luminaires, incorporating electric light sources for operation from supply voltages up to 1 000 V. The requirements and related tests of this standard cover: classification, marking, mechanical construction, electrical construction and photobiological safety.

Each section of this Part 1 is read in conjunction with this Section 0 and with other relevant sections to which reference is made.

Each part of IEC 60598-2 details requirements for a particular type of luminaire or group of luminaires on supply voltages not exceeding 1 000 V. These parts are published separately for ease of revision and additional sections will be added as and when a need for them is recognized.

The presentation of photometric data for luminaires is under consideration by the International Commission on Illumination (CIE) and is not, therefore, included in this Part 1.

Requirements are included in this Part 1 for luminaires incorporating ignitors with nominal peak values of the voltage pulse not exceeding those of Table 11.2. The requirements apply to luminaires with ignitors built into ballasts and to luminaires with ignitors separate from ballasts. For luminaires with ignitors built into lamps, the requirements are under consideration.

Requirements for semi-luminaires are included in this Part 1.

In general, this Part 1 covers safety requirements for luminaires. The object of this Part 1 is to provide a set of requirements and tests which are considered to be generally applicable to most types of luminaires and which can be called up as required by the detail specifications of IEC 60598-2. This Part 1 is thus not regarded as a specification in itself for any type of luminaire, and its provisions apply only to particular types of luminaires to the extent determined by the appropriate part of IEC 60598-2.

The parts of IEC 60598-2, in making reference to any of the sections of Part 1, specify the extent to which that section is applicable and the order in which the tests are to be performed; they also include additional requirements as necessary.

The order in which the sections of Part 1 are numbered has no particular significance as the order in which their provisions apply is determined for each type of luminaire or group of luminaires by the appropriate part of IEC 60598-2. All parts of IEC 60598-2 are self-contained and therefore do not contain references to other parts of IEC 60598-2.

Where the requirements of any of the sections of Part 1 are referred to in the parts of IEC 60598-2 by the phrase "The requirements of section... of IEC 60598-1 apply", this phrase is to be interpreted as meaning that all the requirements of that section of Part 1 apply except those which are clearly inapplicable to the particular type of luminaire covered by that part of IEC 60598-2.

For explosion proof luminaires, as covered by IEC 60079, the requirements of IEC 60598 (selecting the appropriate parts 2) are applied in addition to the requirements of IEC 60079. In the event of any conflict between IEC 60598 and IEC 60079, the requirements of IEC 60079 take priority.

Attention is drawn to lamp performance standards which contain "information for luminaire design"; this should be followed for proper lamp operation; however, this standard does not require the testing of lamp performance as part of the type test approval for luminaires.

Improvements in safety to take into account the state of the art technology are incorporated in the standards with revisions and amendments on an ongoing basis. Regional standardisation bodies may include statements in their derived standards to cover products which have complied with the previous document as shown by the manufacturer or standardization body. The statements may require that for such products, the previous standard may continue to apply to production until a defined date after which the new standard shall apply.

0.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60061, *Lamp caps and holders together with gauges for the control of interchangeability and safety*

IEC 60061-2, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 2: Lampholders*

IEC 60061-3, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 3: Gauges*

IEC 60065:2001, *Audio, video and similar electronic apparatus – Safety requirements*
Amendment 1:2005

IEC 60068-2-6:2007, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-14:2009, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC/TR 60083, *Plugs and socket-outlets for domestic and similar general use standardized in member countries of IEC*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60155, *Glow-starters for fluorescent lamps*

IEC 60227(all parts), *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60238, *Edison screw lampholders*

IEC 60245 (all parts), *Rubber insulated cables – Rated voltages up to and including 450/750 V*

IEC 60320 (all parts), *Appliance couplers for household and similar general purposes*

IEC 60357, *Tungsten halogen lamps (non-vehicle) – Performance specifications*

IEC 60360, *Standard method of measurement of lamp cap temperature rise*

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification: Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60400, *Lampholders for tubular fluorescent lamps and starterholders*

IEC 60417, *Graphical symbols for use on equipment* Available at: <http://www.graphical-symbols.info/equipment>

IEC 60432-1, *Incandescent lamps – Safety specifications – Part 1: Tungsten filament lamps for domestic and similar general lighting purposes*

IEC 60432-2, *Incandescent lamps – Safety specifications – Part 2: Tungsten halogen lamps for domestic and similar general lighting purposes*

IEC 60432-3, *Incandescent lamps – Safety specifications – Part 3: Tungsten-halogen lamps (non-vehicle)*

IEC 60449:1973, *Voltage bands for electrical installations of buildings*
Amendment 1:1979

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60570:2003, *Electrical supply track systems for luminaires*

IEC 60598-2 (all parts), *Luminaires – Part 2: Particular requirements*

IEC 60598-2-4, *Luminaires – Part 2: Particular requirements – Section 4: Portable general purpose luminaires*

IEC 60662, *High-pressure sodium vapour lamps – Performance specifications*

IEC 60682, *Standard method of measuring the pinch temperature of quartz-tungsten-halogen lamps*

IEC 60684 (all parts), *Flexible insulating sleeving*

IEC 60695-2-11, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products*

IEC 60695-11-5, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

IEC 60838 (all parts), *Miscellaneous lampholders*

IEC 60989, *Separating transformers, autotransformers, variable transformers and reactors*

IEC 60990:1999, *Methods of measurement of touch current and protective conductor current*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61058-1:2000, *Switches for appliances – Part 1: General requirements*

IEC 61167, *Metal halide lamps – Performance specification*

IEC 61184, *Bayonet lampholders*

IEC 61199, *Single-capped fluorescent lamps – Safety specifications*

IEC 61249 (all parts), *Materials for printed boards and other interconnecting structures*

IEC 61347 (all parts), *Lamp controlgear*

IEC 61347-1, *Lamp controlgear – Part 1: General and safety requirements*

IEC 61347-2-9, *Lamp controlgear – Part 2-9: Particular requirements for electromagnetic controlgear for discharge lamps (excluding fluorescent lamps)*

IEC 61558 (all parts), *Safety of power transformers, power supplies, reactors and similar products*

IEC 61558-1:2005, *Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests*

IEC 61558-2 (all parts), *Safety of power transformers, power supplies, reactors and similar products – Part 2: Particular requirements and tests*

IEC 61558-2-5, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-5: Particular requirements and test for transformer for shavers, power supply units for shavers and shaver supply units*

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*

IEC 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems – requirements and tests*

IEC 62031, *LED modules for general lighting – Safety specifications*

IEC 62035, *Discharge lamps (excluding fluorescent lamps) – Safety specifications*

IEC/TR 62778, *Application of IEC 62471 for the assessment of blue light hazard to light sources and luminaires*

IEC 80416-1, *Basic principles for graphical symbols for use on equipment – Part 1: Creation of symbol originals*

0.3 General requirements

0.3.1 Luminaires shall be so designed and constructed that in normal use they function safely and cause no danger to persons or surroundings. In general, compliance is checked by carrying out all the tests specified.

0.3.2 A luminaire shall comply with a part of IEC 60598-2. If, however, an appropriate part of IEC 60598-2 does not exist for a particular luminaire or group of luminaires, the nearest applicable part of IEC 60598-2 may be used as a guide to the requirements and tests.

Where the design of a luminaire is such that two or more parts of IEC 60598-2 are applicable, the luminaire shall comply with both or all of the appropriate sections.

0.3.3 Semi-luminaires should be regarded as luminaires for test purposes.

0.4 General test requirements and verification

0.4.1 Tests according to this standard are type tests. For the definition of a "type test", see Section 1 of this Part 1.

The requirements and tolerances permitted by this standard are related to testing of a type test sample submitted for that purpose. Compliance of the type test sample does not ensure compliance of the whole production of a manufacturer. Compliance for production is the responsibility of the manufacturer and may include routine tests and quality assurance in addition to type testing.

0.4.2 Except where otherwise specified in the sections of Part 1 or Part 2, luminaires shall be tested as delivered, and installed as for normal use, in an ambient temperature of between 10 °C and 30 °C, having regard to the manufacturer's installation instructions. The lamp (or lamps) is (are) not included except where essential for the test.

Luminaires cannot be regarded as meeting the requirements of this Part 1 unless all internal wiring is complete.

In general, the tests are made on a single sample luminaire or, where a range of similar luminaires is involved, on a single luminaire of each rated wattage in the range or on a representative selection from the range as agreed with the manufacturer (see Annex S). This selection shall include the luminaire, together with any attachments, which represents the most unfavourable combination from a testing point of view.

In accordance with IEC guidelines, new IEC standards are divided into those covering either safety or performance. In the lamp safety standards, "information for luminaire design" is given for the safe operation of lamps; this shall be regarded as normative when testing luminaires to this standard.

Each sample luminaire shall comply with all the relevant tests. In order to reduce the time of testing and to allow for any tests which may be destructive, the manufacturer may submit additional luminaires or parts of luminaires provided that these are of the same materials and design as the original luminaire and that the results of the test are the same as if carried out on an identical luminaire. Where the test for compliance is shown as being "by inspection", this shall include any necessary handling.

For track-mounted luminaires the manufacturer shall provide, together with the luminaire, a sample of the appropriate track, connector and adaptors for the luminaire to be connected.