

Industrial-process measurement, control and automation - Evaluation of system properties for the purpose of system assessment - Part 3: Assessment of system functionality

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61069-3:2016 sisaldab Euroopa standardi EN 61069-3:2016 ingliskeelset teksti.	This Estonian standard EVS-EN 61069-3:2016 consists of the English text of the European standard EN 61069-3:2016.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 28.10.2016.	Date of Availability of the European standard is 28.10.2016.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 25.040.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Industrial-process measurement, control and automation -
Evaluation of system properties for the purpose of system
assessment - Part 3: Assessment of system functionality
(IEC 61069-3:2016)**

Mesure, commande et automation dans les processus
industriels - Appréciation des propriétés d'un système en
vue de son évaluation - Partie 3: Évaluation de la
fonctionnalité d'un système
(IEC 61069-3:2016)

Leittechnik für industrielle Prozesse - Ermittlung der
Systemeigenschaften zum Zweck der Eignungsbeurteilung
eines Systems - Teil 3: Eignungsbeurteilung der
Systemfunktionalität
(IEC 61069-3:2016)

This European Standard was approved by CENELEC on 2016-07-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 65A/791/FDIS, future edition 2 of IEC 61069-3, prepared by SC 65A "System aspects" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61069-3:2016.

The following dates are fixed:

- latest date by which the document has to be (dop) 2017-04-28
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2019-10-28
standards conflicting with the
document have to be withdrawn

This document supersedes EN 61069-3:1996.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61069-3:2016 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61069-5:2016	NOTE	Harmonized as EN 61069-5:2016 (not modified).
IEC 61131-3	NOTE	Harmonized as EN 61131-3.
IEC 61158 Series	NOTE	Harmonized as EN 61158 Series.
IEC 61297	NOTE	Harmonized as EN 61297.
IEC 61512 Series	NOTE	Harmonized as EN 61512 Series.
IEC 61784 Series	NOTE	Harmonized as EN 61784 Series.
IEC/TS 62603-1:2014	NOTE	Harmonized as CLC/TS 62603-1:2014.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61069-1	2016	Industrial-process measurement, control and automation - Evaluation of system properties for the purpose of system assessment - Part 1: Terminology and basic concepts	EN 61069-1	2016
IEC 61069-2	2016	Industrial-process measurement, control and automation - Evaluation of system properties for the purpose of system assessment - Part 2: Assessment methodology	EN 61069-2	2016

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references.....	8
3 Terms, definitions, abbreviated terms, acronyms, conventions and symbols.....	8
3.1 Terms and definitions.....	8
3.2 Abbreviated terms, acronyms, conventions and symbols.....	8
4 Basis of assessment specific to functionality.....	9
4.1 Functionality properties.....	9
4.1.1 General.....	9
4.1.2 Coverage.....	9
4.1.3 Configurability.....	10
4.1.4 Flexibility.....	11
4.2 Factors influencing functionality.....	12
5 Assessment method.....	12
5.1 General.....	12
5.2 Defining the objective of the assessment.....	12
5.3 Design and layout of the assessment.....	12
5.4 Planning of the assessment program.....	13
5.5 Execution of the assessment.....	13
5.6 Reporting of the assessment.....	13
6 Evaluation techniques.....	13
6.1 General.....	13
6.2 Analytical evaluation techniques.....	13
6.2.1 Coverage.....	13
6.2.2 Configurability.....	14
6.2.3 Flexibility.....	14
6.3 Empirical evaluation techniques.....	14
6.4 Additional topics for evaluation techniques.....	14
Annex A (informative) Checklist and/or example of SRD for system functionality.....	15
Annex B (informative) Checklist and/or example of SSD for system functionality.....	16
B.1 SSD information.....	16
B.2 Check points for system functionality.....	16
Annex C (informative) Example of a list of assessment items (information from IEC TS 62603-1).....	17
C.1 Overview.....	17
C.2 System characteristics.....	17
C.2.1 Overview.....	17
C.2.2 System scalability.....	17
C.2.3 System expandability.....	17
C.2.4 Integration of subsystems.....	17
C.2.5 Automatic documentation.....	17
C.2.6 Programming languages for control.....	18
C.2.7 BCS localisation.....	19
C.3 Functionality properties.....	20

C.3.1	Input/output specifications.....	20
C.3.2	Conventional input/output.....	20
C.3.3	Input/output from/to smart devices.....	21
C.3.4	Fieldbus connection to the remote I/O	21
C.3.5	Input validation	21
C.3.6	Special inputs	21
C.3.7	Software requirements	21
C.3.8	Alarm management.....	22
C.3.9	Events management.....	24
C.3.10	Historical archiving.....	25
C.3.11	Trend and statistics management	26
C.3.12	Communication requirements	26
C.3.13	Fieldbus.....	27
C.3.14	Controller network.....	27
C.3.15	Control room network.....	27
C.3.16	External link.....	28
C.3.17	Communication interfaces	28
C.3.18	Communication with ERP system	28
C.3.19	Communication with a manufacturing execution system (MES).....	29
C.3.20	Software simulator	29
C.3.21	Simulator of the control logic	29
C.3.22	On-line debugging.....	29
C.3.23	Simulator of the I/O.....	30
C.3.24	Remote supervisory functions.....	30
C.3.25	Technology and scope of the BCS	30
C.3.26	Basic architecture	30
C.4	Configurability	31
C.4.1	System configuration.....	31
C.4.2	On-line configuration.....	32
C.4.3	Off-line configuration.....	32
C.4.4	Configuration in simulation mode.....	32
C.4.5	Graphical resources	32
C.5	Flexibility	32
C.5.1	Spare capacity of the system.....	32
C.5.2	Total number of I/O	33
C.5.3	Number of tags	33
C.5.4	Number of control loops	34
C.5.5	System scalability	34
C.5.6	System expandability	34
Bibliography	35
Figure 1 – General layout of IEC 61069.....		7
Figure 2 – Functionality.....		9
Figure 3 – Configuration methods.....		10
Figure C.1 – Communication networks in a BCS		27
Figure C.2 – Example of a layout drawing.....		31
Table A.1 – SRD checklist.....		15

INTRODUCTION

IEC 61069 deals with the method which should be used to assess system properties of a basic control system (BCS). IEC 61069 consists of the following parts:

- Part 1: Terminology and basic concepts
- Part 2: Assessment methodology
- Part 3: Assessment of system functionality
- Part 4: Assessment of system performance
- Part 5: Assessment of system dependability
- Part 6: Assessment of system operability
- Part 7: Assessment of system safety
- Part 8: Assessment of other system properties

Assessment of a system is the judgement, based on evidence, of the suitability of the system for a specific mission or class of missions.

To obtain total evidence would require complete evaluation (for example under all influencing factors) of all system properties relevant to the specific mission or class of missions.

Since this is rarely practical, the rationale on which an assessment of a system should be based is:

- the identification of the importance of each of the relevant system properties,
- the planning for evaluation of the relevant system properties with a cost-effective dedication of effort to the various system properties.

In conducting an assessment of a system, it is crucial to bear in mind the need to gain a maximum increase in confidence in the suitability of a system within practical cost and time constraints.

An assessment can only be carried out if a mission has been stated (or given), or if any mission can be hypothesized. In the absence of a mission, no assessment can be made; however, evaluations can still be specified and carried out for use in assessments performed by others. In such cases, IEC 61069 can be used as a guide for planning an evaluation and it provides methods for performing evaluations, since evaluations are an integral part of assessment.

In preparing the assessment, it can be discovered that the definition of the system is too narrow. For example, a facility with two or more revisions of the control systems sharing resources, for example a network, should consider issues of co-existence and inter-operability. In this case, the system to be investigated should not be limited to the “new” BCS; it should include both. That is, it should change the boundaries of the system to include enough of the other system to address these concerns.

The part structure and the relationship among the parts of IEC 61069 are shown in Figure 1.




Figure 1 – General layout of IEC 61069

Some example assessment items are integrated in Annex C.