

**Telecontrol equipment and systems - Part 6-503:
Telecontrol protocols compatible with ISO standards and
ITU-T recommendations - TASE.2 Services and protocol**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 60870-6-503:2014 sisaldab Euroopa standardi EN 60870-6-503:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 60870-6-503:2014 consists of the English text of the European standard EN 60870-6-503:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 03.10.2014.	Date of Availability of the European standard is 03.10.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 33.200

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

**Telecontrol equipment and systems - Part 6-503: Telecontrol
protocols compatible with ISO standards and ITU-T
recommendations - TASE.2 Services and protocol
(IEC 60870-6-503:2014)**

Matériels et systèmes de téléconduite - Partie 6-503:
Protocoles de téléconduite compatibles avec les normes
ISO et les recommandations de l'UIT-T - Services et
protocole TASE.2
(CEI 60870-6-503:2014)

Fernwirkrichtungen und -systeme - Teil 6-503:
Fernwirkprotokolle, die mit ISO-Normen und ITU-T-
Empfehlungen kompatibel sind - TASE.2-Dienste und -
Protokoll
(IEC 60870-6-503:2014)

This European Standard was approved by CENELEC on 2014-08-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 57/1453/FDIS, future edition 3 of IEC 60870-6-503, prepared by IEC/TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60870-6-503:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-05-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-08-19

This document supersedes EN 60870-6-503:2002.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60870-6-503:2014 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60870-6-702	2014	Telecontrol equipment and systems - Part 6-702: Telecontrol protocols compatible with ISO standards and ITU-T recommendations - Functional profile for providing the TASE.2 application service in end systems	EN 60870-6-702	2014
IEC 60870-6-802	2014	Telecontrol equipment and systems - Part 6-802: Telecontrol protocols compatible with ISO standards and ITU-T recommendations - TASE.2 Object models	EN 60870-6-802	2014
IEC 61970-452	2013	Energy management system application program interface (EMS-API) - Part 452: CIM static transmission network model profiles	EN 61970-452	2013
IEC 61970-552	2013	Energy Management System Application Program Interface (EMS-API) - Part 552: CIMXML Model Exchange Format	EN 61970-552	2014
IEC/TS 62351-4	2007	Power systems management and associated information exchange - Data and communications security - Part 4: Profiles including MMS	-	-
ISO 9506-1	2003	Industrial automation systems - Manufacturing Message Specification - Part 1: Service definition	-	-
ISO 9506-2	2003	Industrial automation systems - Manufacturing Message Specification - Part 2: Protocol specification	-	-

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
1.1 General.....	11
1.2 Control centre.....	11
1.3 Architecture.....	11
1.4 Network Model.....	12
1.5 Relation between TASE.2 and MMS.....	13
2 Normative references.....	13
3 Terms and definitions.....	14
4 Abbreviations.....	16
5 TASE.2 Model.....	17
5.1 General.....	17
5.2 Informal TASE.2 Model Description.....	17
5.2.1 General.....	17
5.2.2 Associations.....	18
5.2.3 Bilateral agreements, bilateral tables and access control.....	19
5.2.4 Data Value objects and services.....	20
5.2.5 Data Set objects and services.....	21
5.2.6 Account Objects and Services.....	21
5.2.7 Information Message object and services.....	21
5.2.8 Transfer Set objects and services.....	21
5.2.9 Common Data Transfer mechanisms.....	24
5.2.10 Special Transfer objects and services.....	25
5.2.11 Device objects and services.....	26
5.2.12 Program objects and services.....	27
5.2.13 Event Enrollment objects and services.....	27
5.2.14 Event Condition objects and services.....	27
5.3 Formal TASE.2 model description.....	27
5.3.1 General.....	27
5.3.2 General access control requirements.....	29
5.3.3 Association management.....	30
5.3.4 Bilateral Tables.....	32
5.3.5 List of Access Control Specification.....	33
5.3.6 Data values.....	34
5.3.7 Data Sets.....	35
5.3.8 Accounts.....	37
5.3.9 Information Messages.....	37
5.3.10 Transfer Sets.....	38
5.3.11 Special Transfer objects.....	43
5.3.12 Devices.....	44
5.3.13 Programs.....	46
5.3.14 Event Enrollments.....	46
5.3.15 Event Conditions.....	46
6 Mapping of TASE.2 Object Models onto MMS Object Models.....	46
6.1 General.....	46

6.2	Object modelling notation.....	46
6.3	The virtual control centre (VCC).....	47
6.3.1	General	47
6.3.2	TASE.2 Domain mapping.....	47
6.3.3	TASE.2 Control Centre mapping	48
6.3.4	OSI Application Processes, Application Entities and Addressing.....	48
6.4	Association object model mapping	48
6.5	Bilateral Table object model mapping.....	49
6.6	Data Value object model mapping	50
6.7	Data Set object model mapping	51
6.8	Information Message object model mapping.....	52
6.9	Transfer Set object model mapping.....	53
6.9.1	General	53
6.9.2	Data Set Transfer Set object model mapping	53
6.9.3	Information Message Transfer Set object model mapping	55
6.10	Next Transfer Set object model mapping.....	56
6.11	Transfer Set Name object model mapping.....	56
6.12	Conditions object model mapping.....	56
6.13	Event Code object model mapping	57
6.14	Transfer Set Time Stamp object model mapping	57
6.15	Device object model mapping	57
7	Mapping of TASE.2 operations and actions onto MMS services	58
7.1	General.....	58
7.2	Use of MMS services	59
7.2.1	General	59
7.2.2	Association Management Mapping to MMS.....	59
7.2.3	Data Value operations mapping to MMS	62
7.2.4	Data Set operations mapping to MMS.....	66
7.2.5	Transfer Set operations and actions mapping to MMS	73
7.2.6	Device operations and actions mapping to MMS.....	81
7.2.7	Summary of TASE.2 operations	86
8	Standardized Application-specific objects	88
8.1	General.....	88
8.2	Named Type objects	88
8.2.1	General	88
8.2.2	Visible-String-32 Type	88
8.2.3	MMS ObjectName.....	88
8.2.4	Time Stamp Types.....	89
8.2.5	TimeStampExtended Type	89
8.2.6	Time Interval Types	90
8.2.7	TransferSet Types	90
8.2.8	Conditions Types.....	92
8.2.9	SupportedFeatures Type	93
8.2.10	TASE.2Version Type	93
8.3	Named Variable Objects	94
8.3.1	General	94
8.3.2	"Supported_Features".....	94
8.3.3	"Bilateral_Table_ID"	94
8.3.4	"TASE.2_Version".....	94

8.3.5	Data Value objects	94
8.3.6	Transfer Set objects	95
8.3.7	"Next_DSTransfer_Set"	95
8.3.8	"Transfer_Set_Name"	95
8.3.9	"IM_Transfer_Set"	95
8.3.10	"DSConditions_Detected"	95
8.3.11	"Transfer_Set_Time_Stamp"	96
8.3.12	"Transfer_Report_ACK"	96
8.3.13	"Transfer_Report_NACK"	96
8.4	Named Variable List objects	96
8.5	Information Message objects	96
9	Use cases for semantic integration with IEC 61970	97
9.1	General	97
9.2	Use Case 1: Determining what Measurement/MeasurementValues are available	97
9.2.1	General	97
9.2.2	Use Case 1a: Determining information associated to equipment	97
9.2.3	Use Case 1b: Determining Measurement information for non-equipment related measurements	98
9.3	Use Case 2: Exchange of Bilateral Table information	98
10	Bilateral Table semantic model	98
10.1	General	98
10.2	IEC 61970-452 Classes	100
10.2.1	Command	100
10.2.2	Control	100
10.2.3	IdentifiedObject	100
10.2.4	DiscreteCommand	101
10.2.5	MeasurementValue	101
10.2.6	Setpoint	101
10.3	ICCP Specific Classes	102
10.3.1	ICCPAccessPoint	102
10.3.2	ICCPCommandPoint	102
10.3.3	ICCPControlPoint	103
10.3.4	ICCP IndicationPoint	103
10.3.5	ICCPInformationMessage	104
10.3.6	ICCPPoint	104
10.3.7	ICCPSetPoint	104
10.3.8	ISOAPAddress	105
10.3.9	ISOUpperLayer	105
10.3.10	TASE2BilateralTable	105
10.3.11	TCP_AccessPoint	106
10.3.12	Enumerations	106
11	Conformance	107
Annex A (normative)	TASE.2 Operations and actions summary	108
Annex B (informative)	Quality of Service (QOS), Routing and Priority	110
B.1	General	110
B.2	Background	110
B.3	TASE.2 Requirements	111
B.3.1	General	111

B.3.2	Transport layer	111
B.4	Network layer.....	112
Annex C (informative)	TASE.2 Operations and actions summary	113
Annex D (informative)	TASE.2 (2002) Additional Model Elements	114
D.1	General.....	114
D.2	Informal TASE.2 Model Description.....	114
D.2.1	General	114
D.2.2	Bilateral Agreements, Bilateral Tables and access control	114
D.2.3	Account objects and services.....	114
D.2.4	Program objects and services	115
D.2.5	Event Enrollment objects and services	115
D.2.6	Event Condition objects and services	115
D.3	Formal TASE.2 Model description	116
D.3.1	General	116
D.3.2	Accounts	116
D.3.3	Accounts models	116
D.3.4	Transfer Sets.....	116
D.3.5	Transfer Account Transfer Set object model	119
D.3.6	Information Message Transfer Set object model	121
D.3.7	Special Transfer Sets	121
D.3.8	Programs.....	122
D.3.9	Event Enrollments	123
D.3.10	Event Conditions	124
Annex E (informative)	Mapping of TASE.2 (2002) object models onto MMS object models.....	125
E.1	General.....	125
E.2	Bilateral Table object model mapping.....	125
E.3	Time Series Transfer Set object model mapping	125
E.3.1	General	125
E.3.2	TSTransmissionPars Object Model Mapping	126
E.4	Account Object Model Mapping.....	127
E.5	Transfer Set Object Model Mapping	127
E.5.1	Transfer Account Transfer Set Object Model Mapping	127
E.5.2	TATransmissionPars Object Model Mapping	127
E.6	Program Object Model Mapping	127
E.7	Event Enrollment Object Model Mapping	128
E.8	Conditions Object Model Mapping	129
E.8.1	General	129
E.8.2	Event Condition Object Model Mapping	129
Annex F (informative)	Mapping of TASE.2 (2002) Operations and Actions onto MMS Services.....	131
F.1	General.....	131
F.2	Use of MMS Services.....	131
F.2.1	Association Management Mapping.....	131
F.2.2	Transfer Set Operation and Action Mapping.....	131
F.2.3	Condition Monitoring Mapping	132
F.2.4	Get Next TSTransfer Set Value Operation Mapping	136
F.2.5	Account Operations and Actions Mapping	137
F.2.6	Query Mapping	137

F.2.7	Program Operations Mapping to MMS	138
F.2.8	Event Enrollment Operations Mapping to MMS	142
F.2.9	Event Condition Actions Mapping onto MMS – Event Notification Action Mapping	144
F.2.10	Summary of TASE.2 Operations	144
Annex G (informative)	TASE.2 (2002) Standardized Application-specific Objects	146
G.1	General.....	146
G.2	Named Type Objects	146
G.2.1	General	146
G.2.2	TransferSet Types	146
G.2.3	SupportedFeatures Type	147
G.2.4	Conditions Types.....	147
G.3	Named Variable Objects	148
G.3.1	General	148
G.3.2	"Next_TSTransfer_Set".....	148
G.3.3	"TSConditions_Detected".....	148
G.3.4	"TA_Transfer_Set".....	148
G.3.5	"TAConditions_Detected".....	149
G.3.6	"Event_Code_Detected"	149
G.3.7	Information Message Objects	149
G.4	Event Condition Objects.....	149
Figure 1	– Protocol relationships.....	12
Figure 2	– TASE.2 network topologies	13
Figure 3	– Informal TASE.2 Model	18
Figure 4	– Transfer DataSet reporting mechanism	23
Figure 5	– General Transfer reporting mechanism	24
Figure 6	– Relationship between TASE.2 and real control centres	28
Figure 7	– TASE.2 server components.....	58
Figure 8	– TASE.2 Server association control elements	60
Figure 9	– Data Value operations.....	63
Figure 10	– Sequence of Get Data Value	64
Figure 11	– Data Set operations	67
Figure 12	– Sequence of Create Data Set operation	69
Figure 13	– Sequence of Delete Data Set	70
Figure 14	– Transfer Set services	74
Figure 15	– Device operations	81
Figure 16	– Sequence of Device Control.....	82
Figure 17	– Measurements and network models	97
Figure 18	– CIM and IEC semantic harmonization	99
Figure B.1	– ToS Byte field definition RFC-2474 and RFC-3168.....	112
Figure F.1	– Sequence of Transfer Set operations and actions	135
Figure F.2	– Server Program Components	138
Figure F.3	– Sequence of Program Invocation operations	142
Table 1	– Scope of the object models in the VCC	29

Table 2 – Summary of TASE.2 operations.....	87
Table A.1 – TASE.2 Operations versus MMS services	108
Table B.1 – Typical Priorities	111
Table C.1 – TASE.2 (2002) Additional Operations and Actions	113
Table F.1 – Summary of TASE.2 Operations from IEC 60870-6-503:2002	145
Table G.1 – TASE.2 Event Objects	150

INTRODUCTION

The Telecontrol Application Service Element (TASE.2) protocol (also known as Inter-Control Centre Communications Protocol, ICCP) allows for data exchange over Wide Area Networks (WANs) between a utility control centre and other control centres, other utilities, power pools, regional control centres, and Non-Utility Generators. Data exchange information consists of real-time and historical power system monitoring and control data, including measured values, scheduling data, energy accounting data, and operator messages. This data exchange occurs between one control centre's Supervisory Control And Data Acquisition/Energy Management System/Distribution Management System (SCADA/EMS/DMS) host and another centre's host, often through one or more intervening communications processors.

This part of IEC 60870 defines a mechanism for exchanging time-critical data between control centres. In addition, it provides support for device control, general messaging and control of programs at a remote control centre. It defines a standardized method of using the ISO 9506 Manufacturing Message Specification (MMS) services to implement the exchange of data. The definition of TASE.2 consists of three documents. This part of IEC 60870 defines the TASE.2 application modelling and service definitions. IEC 60870-6-702 defines the application profile for use with TASE.2. IEC 60870-6-802 defines a set of standardized object definitions to be supported.

The TASE.2 describes real control centres with respect to their external visible data and behaviour using an object oriented approach. The objects are abstract in nature and may be used in a wide variety of applications. The use of TASE.2 goes far beyond the application in the control centre to control centre communications. This standard must be understood as a tool box for any application domain with comparable requirements. i.e. the TASE.2 may be applied in areas like substation automation, power plants, factory automation, chemical plants, or others which have comparable requirements. It provides a generic solution for advanced Information and Communication Technology.

The TASE.2 version number for this standard is 2001-08. See 8.3.4 for more details.

TELECONTROL EQUIPMENT AND SYSTEMS –

Part 6-503: Telecontrol protocols compatible with ISO standards and ITU-T recommendations – TASE.2 Services and protocol

1 Scope

1.1 General

This part of IEC 60870 specifies a method of exchanging time-critical control centre data through wide-area and local-area networks using a full ISO compliant protocol stack. It contains provisions for supporting both centralized and distributed architectures. This standard includes the exchange of real-time data indications, control operations, time-series data, scheduling and accounting information, remote program control and event notification.

Though the primary objective of TASE.2 is to provide control centre (telecontrol) data exchange, its use is not restricted to control centre data exchange. It may be applied in any other domain having comparable requirements. Examples of such domains are power plants, factory automation, process control automation, and others.

This standard does not specify individual implementations or products, nor does it constrain the implementation of entities and interfaces within a computer system. This standard specifies the externally visible functionality of implementations together with conformance requirements for such functionalities.

1.2 Control centre

The model of a control centre includes four primary classes of host processors: SCADA/EMS, Demand Side Management (DSM)/ Load Management, Distributed Applications, and Display Processors. The SCADA/EMS host is the primary processor, utilizing analogue and digital monitoring data collected at power plants, Non-Utility Generators, and transmission and distribution substations via Data Acquisition Units (DAUs) and Remote Terminal Units (RTUs). The control centre typically contains redundant SCADA/EMS/DMS hosts in a "hot standby" configuration. The DSM/Load Management host(s) are used by either an operator or EMS application to initiate load management activities. The Distributed Application host(s) perform miscellaneous analysis, scheduling, or forecasting functions. Display Processors allow for local operator and dispatcher display and control. Typically, the control centre will contain one or more Local Area Networks (LANs) to connect these various hosts. The control centre will also access several WANs, often through intermediate communications processors. These WAN connections may include the company-wide area network for communications with the corporate host and a distinct real-time SCADA network. Each control centre will also have one or more TASE.2 instances to handle data exchange with remote control centres.

Other classes of host processors like archive systems, engineering stations, or quality control systems (e.g., for data recording according to ISO 9000) may also be included. The application of the TASE.2 control centre model is in principle unlimited. This model provides a common and abstract definition applicable for any real systems which have comparable requirements.

1.3 Architecture

The TASE.2 protocol relies on the use of MMS services (hence the underlying MMS protocol) to implement the control centre data exchange. Figure 1 shows the relationship of TASE.2, the MMS provider, and the rest of the protocol stack. In most cases, the values of objects being transferred are translated from/to the local machine representation automatically by the

local MMS provider. Some TASE.2 objects require a common syntax (representation) and meaning (interpretation) by both communicating TASE.2 systems. This common representation and interpretation constitutes a form of protocol. The control centre applications are not part of this standard. It is assumed that these applications request TASE.2 operations and supply control centre data and functions to the TASE.2 implementation as needed. The specific interface between TASE.2 and the control centre applications is a local issue and not part of this standard.




Figure 1 – Protocol relationships

The protocol architecture for TASE.2 requires the use of ISO protocols in layers 5 to 7 of the OSI reference model. The Transport Profiles (layers 1 to 4) can use virtually any standard or de-facto standard (e.g. TCP) connection-mode transport layer and connectionless-mode network layer (e.g., IP) services over any type of transmission media.

1.4 Network Model

The TASE.2 Data Exchange network can be either a private or public packet-switched or mesh network connecting communications processors which provide adequate routing functionality to allow for redundant paths and reliable service.

Figure 2 shows a typical network topology using a router-based Wide Area Network (WAN). The WAN provides routing and reliable service between control centres (which may include internal networks and routing capabilities).

The mesh network shown in Figure 2 demonstrates the concept of redundant paths for a mesh network. Each control centre maintains its own series of direct circuits, and also provides a mechanism for routing between those direct circuits. Control Centre C provides an alternate routing path for network traffic going from Control Centre A to B. This network configuration requires key control centres to provide significant routing capabilities.




Figure 2 – TASE.2 network topologies

1.5 Relation between TASE.2 and MMS

The TASE.2 resides on top of MMS. It describes a standardized application of MMS using the MMS services and protocol. TASE.2 enhances the functionality of MMS by specifying structured data mapped to MMS objects and assigning specific semantics to it. As an example of pure MMS services, MMS allows reading data from a remote system. The data will be responded without any specific condition. If these data are read depending on very specific conditions (e.g., on change only) then TASE.2 provides appropriate services which are not provided by MMS.

Though the specific requirements agreed upon within the IEC IEC TC 57 have led to the definition of TASE.2 there are several other application domains (outside the control centres) with less, very limited or mixed requirements which might use the TASE.2 services. These other areas are outside the scope of this standard but the use of TASE.2 goes far beyond the specific scope of this standard.

TASE.2 provides an independent and scalable set of services to allow efficient implementations optimized for the respective requirements of a control centre. It does this by defining several conformance building blocks. MMS offers also a scalability of its services specifying MMS Conformance Building Blocks (CBBs). A simple TASE.2 implementation requires only a simple MMS implementation.

TASE.2 and MMS provide their services to their respective users. MMS provides its services to TASE.2 and TASE.2 provides its services to the control centre application. MMS is an independent standard that can provide its services also to users other than TASE.2 – it can serve directly to specific control centre applications and to any other application. This means that the use of MMS is not restricted to TASE.2.

For requirements outside the scope of this standard or for future requirements, for example journaling of data, downloading and uploading of mass data like programs, additional MMS models and services, i.e. Journaling and Domain Loading respective can be applied by a real system in addition to TASE.2. This is possible because the additional application of MMS objects and services is independent of the use of TASE.2 and the use of MMS by TASE.2.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For