

**Telecontrol equipment and systems - Part 6-802:
Telecontrol protocols compatible with ISO standards and
ITU-T recommendations - TASE.2 Object models**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 60870-6-802:2014 sisaldab Euroopa standardi EN 60870-6-802:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 60870-6-802:2014 consists of the English text of the European standard EN 60870-6-802:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 03.10.2014.	Date of Availability of the European standard is 03.10.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 33.200

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

**Telecontrol equipment and systems - Part 6-802: Telecontrol
protocols compatible with ISO standards and ITU-T
recommendations - TASE.2 Object models
(IEC 60870-6-802:2014)**

Matériels et systèmes de téléconduite - Partie 6-802:
Protocoles de téléconduite compatibles avec les normes
ISO et les recommandations de l'UIT-T - Modèles d'objets
TASE.2
(CEI 60870-6-802:2014)

Fernwirkrichtungen und -systeme - Teil 6-802:
Fernwirkprotokolle, die mit ISO-Normen und ITU-T-
Empfehlungen kompatibel sind - TASE.2-Objektmodelle
(IEC 60870-6-802:2014)

This European Standard was approved by CENELEC on 2014-08-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 57/1455/FDIS, future edition 3 of IEC 60870-6-802, prepared by IEC/TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60870-6-802:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-05-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-08-19

This document supersedes EN 60870-6-802:2002.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60870-6-802:2014 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60870-5-101	2003	Telecontrol equipment and systems - Part 5-101: Transmission protocols - Companion standard for basic telecontrol tasks	EN 60870-5-101	2003
IEC 60870-6-503	2014	Telecontrol equipment and systems - Part 6-503: Telecontrol protocols compatible with ISO standards and ITU-T recommendations - TASE.2 Services and protocol	EN 60870-6-503	2014
ISO 9506-1	2003	Industrial automation systems - Manufacturing Message Specification - Part 1: Service definition	-	-
ISO 9506-2	2003	Industrial automation systems - Manufacturing Message Specification - Part 2: Protocol specification	-	-

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Abbreviations	7
5 Object models	7
5.1 General.....	7
5.2 Supervisory Control and Data Acquisition	8
5.2.1 General	8
5.2.2 IndicationPoint object	8
5.2.3 ControlPoint Object	11
5.2.4 Protection Equipment Event Object Model	13
5.3 Device Outage Object.....	16
5.4 InformationBuffer Object.....	19
6 MMS Types for Object Exchange.....	19
6.1 General.....	19
6.2 Supervisory Control and Data Acquisition Types	20
6.2.1 IndicationPoint Type Descriptions	20
6.2.2 ControlPoint Type Descriptions.....	23
6.2.3 Protection Equipment Type Descriptions.....	23
6.3 Device Outage Type Descriptions	24
6.4 InformationBuffer Type Descriptions	26
7 Mapping of Object Models to MMS Types	26
7.1 Supervisory Control and Data Mapping	26
7.1.1 Indication Object Mapping	26
7.1.2 ControlPoint Object Mapping	29
7.1.3 Protection Event Mapping.....	30
7.2 Device Outage Mapping	33
7.3 Information Buffer Mapping	35
8 Use of Supervisory Control Objects	36
8.1 General.....	36
8.2 Use of IndicationPoint Model.....	36
8.3 Use of ControlPoint Model	37
9 Conformance	37
Annex A (informative) TASE.2 (2002) Additional Object Models	39
A.1 General.....	39
A.2 Transfer Accounts.....	39
A.3 Power Plant Objects	46
A.3.1 General	46
A.3.2 Availability Report Object	46
A.3.3 Real Time Status Object	50
A.3.4 Forecast Schedule Object.....	53
A.4 General Data Report Object.....	55
A.4.1 General	55

A.4.2	General Data Request Object	56
A.4.3	General Data Response Object	59
Annex B (informative)	TASE.2 (2002) Additional MMS Object Types	61
B.1	General	61
B.2	Transfer Account Types	61
B.3	Power Plant Type Descriptions	63
B.4	Power System Dynamics	66
B.4.1	General	66
B.4.2	Matrix Data Types	67
B.5	GeneralDataReport Type Descriptions	68
B.6	GeneralDataResponse Type Descriptions	68
Annex C (informative)	TASE.2 (2002) Mapping of Objects to MMS Types	69
C.1	General	69
C.2	Transfer Accounts Mapping	69
C.2.1	TransferAccount Mapping	69
C.2.2	TransmissionSegment Mapping	73
C.2.3	ProfileValue Mapping	76
C.2.4	AccountRequest Mapping	76
C.3	Power Plant Mapping	77
C.3.1	Availability Report Mapping	77
C.3.2	Real Time Status Mapping	80
C.3.3	Forecast Mapping	82
C.3.4	Curve Mapping	83
C.4	General Data Report Mapping	85
C.4.1	General Data Request Mapping	85
C.4.2	General Data Response Mapping	88
Annex D (informative)	Transfer account examples	90

INTRODUCTION

The primary purpose of Telecontrol Application Service Element (TASE.2) is to transfer data between control systems and to initiate control actions. Data is represented by object instances. This part of IEC 60870 proposes object models from which to define object instances. The object models represent objects for transfer. The local system may not maintain a copy of every attribute of an object instance.

The object models presented herein are specific to "control centre" or "utility" operations and applications; objects required to implement the TASE.2 protocol and services are found in IEC 60870-6-503. Since needs will vary, the object models presented here provide only a base; extensions or additional models may be necessary for two systems to exchange data not defined within this standard.

It is by definition that the attribute values (i.e. data) are managed by the owner (i.e. source) of an object instance. The method of acquiring the values is implementation dependent; therefore accuracy is a local matter.

The notation of the object modelling used for the objects specified in Clause 5 is defined in IEC 60870-6-503. This part of IEC 60870 is based on the TASE.2 services and protocol. To understand the modelling and semantics of this standard, some basic knowledge of IEC 60870-6-503 would be advisable.

The notation of the object modelling used for the objects specified in Clause B.2 is defined in IEC 60870-6-503. This part of IEC 60870-6 is based on the TASE.2 services and protocol. To understand the modelling and semantics of this part of IEC 60870-6, some basic knowledge of IEC 60870-6-503 would be advisable.

Clause 5 describes the control centre-specific object models and their application. They are intended to provide information to explain the function of the data.

Clause 6 defines a set of MMS type descriptions for use in exchanging the values of instances of the defined object models. It is important to note that not all attributes of the object models are mapped to types. Some attributes are described simply to define the processing required by the owner of the data and are never exchanged between control centres. Other attributes are used to determine the specific types of MMS variables used for the mapping, and therefore do not appear as exchanged values themselves. A single object model may also be mapped onto several distinct MMS variables, based on the type of access and the TASE.2 services required.

Clause 7 describes the mapping of instances of each object type MMS variables and named variable lists for implementing the exchange.

Clause 8 describes device-specific codes and semantics to be used with the general objects.

Clause 9 is the standards conformance table.

An informative Annex A is included which describes some typical interchange scheduling scenarios, along with the use of TASE.2 objects to implement the schedule exchange.