

**Industrial communication networks - Fieldbus
specifications - Part 5-2: Application layer service
definition - Type 2 elements**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61158-5-2:2014 sisaldab Euroopa standardi EN 61158-5-2:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 61158-5-2:2014 consists of the English text of the European standard EN 61158-5-2:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 10.10.2014.	Date of Availability of the European standard is 10.10.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 25.040.40, 35.100.70, 35.110

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

Industrial communication networks - Fieldbus specifications -
Part 5-2: Application layer service definition - Type 2 elements
(IEC 61158-5-2:2014)

Réseaux de communication industriels - Spécifications
des bus de terrain -
Partie 5-2: Définition des services de la couche application -
Éléments de type 2
(CEI 61158-5-2:2014)

Industrielle Kommunikationsnetze - Feldbusse -
Teil 5-2: Dienstfestlegungen des Application Layer
(Anwendungsschicht) - Typ 2-Elemente
(IEC 61158-5-2:2014)

This European Standard was approved by CENELEC on 2014-09-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/763/FDIS, future edition 3 of IEC 61158-5-2, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-5-2:2014.

The following dates are fixed:

- latest date by which the document has to be (dop) 2015-06-22
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2017-09-22
standards conflicting with the
document have to be withdrawn

This document supersedes EN 61158-5-2:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-5-2:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61131-1	NOTE	Harmonized as EN 61131-1.
IEC 61158-2:2014	NOTE	Harmonized as EN 61158-2 ¹⁾ (not modified).
IEC 61784-1:2014	NOTE	Harmonized as EN 61784-1:2014 (not modified).
IEC 61784-2:2014	NOTE	Harmonized as EN 61784-2 ¹⁾ (not modified).
IEC 62026-3	NOTE	Harmonized as EN 62026-3 (not modified).

¹⁾ To be published.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61131-3	2003 ²⁾	Programmable controllers - Part 3: Programming languages	EN 61131-3	2003 ³⁾
IEC 61158-1	2014	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	EN 61158-1	2014
IEC 61158-3-2	2014	Industrial communication networks - Fieldbus specifications - Part 3-2: Data-link layer service definition - Type 2 elements	EN 61158-3-2 ⁴⁾	-
IEC 61158-4-2	2014	Industrial communication networks - Fieldbus specifications - Part 4-2: Data-link layer protocol specification - Type 2 elements	EN 61158-4-2 ⁴⁾	-
IEC 61158-6-2	2014	Industrial communication networks - Fieldbus specifications - Part 6-2: Application layer protocol specification - Type 2 elements	EN 61158-6-2 ⁴⁾	-
IEC 61588	2009	Precision clock synchronization protocol for networked measurement and control systems	-	-
IEC 61784-3-2	-	Industrial communication networks - Profiles - Part 3-2: Functional safety fieldbuses - Additional specifications for CPF 2	EN 61784-3-2	-
ISO/IEC 646	-	Information technology - ISO 7-bit coded character set for information interchange	-	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic reference model: The basic model	-	-

²⁾ Superseded by IEC 61131-3:2013.

³⁾ Superseded by EN 61131-3:2013 (IEC 61131-3:2013).

⁴⁾ To be published.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 8859-1	-	Information technology - 8-bit single-byte coded graphic character sets - Part-1: Latin alphabet No. 1	-	-
ISO/IEC 8859-5	1988 ⁵⁾	Information processing - 8-bit single-byte coded graphic character sets - Part 5: Latin/Cyrillic alphabet	-	-
ISO/IEC 8859-9	1989 ⁶⁾	Information processing - 8-bit single-byte coded graphic character sets - Part 9: Latin alphabet No. 5	-	-
ISO/IEC 9545	-	Information technology - Open Systems Interconnection - Application layer structure	-	-
ISO/IEC 10646	-	Information technology - Universal Coded Character Set (UCS)	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
ISO/IEC/IEEE 60559	-	Information technology - Microprocessor Systems - Floating-Point arithmetic	-	-
ISO 639-2	-	Codes for the representation of names of languages - Part-2: Alpha-3 code	-	-
ISO 8859-1	1987 ⁷⁾	Information processing - 8-bit single-byte coded graphic character sets - Part 1: Latin alphabet No. 1	-	-
ISO 8859-2	1987 ⁸⁾	Information processing - 8-bit single byte coded graphic character sets - Part 2: Latin alphabet No. 2	-	-
ISO 8859-3	1988 ⁹⁾	Information processing - 8-bit single-byte coded graphic character sets - Part-3: Latin alphabet no. 3	-	-
ISO 8859-4	1988 ¹⁰⁾	Information processing - 8-bit single-byte coded graphic character sets - Part-4: Latin alphabet no. 4	-	-
ISO 8859-6	1987 ¹¹⁾	Information processing - 8-Bit single-byte coded graphic character sets - Part 6: Latin/Arabic alphabet	-	-

⁵⁾ Superseded by ISO/IEC 8859-5:1999.

⁶⁾ Superseded by ISO/IEC 8859-9:1999.

⁷⁾ Superseded by ISO/IEC 8859-1:1998.

⁸⁾ Superseded by ISO/IEC 8859-2:1999.

⁹⁾ Superseded by ISO/IEC 8859-3:1999.

¹⁰⁾ Superseded by ISO/IEC 8859-4:1998.

¹¹⁾ Superseded by ISO/IEC 8859-6:1999.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO 8859-7	1987 ¹²⁾	Information processing - 8-bit single-byte coded graphic character sets - Part 7: Latin/Greek alphabet	-	-
ISO 8859-8	1988 ¹³⁾	Information processing - 8-bit single-byte coded graphic character sets - Part-8: Latin/hebrew alphabet	-	-
ISO 11898	1993 ¹⁴⁾	Road vehicles - Interchange of digital information - Controller area network (CAN) for high-speed communication	-	-
IETF RFC 1759	-	Printer MIB	-	-

¹²⁾ Superseded by ISO/IEC 8859-7:2003.

¹³⁾ Superseded by ISO/IEC 8859-8:1999.

¹⁴⁾ Superseded by ISO 11898-1:2003 and ISO 11898-2:2003.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	9
1 Scope.....	10
1.1 General.....	10
1.2 Specifications.....	11
1.3 Conformance.....	11
2 Normative references	11
3 Terms, definitions, symbols, abbreviations and conventions	13
3.1 ISO/IEC 7498-1 terms	13
3.2 ISO/IEC 8822 terms	13
3.3 ISO/IEC 9545 terms	13
3.4 ISO/IEC 8824-1 terms	13
3.5 Type 2 fieldbus data-link layer terms	14
3.6 Type 2 fieldbus application-layer specific definitions.....	14
3.7 Type 2 abbreviations and symbols.....	22
3.8 Conventions	23
4 Common concepts.....	26
5 Data type ASE.....	26
5.1 General.....	26
5.2 Formal definition of data type objects	26
5.3 FAL defined data types.....	26
5.4 Data type ASE service specification	36
6 Communication model specification.....	36
6.1 Concepts.....	36
6.2 ASEs.....	45
6.3 ARs.....	175
6.4 Summary of FAL classes	206
6.5 Permitted FAL services by AR type	206
Bibliography.....	208
Figure 1 – Overview of ASEs and object classes	38
Figure 2 – Addressing format using MAC, class, instance and attribute IDs	39
Figure 3 – Identity object state transition diagram	58
Figure 4 – Static Assembly state transition diagram.....	63
Figure 5 – Dynamic Assembly state transition diagram	64
Figure 6 – Typical timing relationships for acknowledged data production.....	74
Figure 7 – Example of a COS system with two acking devices	75
Figure 8 – Message flow in COS connection – one Connection object, one consumer.....	75
Figure 9 – Message flow in COS connection – multiple consumers	76
Figure 10 – Path Reconfiguration in a ring topology	88
Figure 11 – CPF2 time synchronization offset clock model.....	89
Figure 12 – CPF2 time synchronization system with offset clock model	90
Figure 13 – CPF2 time synchronization group startup sequence	93
Figure 14 – Parameter object state transition diagram	99

Figure 15 – Example of Find_Next_Object_Instance service	125
Figure 16 – Transmission trigger timer	169
Figure 17 – Inactivity watchdog timer	170
Figure 18 – Using tools for configuration	171
Figure 19 – Production inhibit timer	172
Figure 20 – Context of transport services within the connection model	178
Figure 21 – Application-to-application view of data transfer	178
Figure 22 – Data flow diagram for a link producer	179
Figure 23 – Data flow diagram for a link consumer	180
Figure 24 – Triggers	181
Figure 25 – Binding transport instances to the producer and consumer of a transport connection that does not have a reverse data path	182
Figure 26 – Binding transport instances to the producers and consumers of a transport connection that does have a reverse data path	182
Figure 27 – Binding transport instances to the producer and consumers of a multipoint connection when the transport connection does not have a reverse data path	183
Figure 28 – Binding transport instances to the producers and consumers of a multipoint connection when the transport connection does have reverse data paths	183
Table 1 – Valid IANA MIB printer codes for character set selection	35
Table 2 – Common elements	42
Table 3 – ST language elements	43
Table 4 – Type conversion operations	43
Table 5 – Values of implementation-dependent parameters	44
Table 6 – Extensions to IEC 61131-3:2003	45
Table 7 – Identity object state event matrix	59
Table 8 – Static Assembly state event matrix	64
Table 9 – Static Assembly instance attribute access	64
Table 10 – Dynamic Assembly state event matrix	65
Table 11 – Dynamic Assembly instance attribute access	65
Table 12 – Message Router object Forward_Open parameters	68
Table 13 – Acknowledge Handler object state event matrix	71
Table 14 – Producing I/O application object state event matrix	72
Table 15 – Profile identification	85
Table 16 – Profile default settings and ranges	85
Table 17 – Profile transports	85
Table 18 – Default PTP clock settings	86
Table 19 – Hand_Set clock quality management	87
Table 20 – Path Reconfiguration Signalling message	88
Table 21 – Parameter object state event matrix	99
Table 22 – Status codes	101
Table 23 – Get_Attribute_All service parameters	104
Table 24 – Set_Attribute_All service parameters	106
Table 25 – Get_Attribute_List service parameters	108

Table 26 – Set_Attribute_List service parameters	110
Table 27 – Reset service parameters	112
Table 28 – Start service parameters	114
Table 29 – Stop service parameters	116
Table 30 – Create service parameters	117
Table 31 – Delete service parameters	119
Table 32 – Get_Attribute_Single service parameters	120
Table 33 – Set_Attribute_Single service parameters	122
Table 34 – Find_Next_Object_Instance service parameters	124
Table 35 – NOP service parameters	126
Table 36 – Apply_Attributes service parameters	127
Table 37 – Save service parameters	129
Table 38 – Restore service parameters	130
Table 39 – Get_Member service parameters	132
Table 40 – Set_Member service parameters	134
Table 41 – Insert_Member service parameters	135
Table 42 – Remove_Member service parameters	137
Table 43 – Group_Sync service parameters	138
Table 44 – Add_AckData_Path service parameters	140
Table 45 – Remove_AckData_Path service parameters	141
Table 46 – Get_Enum_String service parameters	142
Table 47 – Symbolic_Translation service parameters	144
Table 48 – CM_Open service parameters	152
Table 49 – CM_Close service parameters	154
Table 50 – CM_Unconnected_Send service parameters	156
Table 51 – CM_Get_Connection_Data service parameters	158
Table 52 – CM_Search_Connection_Data service parameters	160
Table 53 – CM_Get_Connection_Data service parameters	161
Table 54 – I/O Connection object attribute access	166
Table 55 – Bridged Connection object attribute access	166
Table 56 – Explicit messaging object attribute access	167
Table 57 – Connection_Bind service parameters	173
Table 58 – Service_Name service parameters	174
Table 59 – How production trigger, transport class, and CM_RPI determine when data is produced	177
Table 60 – Transport classes	188
Table 61 – UCMM_Create service parameters	199
Table 62 – UCMM_Delete service parameters	200
Table 63 – UCMM_Write service parameters	200
Table 64 – UCMM_Abort service parameters	202
Table 65 – TR_Write service parameters	203
Table 66 – TR_Trigger service parameters	203
Table 67 – TR_Packet_arrived service parameters	204

Table 68 – TR_Ack_received service parameters.....	204
Table 69 – TR_Verify service parameters	205
Table 70 – TR_Status_updated service parameters	205
Table 71 – FAL class summary	206
Table 72 – FAL services by AR type	207

This document is a preview generated by EVS

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-2: Application layer service definition – Type 2 elements

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 2 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 2 fieldbus application layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This standard specifies the structure and services of the Type 2 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can