

**Communication networks and systems for power utility automation - Part 3: General requirements**

This document is a preview generated by EVS

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 61850-3:2014 sisaldab Euroopa standardi EN 61850-3:2014 ingliskeelset teksti.	This Estonian standard EVS-EN 61850-3:2014 consists of the English text of the European standard EN 61850-3:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 18.07.2014.	Date of Availability of the European standard is 18.07.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 33.200

### **Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele**

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Aru 10, 10317 Tallinn, Eesti; [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

### **The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation**

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:  
Aru 10, 10317 Tallinn, Estonia; [www.evs.ee](http://www.evs.ee); phone 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English Version

## Communication networks and systems for power utility automation - Part 3: General requirements (IEC 61850-3:2013)

Réseaux et systèmes de communication pour  
l'automatisation des systèmes électriques - Partie 3:  
Exigences générales  
(CEI 61850-3:2013)

Kommunikationsnetze und -systeme für die  
Automatisierung in der elektrischen Energieversorgung -  
Teil 3: Allgemeine Anforderungen  
(IEC 61850-3:2013)

This European Standard was approved by CENELEC on 2014-01-16. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Foreword

The text of document 57/1391/FDIS, future edition 2 of IEC 61850-3, prepared by IEC/TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61850-3:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-10-18
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-01-16

This document supersedes EN 61850-3:2002.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

## Endorsement notice

The text of the International Standard IEC 61850-3:2013 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- |                   |      |  |
|-------------------|------|--|
| IEC 60127-1       | NOTE | Harmonized as EN 60127-1.                      |
| IEC 60255-27:2005 | NOTE | Harmonized as EN 60255-27:2005 (not modified). |
| IEC 60297-3-101   | NOTE | Harmonized as EN 60297-3-101.                  |
| IEC 60721-3-3     | NOTE | Harmonized as EN 60721-3-3.                    |

## CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references .....	7
3 Terms, definitions and abbreviations .....	9
3.1 Terms and definitions.....	9
3.2 Abbreviations.....	20
4 Environmental conditions.....	20
4.1 General.....	20
4.2 Normal environmental conditions .....	20
4.3 Special environmental conditions .....	21
4.4 Storage conditions .....	22
5 Ratings.....	22
5.1 General.....	22
5.2 Rated voltage – Auxiliary energizing voltage .....	22
5.2.1 AC voltage.....	22
5.2.2 DC voltage.....	22
5.2.3 Operating range.....	22
5.3 Binary input and output.....	22
5.3.1 Binary input .....	22
5.3.2 Binary output .....	22
5.4 Rated burden .....	22
5.5 Rated ambient temperature.....	22
6 Design and construction .....	23
6.1 Marking.....	23
6.1.1 General .....	23
6.1.2 Identification .....	23
6.1.3 Auxiliary supplies, I/O .....	23
6.1.4 Fuses .....	24
6.1.5 Terminals and operating devices .....	25
6.1.6 Equipment protected by double or reinforced insulation .....	25
6.1.7 Batteries .....	26
6.1.8 Test voltage marking .....	27
6.1.9 Warning markings.....	28
6.1.10 Marking durability .....	29
6.2 Documentation.....	29
6.2.1 General .....	29
6.2.2 Equipment ratings.....	29
6.2.3 Equipment installation .....	30
6.2.4 Equipment commissioning and maintenance.....	31
6.2.5 Equipment operation.....	31
6.3 Packaging.....	31
6.3.1 General .....	31
6.3.2 Marking of packaging.....	32
6.4 Dimensions.....	32
6.5 Functional performance requirements .....	32
6.6 Product safety requirements .....	32

6.6.1	Clearances and creepage distances .....	32
6.6.2	IP rating.....	34
6.6.3	Impulse voltage .....	34
6.6.4	AC or d.c. dielectric voltage test .....	36
6.6.5	Protective bonding resistance.....	39
6.6.6	Flammability of insulation materials, components and fire enclosure.....	39
6.6.7	Single-fault condition .....	41
6.7	Electromagnetic compatibility (EMC).....	44
6.7.1	General .....	44
6.7.2	Electromagnetic environment.....	45
6.7.3	Immunity requirements and type tests.....	45
6.7.4	Emission requirements and type tests.....	54
6.8	Burden test.....	55
6.8.1	Burden for AC power supply .....	55
6.8.2	Burden for DC power supply .....	55
6.8.3	Burden for binary input .....	55
6.9	Climatic performance .....	55
6.9.1	General .....	55
6.9.2	Verification procedure.....	56
6.9.3	Climatic environmental tests .....	57
6.10	Mechanical performance .....	61
6.10.1	Vibration response and endurance (sinusoidal).....	61
6.10.2	Shock response, shock withstand and bump .....	61
6.10.3	Seismic.....	61
6.11	Enclosure protection .....	62
7	Tests .....	62
7.1	General.....	62
7.2	Test reference conditions .....	62
7.3	Device reliability classes .....	62
7.4	Communication conditions during tests .....	62
7.5	Conditions to be met (acceptance criteria) .....	63
7.5.1	General .....	63
7.5.2	Conditions to be met by class 1 and class 2 devices .....	63
7.5.3	Additional condition to be met by class 1 devices .....	63
7.5.4	Additional condition to be met by class 2 devices .....	63
7.5.5	Equipment functioning .....	64
7.5.6	Exceptions.....	64
7.6	Test overview.....	64
7.7	Test report content.....	65
8	Marking, labelling and packaging.....	66
9	Rules for transport, storage, installation, operation and maintenance .....	66
10	Product documentation .....	66
	Bibliography.....	67
	Figure 1 – Example of power station and substation: selection of the specifications for apparatus and related connections .....	47
	Figure 2 – Example air-insulated substation (AIS): selection of the specifications for apparatus and related connections .....	49

Table 1 – Normal environmental conditions.....	21
Table 2 – Special environmental conditions .....	21
Table 3 – Symbols .....	26
Table 4 – Symbols and marking of test voltage(s) .....	28
Table 5 – Current levels in normal operational condition .....	34
Table 6 – Charge of energy of capacitance levels .....	34
Table 7 – AC test voltages .....	38
Table 8 – Current levels in single fault condition .....	44
Table 9 – Immunity specification – Enclosure port.....	49
Table 10 – Immunity specifications – Signal ports .....	50
Table 11 – Immunity specifications – Low voltage a.c. input power ports and low voltage a.c. output power ports .....	51
Table 12 – Immunity specifications – Low voltage d.c. input power ports and low voltage d.c. output power ports .....	52
Table 13 – Immunity specifications – Functional earth port .....	53
Table 14 – Emission tests – Auxiliary power supply port .....	54
Table 15 – Emission tests – Telecommunication port.....	54
Table 16 – Emission tests below 1 GHz – Enclosure port at a measuring distance of 10 m .....	54
Table 17 – Emission tests above 1 GHz – Enclosure port at a measuring distance of 3 m .....	54
Table 18 – Dry heat test operational .....	57
Table 19 – Cold test operational .....	58
Table 20 – Dry heat test maximum storage temperature .....	58
Table 21 – Cold test minimum storage temperature .....	59
Table 22 – Change of temperature test .....	59
Table 23 – Damp heat steady state test .....	60
Table 24 – Damp heat cyclic test .....	61
Table 25 – Test reference conditions .....	62
Table 26 – Device communications profiles (conditions) during tests for Ethernet equipment with specified ranges of frame size (for example, an Ethernet switch).....	63
Table 27 – Device communications profiles (conditions) during tests for serial devices without specified ranges of frame size (for example, serial media converters).....	63
Table 28 – Test overview .....	64

# COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

## Part 3: General requirements

### 1 Scope

This part of IEC 61850 defines the general requirements, mainly regarding construction, design and environmental conditions for utility communication and automation IEDs and systems in power plant and substation environments. These general requirements are in line with requirements for IEDs used in similar environments, for example measuring relays and protection equipment.

When communication or automation IEDs are an integral part of another device in the power plant or substation, then the environmental requirements for the device itself apply to the communications equipment.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-14:2009, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-78:2001, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60255-21-1, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section 1: Vibration tests (sinusoidal)*

IEC 60255-21-2, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section 2: Shock and bump tests*

IEC 60255-21-3, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section 3: Seismic tests*

IEC 60255-27:2013, *Measuring relays and protection equipment – Part 27: Product safety requirements*

IEC 60417, *Graphical symbols for use on equipment*. Available from <<http://www.graphical-symbols.info/equipment>>



IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60695-11-10, *Fire hazard testing – Part 11-10: Test flames – 50 W horizontal and vertical flame test methods*

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

IEC 60990:1999, *Methods of measurement of touch current and protective conductor current*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2008, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4:2004, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:2008, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8:2001, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11:2004, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

IEC 61000-4-16:2002, *Electromagnetic compatibility (EMC) – Part 4-16: Testing and measurement techniques – Test for immunity to conducted, common mode disturbances in the frequency range 0 Hz to 150 kHz*

IEC 61000-4-17:2009, *Electromagnetic compatibility (EMC) – Part 4-17: Testing and measurement techniques – Ripple on d.c. input power port immunity test*

IEC 61000-4-18:2006, *Electromagnetic compatibility (EMC) – Part 4-18: Testing and measurement techniques – Damped oscillatory wave immunity test*

IEC 61000-4-29:2000, *Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on d.c. input power port immunity tests*

IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 1: General requirements*

IEC 61180-1:1992, *High-voltage test techniques for low voltage equipment – Part 1: Definitions, test and procedure requirements*

IEC 61180-2, *High-voltage test techniques for low-voltage equipment – Part 2: Test equipment*

IEC 61850 (all parts), *Communication networks and systems in substations*

IEC/TS 61850-2:2003, *Communication networks and systems in substations – Part 2: Glossary*

IEC 62271-1, *High-voltage switchgear and controlgear – Part 1: Common specifications*

CISPR 22:2008, *Information technology equipment – Radio disturbance characteristics – Limits and methods of measurement*

CISPR 24:2010, *Information technology equipment – Immunity characteristics – Limits and methods of measurement*

ISO 780:1997, *Packaging – Pictorial marking for handling of goods*

ISO 7000, *Graphical symbols for use on equipment – Registered symbols*. Available from <http://www.graphical-symbols.info/equipment>

ISO 9772, *Cellular plastics – Determination of horizontal burning characteristics of small specimens subjected to a small flame*

IEEE 1613:2009, *IEEE standard environmental and testing requirements for communications networking devices installed in electric power substations*

### **3 Terms, definitions and abbreviations**

#### **3.1 Terms and definitions**

For the purposes of this document, the terms and definitions given in IEC 61850-2, as well as the following, apply.

##### **3.1.1**

###### **accessible part**

part which can be touched in normal operational use with a standard rigid or jointed test finger as specified in IEC 60529

Note 1 to entry: Accessible in normal operational use applies mainly to the front of the equipment only, for the purposes of this standard.

Note 2 to entry: A communication circuit/network, which may be connected and taken outside of the cubicle housing, the equipment, or on the front of the panel without the need to open a cover or flap to access it, should be considered to be accessible, i.e. should be PEB, PELV, SELV or equivalent.

[SOURCE: IEC 60050-442:1998, 442-01-15, modified — Notes 1 and 2 to entry have been added.]

##### **3.1.2**

###### **adjacent circuits**

electric circuits which are separated from the considered circuit by the necessary basic or double/reinforced insulation

Note 1 to entry: Circuits which are separated by far more than double or reinforced insulation are not considered to be adjacent.

[SOURCE: IEC 60255-27:2013, 3.2]