

**High-voltage switchgear and controlgear -- Part 112:
Alternating current high-speed earthing switches for
secondary arc extinction on transmission lines**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 62271-112:2013 sisaldab Euroopa standardi EN 62271-112:2013 ingliskeelset teksti.	This Estonian standard EVS-EN 62271-112:2013 consists of the English text of the European standard EN 62271-112:2013.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 04.10.2013.	Date of Availability of the European standard is 04.10.2013.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.130.10, 29.130.99

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

**High-voltage switchgear and controlgear -
Part 112: Alternating current high-speed earthing switches for secondary
arc extinction on transmission lines
(IEC 62271-112:2013)**

Appareillage à haute tension -
Partie 112: Sectionneurs de terre rapides
à courant alternatif pour l'extinction de
l'arc secondaire sur les lignes de transport
(CEI 62271-112:2013)

Hochspannungs-Schaltgeräte und -
Schaltanlagen -
Teil 112: Schnellschaltende
Wechselstrom-Erdungsschalter zum
Löschen von sekundären
Lichtbögen auf Freileitungen
(IEC 62271-112:2013)

This European Standard was approved by CENELEC on 2013-09-10. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17A/1042/FDIS, future edition 1 of IEC 62271-112, prepared by subcommittee 17A, High-voltage switchgear and controlgear, of IEC/TC 17, "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62271-112:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-06-10
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-09-10

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62271-112:2013 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62271-1	2007	High-voltage switchgear and controlgear - Part 1: Common specifications	EN 62271-1	2008
IEC 62271-100	2008	High-voltage switchgear and controlgear - Part 100: Alternating current circuit-breakers	EN 62271-100	2009
IEC 62271-102	2001	High-voltage switchgear and controlgear -	EN 62271-102	2002
+ corr. April	2002	Part 102: Alternating current disconnectors	+ corr. July	2008
+ corr. February	2005	and earthing switches	+ corr. March	2005
+ corr. May	2003			
IEC 62271-203	2011	High-voltage switchgear and controlgear -	EN 62271-203	2012
+ corr. July	2013	Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV		

CONTENTS

FOREWORD.....	4
1 General	6
1.1 Scope.....	6
1.2 Normative references	6
2 Normal and special service conditions	6
3 Terms and definitions	6
3.1 General terms	6
3.2 Assemblies of switchgear and controlgear	8
3.3 Parts of assemblies	8
3.4 Switching devices.....	8
3.5 Parts of switchgear and controlgear	8
3.6 Operation	8
3.7 Characteristics quantities	8
4 Ratings.....	8
5 Design and construction	10
6 Type tests	11
7 Routine tests	14
8 Guide to the selection of HSES	14
9 Information to be given with enquiries, tenders and orders	14
10 Rules for transport, storage, installation, operation and maintenance	15
11 Safety.....	15
Annex A (informative) Background information on the use of HSES	16
Annex B (informative) Induced current and voltage conditions for other cases	21
Figure 1 – Explanation of a multi-phase auto-reclosing scheme	7
Figure 2 – Timing chart of HSES and circuit-breakers	9
Figure A.1 – Single-line diagram of a power system.....	17
Figure A.2 – Timing chart of the HSESs in relation to the transmission line circuit-breakers	17
Figure A.3 – Typical timing chart showing the time between fault initiation and a successful re-close of the transmission line circuit-breakers	18
Figure B.1 – System condition to explain successive fault.....	22
Figure B.2 – Example of waveforms of delayed current zero phenomena	22
Figure B.3 – Typical test circuit for electromagnetic coupling test-duty of a HSES with delayed current zero crossings	24
Figure B.4 – Typical test circuit for electrostatic coupling test-duty of HSES with delayed current zero crossings	24
Table 1 – Standardized values of rated induced currents and voltages	10
Table 2 – Items to be listed on nameplate of a HSES.....	11
Table A.1 – Comparison of earthing switches.....	19
Table A.2 – Comparison of a four-legged reactor and HSES	20
Table B.1 – Preferred values for single-phase earth fault with delayed current zero phenomena in the presence of a successive fault	23

Table B.2 – Preferred values for multi-phase earth faults in a double-circuit system25

Table B.3 – Preferred values for covering the cases of categories 0 and 125

This document is a preview generated by EVS

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 112: Alternating current high-speed earthing switches for secondary arc extinction on transmission lines

1 General

1.1 Scope

This part of IEC 62271 applies to a.c. high-speed earthing switches designed for indoor and outdoor installation and for operation at service frequencies of 50 Hz and 60 Hz on systems having voltages of 550 kV and above.

High-speed earthing switches described in this standard are intended to extinguish the secondary arc remaining after clearing faults on transmission lines by the circuit-breakers.

1.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62271-1:2007, *High-voltage switchgear and controlgear – Part 1: Common specifications*

IEC 62271-100:2008, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2001, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-203:2011, *High-voltage switchgear and controlgear – Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

2 Normal and special service conditions

Clause 2 of IEC 62271-1:2007 is applicable.

3 Terms and definitions

For the purposes of this document, the terms and definitions given in Clause 3 of IEC 62271-1:2011, as well as the following apply.

3.1 General terms

3.1.101

secondary arc

arc that remains at the faulted point after interruption of the short-circuit current fed by the network

Note 1 to entry: This secondary arc is supplied by electrostatic or electromagnetic induction from the adjacent healthy phases.