

Hoonete ventilatsioon – Hoones olevate õhujaotussüsteemide tulekaitse

Ventilation for buildings - Fire precautions for air distribution systems in buildings

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

| | |
|--|---|
| <p>Käesolev Eesti standard EVS-EN 15423:2008 sisaldab Euroopa standardi EN 15423:2008 ingliskeelset teksti.</p> <p>Standard on kinnitatud Eesti Standardikeskuse 20.06.2008 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 07.05.2008.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p> | <p>This Estonian standard EVS-EN 15423:2008 consists of the English text of the European standard EN 15423:2008.</p> <p>This standard is ratified with the order of Estonian Centre for Standardisation dated 20.06.2008 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.</p> <p>Date of Availability of the European standard text 07.05.2008.</p> <p>The standard is available from Estonian standardisation organisation.</p> |
|--|---|

ICS 13.220.50, 91.140.30

Võtmesõnad:

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

ICS 13.220.50; 91.140.30

English Version

Ventilation for buildings - Fire precautions for air distribution systems in buildings

Systèmes de ventilation des bâtiments - Sécurité incendie
pour les systèmes de distribution d'air dans les bâtiments

Lüftung von Gebäuden - Brandschutz von Lüftungsanlagen
in Gebäuden

This European Standard was approved by CEN on 11 March 2008.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

| | |
|--|----|
| Foreword..... | 3 |
| 1 Scope | 4 |
| 2 Normative references | 5 |
| 3 Terms and definitions | 6 |
| 4 Air distribution system..... | 7 |
| 4.1 General requirements..... | 7 |
| 4.2 Design of air distribution systems..... | 7 |
| 4.3 Installation | 7 |
| 5 Requirements for components intended for fire precautions | 7 |
| 5.1 General..... | 7 |
| 5.2 Inlet/outlet louvres | 8 |
| 5.3 Fans..... | 8 |
| 5.4 Air control dampers..... | 10 |
| 5.5 Duct | 11 |
| 5.6 Fire dampers and smoke control dampers | 11 |
| 5.7 Air terminal devices..... | 12 |
| 5.8 Anchors and supports | 13 |
| 5.9 Duct fittings | 13 |
| 5.10 Control panels..... | 13 |
| 5.11 Cables and connections | 14 |
| 5.12 Air handling units | 14 |
| 5.13 Air filters | 15 |
| 5.14 Sound attenuators | 16 |
| 5.15 Heat exchangers | 16 |
| 6 Commissioning and maintenance of air distribution systems | 16 |
| 7 Marking, labelling and product information..... | 17 |
| Annex A (informative) Checklist for components | 18 |
| Annex B (informative) Table of components/characteristics European Standards | 20 |
| Annex C (informative) Maintenance for fire dampers and smoke control dampers..... | 22 |
| Bibliography | 24 |

Foreword

This document (EN 15423:2008) has been prepared by Technical Committee CEN/TC 156 "Ventilation for buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2008, and conflicting national standards shall be withdrawn at the latest by November 2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This document gives guidance for system designers, installers, commissioners and maintenance teams on the incorporation of protective measures for air distribution systems including dual purpose systems for smoke and heat exhaust systems within buildings, to prevent the initiation and the spread of fire, smoke and other by-products of combustion.

This document intends to only support any national (building) regulations, which are the basis of any design of a building or parts of it. It is up to the designer to enquire about the suitability (in particular in legal terms) of a specific solution given in this document (e.g. although “dual purpose systems” are covered in this document, they may not be permitted in some Member States or only in certain types of buildings).

This document applies to all air distribution systems including dual purpose systems (except systems only dedicated to smoke exhaust systems, which are dealt in other European standards) including technical rooms or spaces for the installation of devices to assist in ventilation of a building (e.g. distance of storage of combustible materials to devices and not the fire resistance of the building structure), penetrations, and following components/products used in the system like:

- inlet/outlet louvres;
- fans not exposed / exposed to the smoke;
- air control dampers;
- ducts;
- fire control dampers;
- air terminal devices;
- anchors and supports;
- duct fittings;
- control panels;
- cables and connections;
- air handling units;
- air filters;
- sound attenuators;
- heat exchangers.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1364-2, *Fire resistance test for non loadbearing elements - Part 2: Ceilings*

EN 1366-1, *Fire resistance tests for service installations - Part 1: Ducts*

EN 1366-2, *Fire resistance tests for service installations - Part 2: Fire dampers*

EN 1366-8, *Fire resistance tests for service installations - Part 8: Smoke extraction ducts*

EN 1366-9, *Fire resistance tests for service installations - Part 9: Single compartment smoke extraction ducts*

prEN 1366-10, *Fire resistance tests for service installations - Part 10: Smoke control dampers*

EN 1505, *Ventilation for buildings - Sheet metal air ducts and fittings with rectangular cross section - Dimensions*

EN 1506, *Ventilation for buildings - Sheet metal air ducts and fittings with circular cross section - Dimensions*

EN 1507, *Ventilation for buildings - Sheet metal air ducts with rectangular section - Requirements for strength and leakage*

EN 12101-3, *Smoke and heat control systems - Part 3: Specification for powered smoke and heat exhaust ventilators*

prEN 12101-8, *Smoke and heat control systems - Part 8: Specification for smoke control dampers*

prEN 12101-9, *Smoke and heat control systems - Part 9: Control panels*

EN 12097, *Ventilation for buildings - Ductwork - Requirements for ductwork components to facilitate maintenance of ductwork systems*

EN 12792:2003, *Ventilation for buildings - Symbols, terminology and graphical symbols*

EN 13053, *Ventilation for buildings - Air handling units - Rating and performance for units, components and sections*

EN 13403, *Ventilation for buildings - Non-metallic ducts - Ductwork made from insulation ductboards*

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 13501-3, *Fire classification of construction products and building elements - Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers*

EN 13501-4, *Fire classification of construction products and building elements - Part 4: Classification using data from fire resistance tests on components of smoke control systems*

EN 13964, *Suspended ceilings - Requirements and tests methods*

EN 1886:2007 *Ventilation for buildings - Air handling units - Mechanical performance*

EN 13779, *Ventilation for non-residential buildings - Performance requirements for ventilation and room-conditioning systems*

EN 12237, *Ventilation for buildings - Ductworks - Strength and leakage of circular sheet metal ducts*

3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in EN 12792:2003, together with the following apply.

3.1 shaft
space generally encased with building elements, where ventilation ducts and possibly other pipes and cables are located

3.2 support
device for a system component, e.g. fire damper, silencer, etc. to bear a load

3.3 inlet/outlet louvre
device, consisting of an assembly of parallel sloping vanes, intended to permit the passage of air, while providing a measure of protection against environmental influences

[EN 12792:2003, Table 1, number 242]

3.4 air control damper
element inserted into an air distribution system or element of an air distribution system permitting modification of the air resistance of the system, and consequently changing the air flow rate (dampers), or shutting off the air flow completely (valves), or controlling the air flow rate and in addition providing shut-off of the air flow (control valves)

[EN 12792:2003, Table 1, number 95]

3.5 fire damper
mobile closure within a duct, which is designed to prevent the passage of fire

[EN 1366-2]

3.6 smoke control damper
device automatically or manually activated which may be open or closed in its operational position, to control the flow of smoke and hot gases into, from or within a duct

[prEN 1366-10]

3.8 air terminal devices
component of a ventilation installation which is designed with the purpose of achieving the predetermined movement of air into or from a treated space

[EN 12792:2003, Table 1, number 31]