this docume

TEEVALGUSTUS. OSA 5: ENERGIATÕHUSUSNÄITAJAD

<text> **Road lighting - Energy performance indicators**



EESTI STANDARDI EESSÕNA NATIONAL FOREWORD

Eesti standard EVS-EN 13201-5:2015 This Estonian standard EVS-EN 13201-5:2015 See sisaldab Euroopa standardi EN 13201-5:2015 consists of the English text of the European standard EN 13201-5:2015. ingliskeelset teksti. Standard on jõustunud This standard has been endorsed with a sellekohase teate notification published in the official bulletin of the avaldamisega EVS Teatajas. Estonian Centre for Standardisation. Euroopa standardimisorganisatsioonid on teinud Date of Availability of the European standard is Euroopa standardi rahvuslikele liikmetele 23.12.2015. kättesaadavaks 23.12.2015. Standard kättesaadav Eesti The standard is available from the Estonian Centre on Standardikeskusest. for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile <u>standardiosakond@evs.ee</u>.

STOLION

ICS 93.080.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele
Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.
Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; koduleht <u>www.evs.ee</u>; telefon 605 5050; e-post <u>info@evs.ee</u>
The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage <u>www.evs.ee</u>; phone +372 605 5050; e-mail <u>info@evs.ee</u>

EUROPEAN STANDARD NORME EUROPÉENNE **EUROPÄISCHE NORM**

EN 13201-5

December 2015

ICS 93.080.40

English Version

Road lighting - Part 5: Energy performance indicators

Éclairage public - Partie 5: Indicateurs de performance énergétique

Straßenbeleuchtung - Teil 5: Energieeffizienzindikatoren

This European Standard was approved by CEN on 6 June 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

| Europ | ean foreword | 4 |
|-----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|
| Introduction | | 5 |
| 1 | Scope | 6 |
| 2 | Normative references | 6 |
| 3 3.1 3.2 | Terms, definitions, symbols and abbreviations Terms and definitions Symbols and abbreviations | 6 6 7 |
| 4 4.1 4.2 | Power Density Indicator (PDI) Calculation of the power density indicator Average horizontal illuminance to be used for calculation of the power density indicator | 9 9 |
| 4.3 | System power (P) to be used for calculation of the power density indicator | 10 |
| 4.4 | Area (A) to be used for calculation of the power density indicator | 11 |
| 5 | Annual Energy Consumption Indicator (AECI) | 11 |
| Annex | A (informative) Examples of calculation and typical values of energy performance indicators | 13 |
| A.1 | Examples of operational profiles | 13 |
| A.1.1 | General | 13 |
| A.1.2 | Full power operation | 13 |
| A.1.3 | Multi-power operation | 14 |
| A.1.4 | Operation with vehicle and presence detectors | 14 |
| A.2 | Example of calculation | 15 |
| A.3 | Typical values of energy performance indicators | 16 |
| A.3.1 | General | 16 |
| A.3.2 | Two-lane road for motorized traffic (road profile A) | 17 |
| A.3.3 | Road with mixed motorized and pedestrian traffic without sidewalks (road profile B) | 18 |
| A.3.4 | Road and sidewalk on the side of lighting arrangement (road profile C) | 19 |
| A.3.5 | Road and sidewalk on the opposite side to the lighting arrangement (road profile D) | 20 |
| A.3.6 | Road and two sidewalks on both sides (road profile E) | 21 |
| A.3.7 | Road and two sidewalks on both sides separated from carriageway by grass strips (road profile F) | 22 |
| A.3.8 | Typical values of AECI for different operational profiles | . 22 |
| Annex | x B (informative) Installation luminous efficacy | 24 |
| B.1 | General | 24 |

| B.2 | Calculation of the correction factor | 24 |
|------------|--------------------------------------------------------------------------|----|
| B.3 | Calculation of the utilance | 25 |
| B.4 | Calculation of the efficiency of luminaires | 25 |
| Anne | x C (informative) Lighting factor of an installation | 26 |
| C.1 | Installation lighting factor $q_{ m inst}$ | 26 |
| C.2 | Role of q_{inst} in road lighting design aimed at energy saving | 26 |
| C.3 | Typical values of <i>q</i> _{inst} | 26 |
| Anne | x D (informative) Presentation of energy performance indicators | 27 |
| | grany | 3 |

3

European foreword

This document (EN 13201-5:2015) has been prepared by Technical Committee CEN/TC 169 "Light and lighting", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2016 and conflicting national standards shall be withdrawn at the latest by June 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

EN 13201, *Road lighting* is a series of documents that consists of the following parts:

- Part 1: Guidelines on selection of lighting classes [Technical Report];
- Part 2: Performance requirements;
- Part 3: Calculation of performance;
- Part 4: Methods of measuring lighting performance;
- *Part 5: Energy performance indicators* [present document].

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

The purpose of this European Standard is to define energy performance indicators for road lighting installations. The standard introduces two metrics, the power density indicator (PDI) D_P and the annual energy consumption indicator (AECI) D_E that should always be used together.

To quantify the potential savings obtainable from improved energy performance and reduced environmental impact, it is essential to calculate both the power density indicator (D_P) and the annual energy consumption indicator (D_E). In addition, the installation luminous efficacy (η_{inst}) can be used for comparing the energy performances of alternative road lighting installations.

Careful choice of lighting class(es) during the design and specification phase will help to maximize energy savings by ensuring only the necessary levels of illumination provided at the correct times and for the minimum periods necessary. Additional guidance is given in the CEN/TR 13201-1 with regard to the visual needs of road users, e.g. under varying traffic volumes during certain times of night or under varying weather conditions.

During the design phase of a road lighting installation care should be taken to ensure that the design criteria specified in EN 13201-2 are achieved but that excess overlighting is reduced to the minimum technically obtainable. Overlighting can be minimized by the careful selection of the luminaire and light source but the specified lighting class, the designed lighting point spacing and uniformity ratios are all determining factors of the luminous flux emitted by the light source and thus the power of the light source required. However, this precise luminous flux may not, in reality, exist. Where the luminous flux of the light source is greater than that required the designer can by means of continuously variable control gear, compensate for this effect by reducing the luminous flux of the light source to the required level resulting in lower energy consumption. The same principles and control gear can be used to compensate for changes in luminous flux emitted throughout the lifetime of the light sources.

The energy levels calculated using this standard should not be used as a direct input for the calculation of the load on the electrical distribution system. Such calculations are normally based on the energy requirement derived directly from the lighting and electrical design.

Examples of operational profiles and examples of calculation of the energy performance indicators are provided in Annex A. Typical values of energy performance indicators are provided to illustrate the energy performance of recent technological level of luminaires and installations.

Annex B introduces the installation luminous efficacy and its factors as a measure of the influence of various light losses and other parameters.

Lighting factor of an installation, as introduced in Annex C, can be additionally used to characterize the energy performance of road lighting installations independently on the lighting components used. Other factors and parameters having influence to the energy performance, such as the maintenance factor (see CIE 154), can be recognized but are not dealt with in this standard.

Recommendations on presentation of the energy performance indicators are provided in Annex D.

1 Scope

This part of the European Standard defines how to calculate the energy performance indicators for road lighting installations using the calculated power density indicator (PDI) D_P and the calculated annual energy consumption indicator (AECI) D_E . Power density indicator (D_P) demonstrates the energy needed for a road lighting installation, while it is fulfilling the relevant lighting requirements specified in EN 13201-2. The annual energy consumption indicator (D_E) determines the power consumption during the year, even if the relevant lighting requirements change during the night or seasons.

These indicators may be used to compare the energy performance of different road lighting solutions and technologies for the same road lighting project. The energy performance of road lighting systems with different road geometries or different lighting requirements cannot be compared to each other directly, as the energy performance is influenced by, amongst others, the geometry of the area to be lit, as well as the lighting requirements. The power density indicator (D_P) and annual energy consumption indicator (D_E) apply for all traffic areas covered by the series of lighting classes M, C and P as defined in EN 13201-2.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12665:2011, Light and lighting — Basic terms and criteria for specifying lighting requirements

EN 13201-2, Road lighting — Part 2: Performance requirements

EN 13201-3:2015, Road lighting — Part 3: Calculation of performance

3 Terms, definitions, symbols and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 12665:2011 and the following apply.

3.1.1

system power (of a lighting installation in a given state of operation)

total power of the road lighting installation needed to fulfil the required lighting classes as specified in EN 13201-2 in all the relevant sub-areas, and to operate and control the lighting installation (unit: W)

3.1.2

power density indicator PDI (of a lighting installation in a given state of operation) $D_{\rm P}$

value of the system power divided by the value of the product of the surface area to be lit and the calculated maintained average illuminance value on this area according to EN 13201-3 (unit: W·lx·1·m-2)