

KORSTNAD. TERMO- JA HÜDRODÜNAAMIKA
ARVUTUSMEETODID. OSA 1: KORSTNAD ÜHE
KÜTTESEADME TEENINDAMISEKS

Chimneys - Thermal and fluid dynamic calculation
methods - Part 1: Chimneys serving one heating
appliance

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 13384-1:2015 sisaldab Euroopa standardi EN 13384-1:2015 ingliskeelset teksti.	This Estonian standard EVS-EN 13384-1:2015 consists of the English text of the European standard EN 13384-1:2015.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 01.04.2015.	Date of Availability of the European standard is 01.04.2015.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 91.060.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Aru 10, 10317 Tallinn, Eesti; koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Chimneys - Thermal and fluid dynamic calculation methods -
Part 1: Chimneys serving one heating appliance**

Conduits de fumée - Méthodes de calcul thermo-aéraulique
- Partie 1: Conduits de fumée ne desservant qu'un seul
appareil

Abgasanlagen - Wärme- und strömungstechnische
Berechnungsverfahren - Teil 1: Abgasanlagen mit einer
Feuerstätte

This European Standard was approved by CEN on 24 January 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Symbols and abbreviations	10
5 Calculation method for non-balanced flue chimneys	14
5.1 General principles.....	14
5.2 Pressure requirements.....	15
5.2.1 Negative pressure chimneys.....	15
5.2.2 Positive pressure chimneys	16
5.3 Temperature requirement	16
5.4 Calculation procedure	17
5.5 Flue gas data characterising the heating appliance	18
5.5.1 General.....	18
5.5.2 Flue gas mass flow	18
5.5.3 Flue gas temperature	19
5.5.4 Minimum draught for the heating appliance (P_W) for negative pressure chimney	19
5.5.5 Maximum draught for the heating appliance (P_{Wmax}) for negative pressure chimney	20
5.5.6 Maximum differential pressure of the heating appliance (P_{W0}) for positive pressure chimney	20
5.5.7 Minimum differential pressure of the heating appliance (P_{W0min}) for positive pressure chimney	20
5.6 Characteristic data for the calculation	20
5.6.1 General.....	20
5.6.2 Mean value for roughness (r)	20
5.6.3 Thermal resistance ($1/\Lambda$)	20
5.7 Basic values for the calculation	21
5.7.1 Air temperatures	21
5.7.2 External air pressure (p_L)	23
5.7.3 Gas constant	23
5.7.4 Density of the external air (ρ_L)	24
5.7.5 Specific heat capacity of the flue gas (c_p)	24
5.7.6 Condensing temperature (T_{sp})	24
5.7.7 Correction factor for temperature instability (S_H)	24
5.7.8 Flow safety coefficient (S_E)	24
5.8 Determination of the temperatures	25
5.8.1 General.....	25
5.8.2 Calculation of the coefficient of cooling (K)	25
5.8.3 Coefficient of heat transmission (k_b)	26
5.9 Determination of the density of the flue gas and the velocity of the flue gas.....	28
5.9.1 Density of the flue gas (ρ_m)	28
5.9.2 Velocity of the flue gas (w_m)	28
5.10 Determination of the pressures.....	29
5.10.1 Pressure at the flue gas inlet into the chimney	29
5.10.2 Theoretical draught available due to chimney effect (P_H)	30
5.10.3 Pressure resistance of the chimney (P_R)	30
5.10.4 Wind velocity pressure (P_L)	31

5.11	Minimum draught required at the flue gas inlet into the chimney and maximum allowed draught (P_{Ze} and P_{Zemax}) and maximum and minimum differential pressure at the flue gas inlet into the chimney (P_{ZOe} and P_{ZOemin})	32
5.11.1	General	32
5.11.2	Minimum and maximum draught for the heating appliance (P_W and P_{Wmax}) and maximum and minimum differential pressure of the heating appliance (P_{WO} and P_{WOmin})	33
5.11.3	Effective pressure resistance of the connecting flue pipe (P_{FV})	33
5.11.4	Pressure resistance of the air supply (P_B)	34
5.12	Calculation of the inner wall temperature at the chimney outlet (T_{iob})	35
6	Secondary air for negative pressure chimneys	37
6.1	General	37
6.2	Calculation method	37
6.3	Basic values for the calculation of secondary air	37
6.3.1	General	37
6.3.2	Mixing calculations	37
6.4	Pressures	38
6.4.1	Pressure resistance for the air supply with secondary air (P_{BNL})	38
6.4.2	Draught required for the secondary air devices (P_{NL})	39
6.4.3	Pressure resistance for that part of the connecting flue pipe before the secondary air device (P_{FV1})	40
6.4.4	Pressure requirement with secondary air	41
6.5	Temperature requirement with secondary air	41
7	Calculation method for balanced flue chimneys	41
7.1	General principles	41
7.2	Pressure requirements	42
7.3	Temperature requirements	43
7.4	Calculation procedure	43
7.5	Flue gas data characterizing the heating appliance	43
7.6	Characteristic data for the calculation	44
7.7	Basic values for the calculation	44
7.7.1	Air temperatures	44
7.7.2	Other basic values	45
7.8	Determination of the temperatures	45
7.8.1	Non-concentric (separate) ducts	45
7.8.2	Concentric ducts – calculation based on a correction factor for heat radiation	45
7.8.3	Concentric ducts – calculation based on calculated heat radiation	60
7.8.4	Mean temperatures for pressure calculation	64
7.9	Determination of densities and velocities	65
7.9.1	Density and velocity of the flue gas	65
7.9.2	Density and velocity of the supply air	65
7.10	Determination of pressures	66
7.10.1	Pressure at the flue gas inlet into the chimney	66
7.10.2	Theoretical draught due to chimney effect in the chimney segment (P_H)	66
7.10.3	Pressure resistance in the chimney segment (P_R)	66
7.10.4	Wind velocity pressure (P_L)	66
7.11	Minimum draught required at the flue gas inlet into the chimney and maximum allowed draught (P_{Ze} and P_{Zemax}) and maximum and minimum differential pressure at the flue gas inlet into the chimney (P_{ZOe} and P_{ZOemin})	66
7.11.1	General	66
7.11.2	Minimum and maximum draught for the heating appliance (P_W and P_{Wmax}) and maximum and minimum differential pressure of the heating appliance (P_{WO} and P_{WOmin})	67
7.11.3	Effective pressure resistance of the connection pipe (P_{FV})	67
7.11.4	Pressure resistance of the air supply	67
7.12	Calculation of the inner wall temperature at the chimney outlet (T_{iob})	70
8	Consideration of the condensation heat of the flue gas water vapour	70

8.1	General.....	70
8.2	Onset of condensation.....	71
8.3	Calculation of the flue gas temperature at the outlet of a chimney segment with condensation ($j \geq N_{seg}K$)	73
9	Consideration of chimney fans	78
9.1	General.....	78
9.2	Inline fans	79
9.3	Exhaust fans.....	80
Annex A (informative)	Calculation of thermal resistance	82
Annex B (informative)	Tables	83
Annex C (informative)	Chimney outlet with regard to adjacent buildings	98
Annex D (informative)	Determination of the gas constant R considering the condensation.....	99

Foreword

This document (EN 13384-1:2015) has been prepared by Technical Committee CEN/TC 166 “Chimneys”, the secretariat of which is held by ASI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2015, and conflicting national standards shall be withdrawn at the latest by October 2015.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13384-1:2002+A2:2008.

According to EN 13384-1:2002+A2:2008 the following fundamental changes are given:

- editorial mistakes have been corrected;
- mistakes in formulas have been corrected;
- for wood the rise of the dew point to take into account the acid condensation has been deleted;
- table for material characteristics in Table B.5 has been adapted to EN 15287-1 and supplemented by radiation coefficients;
- in Calculation of thermal resistance according to Annex A are linked to the method of EN 15287-1 for taking into account the temperature dependence has been added;
- for non-concentric ducts the calculation of the mean temperature of the air supply has been amended;
- for chimney fans a calculation procedure has been added;

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

This European Standard “Chimneys — Thermal and fluid dynamic calculation methods” consists of three Parts:

- Part 1: Chimneys serving one heating appliance
- Part 2: Chimneys serving more than one heating appliance
- Part 3: Methods for the development of diagrams and tables for chimneys serving one heating appliance

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard specifies methods for the calculation of the thermal and fluid dynamic characteristics of chimneys serving one heating appliance.

The methods in this part of this European Standard are applicable to negative or positive pressure chimneys with wet or dry operating conditions. It is valid for chimneys with heating appliances for fuels subject to the knowledge of the flue gas characteristics which are needed for the calculation.

The methods in this part of this European Standard are applicable to chimneys with one inlet connected with one appliance. The methods in Part 2 of this European Standard are applicable to chimneys with multiple inlets and one inlet with multiple appliances. Part 3 describes methods for the development of diagrams and tables for chimneys serving one heating appliance.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1443, *Chimneys - General requirements*

EN 1856-1, *Chimneys - Requirements for metal chimneys - Part 1: System chimney products*

EN 1859, *Chimneys — Metal chimneys — Test methods*

EN 13502, *Chimneys - Requirements and test methods for clay/ceramic flue terminals*

EN 15287-1:2007+A1:2010, *Chimneys - Design, installation and commissioning of chimneys - Part 1: Chimneys for non-roomsealed heating appliances*

prEN 16475-2, *Chimneys - Accessories - Part 2: Chimney fans - Requirements and test methods*

CEN/TR 1749, *European scheme for the classification of gas appliances according to the method of evacuation of the combustion products (types)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1443 and the following apply.

3.1

heat output

Q

amount of heat produced by a heating appliance per unit of time

3.1.1

nominal heat output

Q_N

continuous heat output specified by the manufacturer of the heating appliance related to specified fuels