AVALIKE ELEKTRIVÕRKUDE PINGE TUNNUSSUURUSED

Voltage characteristics of electricity supplied by public distribution networks



EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50160:2010+A1:2015 sisaldab Euroopa standardi EN 50160:2010, selle paranduse AC:2010 ja muudatuse A1:2015 ingliskeelset teksti.

Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.

Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 30.07.2010, muudatuse A1 16.01.2015.

Standard on kättesaadav Eesti Standardikeskusest. This Estonian standard EVS-EN 50160:2010+ A1:2015 consists of the English text of the European standard EN 50160:2010, its corrigendum AC:2010 and amendment A1:2015.

This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.

Date of Availability of the European standard is 30.07.2010, for amendment A1 16.01.2015.

The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile <u>standardiosakond@evs.ee</u>.

ICS 29.020

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega: Aru 10, 10317 Tallinn, Eesti; koduleht <u>www.evs.ee;</u> telefon 605 5050; e-post <u>info@evs.ee</u>

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 50160

NORME EUROPÉENNE EUROPÄISCHE NORM

July 2010

ICS 29.020

Supersedes EN 50160:2007

English version

Voltage characteristics of electricity supplied by public electricity networks

Caractéristiques de la tension fournie par les réseaux publics de distribution

Merkmale der Spannung in öffentlichen Elektrizitätsversorgungsnetzen

This European Standard was approved by CENELEC on 2010-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by Working Group 1, Physical characteristics of electrical energy, of the Technical Committee CENELEC TC 8X, System aspects of electrical energy supply. It was submitted to the formal vote and was approved by CENELEC as EN 50160 on 2010-03-01.

This document is the result of an intensive cooperation between CENELEC and CEER, with involvement of CEER experts in TC 8X WG1 as well as in related Task Forces.

This document supersedes EN 50160:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

 latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement

(dop) 2011-03-01

 latest date by which the national standards conflicting with the EN have to be withdrawn

(dow) 2015-03-01

2/25

The main differences from EN 50160:2007 are:

- new organization of the document by grouping clauses related to events and continuous phenomena;
- modification of some definitions and completion by some new definitions;
- new Clause 6 relevant to voltage characteristics in high voltage networks.

This work has been deemed so important, that before submission for vote, a CENELEC enquiry has been made, where NCs had the opportunity to respond to the most essential questions resulting from the WG discussions. This enquiry resulted in an extensive number of valuable comments, which have been carefully examined for possible consideration either for the voting draft in particular or for further work within WG1 on some main issues. Following that, the draft has been revised in depth, considering in particular the comments received on:

- the subclauses relevant to supply voltage changes, where a new formulation (capable of encompassing the needs expressed by the vast majority of the NCs) has been introduced,
- the new Clause 6, relevant to voltage characteristics in high voltage networks, where limits for harmonics and unbalance have been changed into indicative values, as new measurement surveys are taking place in several European countries, and it has been recognized as appropriate to wait for the relevant results before considering the setting of limits.

Contents

1	Scope and object4				
	1.1	Scope	4		
	1.2	Object	4		
2	Norr	native references	5		
3	Terms and definitions				
4	Low-voltage supply characteristics				
	4.1	General	. 10		
	4.2	Continuous phenomena	. 11		
	4.3	Voltage events	. 14		
5	Medium-voltage supply characteristics				
	5.1	General	. 16		
	5.2	Continuous phenomena	. 17		
	5.3	Voltage events	. 20		
6	High-voltage supply characteristics				
	6.1	General	. 22		
	6.2	Continuous phenomena	. 23		
	6.3	Voltage events	. 25		
Anne	x A (informative) Special nature of electricity	. 28		
Anne	xB (informative) Indicative values for voltage events and single rapid voltage changes	. 30		
	B.1	Long interruptions of the supply voltage	. 30		
	B.2	Short interruptions of the supply voltage	. 30		
	B.3	Voltage dips and swells	. 30		
	B.4	Swells (temporary power frequency overvoltages) between live conductors			
		earth			
	B.5	Magnitude of rapid voltage changes			
Bibli	ograp	hy	. 33		
Figui	res				
•		Voltage levels of signal frequencies in percent of U_n used in public LV networks	. 13		
_		Voltage levels of signal frequencies in percent of U_c used in public MV networks			
ı ıguı	O _	voltage levels of digital frequencies in persont of ec acca in public in vinetworks	0		
Table					
Table perce	ent of t	Values of individual harmonic voltages at the supply terminals for orders up to 25 given in the fundamental voltage U_1	. 13		
Table	2 —	the fundamental voltage U_1	. 15		
Table	e 3 —	Classification of swells according to maximum voltage and duration	. 16		
Table	e 4 — ent of t	Values of individual harmonic voltages at the supply terminals for orders up to 25 given in the fundamental voltage U_1	. 19		
		Classification of dips according to residual voltage and duration			
		Classification of swells according to maximum voltage and duration			
Table	e 7 —	Indicative values of individual harmonic voltages at the supply terminals for orders up to percent of the fundamental voltage U_1			
_		Classification of dips according to residual voltage and duration			
		Classification of swells according to maximum voltage and duration			

1 Scope and object

1.1 Scope

This European Standard defines, describes and specifies the main characteristics of the voltage at a network user's supply terminals in public low voltage, medium and high voltage AC electricity networks under normal operating conditions. This standard describes the limits or values within which the voltage characteristics can be expected to remain at any supply terminal in public European electricity networks and does not describe the average situation usually experienced by an individual network user.

NOTE 1 For the definitions of low, medium and high voltage see 3 (Definitions).

This European Standard does not apply under abnormal operating conditions, including the following:

- a) a temporary supply arrangement to keep network users supplied during conditions arising as a result
 of a fault, maintenance and construction work, or to minimize the extent and duration of a loss of
 supply;
- b) in the case of non-compliance of a network user's installation or equipment with the relevant standards or with the technical requirements for connection, established either by the public authorities or the network operator, including the limits for the emission of conducted disturbances;

NOTE 2 A network user's installation may include load and generation.

- c) in exceptional situations, in particular,
 - 1) exceptional weather conditions and other natural disasters;
 - third party interference;
 - 3) acts by public authorities;
 - 4) industrial actions (subject to legal requirements);
 - 5) force majeure;
 - 6) power shortages resulting from external events.

The voltage characteristics given in this standard are not intended to be used as electromagnetic compatibility (EMC) levels or user emission limits for conducted disturbances in public electricity networks.

The voltage characteristics given in this standard are not intended to be used to specify requirements in equipment product standards and in installation standards.

NOTE 3 The performance of equipment might be impaired if it is subjected to supply conditions which are not specified in the equipment product standard.

This standard may be superseded in total or in part by the terms of a contract between the individual network user and the network operator.

NOTE 4 The sharing of complaint management and problem mitigation costs between the involved parties is outside the scope of EN 50160.

Measurement methods to be applied in this standard are described in EN 61000-4-30.

1.2 Object

The object of this European Standard is to define, describe and specify the characteristics of the supply voltage concerning:

- a) frequency;
- b) magnitude;
- c) waveform;
- d) symmetry of the line voltages.

These characteristics are subject to variations during the normal operation of a supply system due to changes of load, disturbances generated by certain equipment and the occurrence of faults which are mainly caused by external events.

The characteristics vary in a manner which is random in time, with reference to any specific supply terminal, and random in location, with reference to any given instant of time. Because of these variations, the values given in this standard for the characteristics can be expected to be exceeded on a small number of occasions.

Some of the phenomena affecting the voltage are particularly unpredictable, which make it very difficult to give useful definite values for the corresponding characteristics. The values given in this standard for the voltage characteristics associated with such phenomena, e.g. voltage dips and voltage interruptions, shall be interpreted accordingly.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60664-1	2007	Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests (IEC 60664-1:2007)
EN 61000-3-3	2008	Electromagnetic compatibility (EMC) – Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection (IEC 61000-3-3:2008)
EN 61000-4-30	2009	Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods (IEC 61000-4-30:2008)
IEC 60364-5-53 + A1	2001 2002	Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control
IEC/TR 61000-2-8	2002	Electromagnetic compatibility (EMC) – Part 2-8: Environment – Voltage dips and short interruptions on public electric power supply systems with statistical measurement results
IEC/TR 61000-3-7	2008	Electromagnetic compatibility (EMC) – Part 3-7: Assessment of emission limits for fluctuating loads in MV and HV power systems

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

conducted disturbance

electromagnetic phenomenon propagated along the line conductors of a supply network

NOTE In some cases an electromagnetic phenomenon is propagated across transformer windings and hence between networks of different voltage levels. These disturbances may degrade the performance of a device, equipment or system or they may cause damage.

3.2

declared supply voltage

U.

supply voltage U_c agreed by the network operator and the network user

NOTE Generally declared supply voltage U_c is the nominal voltage U_n but it may be different according to the agreement between the network operator and the network user.