

**Extended application of results from fire resistance
tests for service installations - Part 4: Linear joint seals**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 15882-4:2012 sisaldab Euroopa standardi EN 15882-4:2012 ingliskeelset teksti.	This Estonian standard EVS-EN 15882-4:2012 consists of the English text of the European standard EN 15882-4:2012.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 09.05.2012.	Date of Availability of the European standard is 09.05.2012.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.220.99

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

ICS 13.220.99

English Version

Extended application of results from fire resistance tests for
service installations - Part 4: Linear joint seals

Application étendue des résultats des essais de résistance
au feu pour les installations de service - Partie 4 :
Calfeutrements de joints linéaires

Erweiterter Anwendungsbereich der Ergebnisse aus
Feuerwiderstandsprüfungen für Installationen - Teil 4:
Abdichtungssysteme für Bauteilfugen

This European Standard was approved by CEN on 30 March 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
4 Extended application principles	7
4.1 General	7
4.2 Principles common to all generic seal types	7
4.2.1 General	7
4.2.2 Seal material (primary generic linear joint seal material as per Annex A)	8
4.2.3 Separating elements — Concrete or masonry	8
4.2.4 Separating elements – Flexible constructions	8
4.2.5 Seal depth	9
5 Extended application report — Contents of the extended application report	9
Annex A (normative) Extended application principles for generic joint seal types	11
A.1 General rules	11
A.2 Specific rules	12

Foreword

This document (EN 15882-4:2012) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2012, and conflicting national standards shall be withdrawn at the latest by November 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

EN 15882 consists of the following parts:

- EN 15882-1, *Extended application of results from fire resistance tests for service installations — Part 1: Ducts*;
- prEN 15882-2, *Extended application of results from fire resistance tests for service installations — Part 2: Dampers*;
- EN 15882-3, *Extended applications of results from fire resistance tests for service installations — Part 3: Penetration seals*;
- EN 15882-4, *Extended application of results from fire resistance tests for service installations — Part 4: Linear joint seals*.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European standard specifies rules and prescribes the methodology for the preparation of extended application reports for linear joint sealing systems tested in accordance with EN 1366-4. The field of the extended application reports is additional to the direct field of application given in EN 1366-4. It may be applied to or based on a single test, or a number of tests, which provide the relevant information for the formulation of an extended application.

Mechanical metal seals are not part of the scope of this European Standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:1999, *Fire resistance tests — Part 1: General requirements*

EN 1363-2:1999, *Fire resistance tests — Part 2: Alternative and additional procedures*

EN 1366-4:2006+A1:2010, *Fire resistance tests for service installations — Part 4: Linear joint seals*

EN 13501-1:2007+A1:2009, *Fire classification of construction products and building elements — Part 1: Classification using data from reaction to fire tests*

EN 13501-2:2007+A1:2009, *Fire classification of construction products and building elements — Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN ISO 13943:2010, *Fire safety — Vocabulary (ISO 13943:2008)*

3 Terms and definitions

For the purposes of this document the terms and definitions given in EN 1363-1:1999, EN 1363-2:1999, EN 1366-4:2006+A1:2010, EN 13501-1:2007+A1:2009, EN 13501-2:2007+A1:2009 and EN ISO 13943:2010, and the following apply:

3.1

fabric seal

seal comprised of a woven fabric, usually glass cloth or similar, which may be used in a combination with other material, such as metal facings, etc. to provide a composite seal

3.2

foam seal

seal made from a one, two or three component expanding foam (expands during application), applied in-situ

3.3

joint depth

overall distance between the exposed and unexposed faces across the thickness of the separating element

Note 1 to entry: See Figure 1.

3.4

joint face framing

additional substrate incorporated between the supporting construction and the joint seal