

Test methods and requirements for accessories for use on distribution cables of rated voltage 0,6/1,0 (1,2) kV

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50393:2015 sisaldab Euroopa standardi EN 50393:2015 ingliskeelset teksti.	This Estonian standard EVS-EN 50393:2015 consists of the English text of the European standard EN 50393:2015.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 13.02.2015.	Date of Availability of the European standard is 13.02.2015.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.120.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Aru 10, 10317 Tallinn, Eesti; koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Test methods and requirements for accessories for use on distribution cables of rated voltage 0,6/1,0 (1,2) kV

Méthodes et prescriptions d'essai pour les accessoires de
câbles de distribution de tension assignée 0,6/1,0 (1,2) kV

Prüfverfahren und Prüfanforderungen für die Garnituren von
Verteilerkabeln mit einer Nennspannung von 0,6/1,0 (1,2)
kV

This European Standard was approved by CENELEC on 2014-12-08. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Foreword.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	7
4 Components	8
4.1 Connectors.....	8
4.2 Materials	9
5 Electrical characteristics.....	9
5.1 Rated voltage.....	9
5.2 Current rating.....	9
6 Range of compliance.....	9
6.1 General.....	9
6.2 Cables.....	9
6.3 Connectors for joints	10
6.4 Water immersion depth.....	11
6.5 Transition joints.....	11
7 Type tests	11
7.1 General.....	11
7.2 Test samples.....	12
7.3 Sequence of tests	12
8 Test methods	15
8.1 General.....	15
8.2 Impulse voltage withstand test at ambient temperature.....	16
8.3 AC voltage withstand test.....	16
8.4 Insulation resistance test.....	17
8.5 Impact test at ambient temperature	17
8.6 Heating cycle test.....	18
8.7 Immersion test – test installation	19
8.8 Examination	19
8.9 Metallic screen short-circuit current withstand test	20
Annex A (informative) Determination of cable conductor temperature.....	29
Annex B (informative) Identification of test cable	34
Annex C (informative) Identification of accessory test samples	35
Annex D (informative) Identification of connector	36
Bibliography.....	37
Figures	
Figure 1 – Example of envelope diameter.....	11
Figure 2 – Typical arrangement for the impact test for joints at ambient temperature.....	21
Figure 3 – Typical arrangement for the heating cycle for joints in air	22
Figure 4 – Typical arrangement for the heating cycle test for joints in water.....	22
Figure 5 – Typical arrangement for the heating cycle test for outdoor terminations in water	23
Figure 6 – Method of connection of three-phase cables for the heating cycle test on a straight joint.....	24

Figure 7 – Method of connection of three-phase cables for the heating cycle test on a branch joint where the main cable conductor cross-section is greater than 50 mm ² and the branch cable conductor cross-section is less than or equal to 50 mm ²	25
Figure 8 – Method of connection of three-phase main and branch cables of equal conductor cross-section for the heating cycle test on a branch joint.....	26
Figure 9 – Method of connection of three-phase main and branch cables of unequal conductor cross-section for the heating cycle test on a branch joint.....	27
Figure 10 – Typical heating cycle.....	28
Figure 11 – Arrangement for the screen short-circuit test.....	28
Figure A.1 – Arrangement for the cable calibration test.....	30
Figure A.2 – Variation of θ_c with θ_{st} for various heating currents.....	33
Tables	
Table 1 – Summary of compliance with different cable insulations.....	10
Table 2 – Compliance extension for conductor connectors in joints.....	10
Table 3 – Test sequence for joints for solid extruded dielectric insulated cables and for transition joints between solid extruded dielectric insulated cables and impregnated paper insulated cables.....	12
Table 4 – Test sequence for stop ends on solid extruded dielectric insulated cables.....	13
Table 5 – Test sequence for outdoor terminations on solid extruded dielectric insulated cables.....	13
Table 6 – Number of test samples and conductor cross-section: straight joints.....	14
Table 7 – Number of test samples and conductor cross-section: branch joints.....	14
Table 8 – Number of test samples and conductor cross-section: stop ends.....	15
Table 9 – Number of test samples and conductor cross-section: outdoor terminations.....	15

Document is a preview generated by EVS

Foreword

This document (EN 50393:2015) has been prepared by CLC/TC 20 “Electric cables”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-12-08
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2017-12-08

This document supersedes EN 50393:2006.

EN 50393:2015 includes the following significant technical changes with respect to EN 50393:2006:

- in Clause 1 'Scope', the revised statement referring to 'existing approvals' has been inserted;
- in Clause 3 'Definitions', definitions of stop end types have been revised to align with those of joints, and definitions of 'rigid' and 'non-rigid' joints have been removed;
- in Clause 6 'Range of compliance', the numbers of joint and termination test samples have been increased (see also Table 6), compliance restriction and extension with regard to different cable designs have been clarified, and compliance restrictions and extensions relating to conductor connectors have been inserted and shown in a new Table 2;
- in 7.3, Table 3, joints of Type II are subject to a new test involving 9 heating cycles in water without oversheath damage (see also 8.6.2);
- in 7.3, Tables 3, 4 and 5, the footnotes referring to examination of tested accessories have been removed;
- in Clause 8 'Test methods', the AC voltage withstand test procedure has been simplified and clarified, references to 'rigid' and 'non-rigid' joints have been removed, reference to the 9 cycle test for Type II joints (Table 3) has been inserted, and requirements relating to examination of tested joints have been simplified and references to specific technologies or materials have been removed;
- Annexes B, C and D have been added to assist in full and accurate identification of test cable, accessories and connectors for inclusion in test reports.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

1 Scope

This European Standard details the performance requirements and the test methods for type testing of cable accessories for use with power distribution cables of rated voltage 0,6/1,0 (1,2) kV as defined in HD 603 or other relevant cable standards.

Cable accessories covered by this European Standard include joints, stop ends and outdoor terminations for extruded solid dielectric insulated cables and transition joints between extruded solid dielectric insulated and impregnated paper insulated cables. Joints, stop ends and outdoor terminations for impregnated paper insulated cables are not included.

The service operating conditions of accessories should be compatible with the service operating conditions of cables on which they are to be installed.

Accessories for special applications such as submarine, shipboard, explosive or seismic environments, or where specified fire performance characteristics are required, are not included.

NOTE 1 This European Standard does not invalidate existing approvals of products achieved on the basis of national standards and specifications and/or the demonstration of satisfactory service performance. However, products approved according to such national standards or specifications cannot directly claim approval to this European standard.

NOTE 2 It may be possible, subject to agreement between supplier and purchaser, and/or the relevant conformity assessment body, to demonstrate that conformity to the earlier standard can be used to claim conformity to this European Standard, provided an assessment is made of any additional type testing that may need to be carried out. Any such additional testing that is part of a sequence of testing cannot be done separately.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 61180-1:1994, *High-voltage test techniques for low-voltage equipment – Part 1: Definitions, test and procedure requirements (IEC 61180-1:1992)*

EN 61238-1, *Compression and mechanical connectors for power cables for rated voltages up to 36 kV ($U_m = 42$ kV) – Part 1: Test methods and requirements (IEC 61238-1)*

HD 603, *Distribution cables of rated voltage 0,6/1 kV*

IEC 60050-461, *International Electrotechnical Vocabulary – Chapter 461: Electric cables*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-461 and the following apply.

3.1 joint

accessory suitable for use in air or underground which makes a connection between two or more insulated power cables to form a continuous circuit