IEC TS 62735-1

Edition 1.0 2015-08

TECHNICAL SPECIFICATION

This document is a preview generated by EVS

colour inside

Direct current (DC) plugs and socket-outlets for information and communication technology (ICT) equipment installed in data centres and telecom central offices
Part 1: Plug and socket-outlet system for 2,6 kW



IEC TS 62735-1:2015-08(en)

THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue
The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,…). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org
The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary
More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

This document is a preview generated by EVS

IEC TS 62735-1

Edition 1.0 2015-08

TECHNICAL SPECIFICATION

This document is a preview generated by EVS

colour inside

Direct current (DC) plugs and socket-outlets for information and communication technology (ICT) equipment installed in data centres and telecom central offices
Part 1: Plug and socket-outlet system for 2,6 kW

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120; 29.120.30

ISBN 978-2-8322-2869-2

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

CONTENTS

FOREWORD 6
1 Scope 8
2 Normative references 9
3 Terms and definitions 10
4 General requirements 14
5 General notes on tests 14
6 Ratings 16
7 Classification 16
7.1 Accessory classifications 16
7.1.1 Classification according to the method of connecting the cable 16
7.1.2 Classification according to the type of terminals 16
7.2 Socket-outlet classifications 16
7.2.1 Classification according to the degree of protection against electric shock 16
7.2.2 Classification according to the existence of shutters 16
7.2.3 Classification according to the method of application/mounting of the socket-outlet 16
7.2.4 Classification according to the method of installation 17
8 Marking 17
8.1 General 17
8.2 Symbols 17
8.3 Visibility of markings 18
8.4 Marking for plugs 18
8.5 Marking of terminals 18
8.6 Durability of marking 19
9 Checking of dimensions 19
10 Protection against electric shock 19
11 Provision for earthing 22
12 Terminals and terminations 23
12.1 General 23
12.2 Terminals with screw clamping for external copper conductors 24
12.3 Screwless terminals for external copper conductors 29
12.4 Flat quick-connect terminations 35
12.4.1 General 35
12.4.2 Constructional requirements 35
12.4.3 Electrical requirements 36
12.5 Permanent connections 36
13 Construction of socket-outlets 36
14 Construction of plugs 43
15 Interlocked socket-outlets 48
16 Resistance to ageing, protection provided by enclosures, and resistance to humidity 48
16.1 Resistance to ageing 48
16.2 Protection provided by enclosures 49
16.2.1 General 49

This document is a preview generated by EVS

16.2.2 Protection against access to hazardous parts and against harmful effects due to ingress of solid foreign objects 49
16.3 Resistance to humidity 50
17 Insulation resistance and electric strength 51
18 Operation of earthing contacts 52
19 Temperature rise 53
20 Breaking capacity 56
21 Normal operation 57
22 Force necessary to withdraw the plug 58
22.1 General 58
22.2 Verification of the maximum withdrawal force for socket-outlets 59
22.3 Verification of the minimum withdrawal force 59
23 Flexible cables and their connection 60
24 Mechanical strength 63
25 Resistance to heat 72
26 Screws, current-carrying parts and connections 73
27 Creepage distances, clearances and distances through sealing compound 75
28 Resistance of insulating material to abnormal heat and to fire 77
29 Resistance to rusting 78
Annex A (normative) Safety-related routine tests for factory-wired accessories (protection against electric shock and correct polarity) 107
A.1 General remarks 107
A.2 Polarized systems, “+” and “−” – correct connection 107
A.3 Earth continuity 108
A.4 Short-circuit/wrong connection and reduction of creepage distance and clearances between “+” and “−” to earth ( ) 108
Annex B (normative) Survey of specimens needed for tests 109
Annex C (informative) Alternative gripping tests 110
C.1 Gripping test C1 110
C.2 Gripping test C2 112
Annex D (normative) Standard sheets and gauges 114
D.1 Standard sheets 114
D.2 Gauges for checking the dimensions of the entry holes 118
Bibliography 121

Figure 1 – Examples of accessories 80
Figure 2 – Pillar terminals 81
Figure 3 – Screw terminals and stud terminals 82
Figure 4 – Saddle terminals 83
Figure 5 – Mantle terminals 84
Figure 6 – Example of thread-forming screw 84
Figure 7 – Example of thread-cutting screw 84
Figure 8 – Arrangement for compression test of 10.2 and 24.6 85
Figure 9 – Gauge for checking non-accessibility of live parts, through shutters 86
Figure 10 – Gauge for checking non-accessibility of live parts, through shutters, and of live parts of socket-outlets with increased protection 87

This document is a preview generated by EVS

Figure 11 – Arrangement for checking damage to conductors 88
Figure 12 – Information for deflection test 89
Figure 13 – Device for checking the resistance to lateral strain 90
Figure 14 – Example of apparatus for breaking capacity and normal operation test 91
Figure 15 – Circuit diagram for breaking capacity and normal operation tests 92
Figure 16 – Apparatus for verification of maximum withdrawal force 92
Figure 17 – Apparatus for testing cord retention 93
Figure 18 – Apparatus for flexing test 94
Figure 19 – Sketches showing the application of the blows according to Table 20 95
Figure 20 – Apparatus for impact test at low temperature of 24.5 96
Figure 21 – Example of test arrangement to verify the fixation of pins in the body of the plug 97
Figure 22 – Arrangement for test on covers or cover-plates 97
Figure 23 – Gauge (thickness about 2 mm) for the verification of the outline of covers or cover-plates 98
Figure 24 – Examples of application of the gauge of Figure 23 on covers fixed without screws on a mounting surface or supporting surface 99
Figure 25 – Examples of application of the gauge of Figure 23 in accordance with the requirements of 24.16 100
Figure 26 – Gauge for verification of grooves, holes and reverse tapers 101
Figure 27 – Sketch showing the direction of application of the gauge of Figure 26 101
Figure 28 – Ball pressure test apparatus 101
Figure 29 – Apparatus for compression test for the verification of resistance to heat of 25.5 102
Figure 30 – Test procedures for normal operation (see Clause 21) 103
Figure 31 – Clamping unit for the temperature rise test of Clause 19 104
Figure 32 – The profile of the inrush current for the test of Clause 20 105
Figure 33 – Annex to Figure 32 with additional information on a possible circuit to produce the inrush current as given in Figure 32 105
Figure 34 – Circuit diagram for testing socket-outlets and plugs according to 18.2 106
Figure 35 – Possible test setup for the temperature rise test for Clauses 19 and 21 106
Figure C.1 – Reference plug for gripping test 111
Figure C.2 – Example of the test apparatus for plug gripping test 112
Figure D.1 – Standard sheet 1: 2,6 kW / 294 V to 400 V d.c. socket-outlet for class I equipment 115
Figure D.2 – Standard sheet 2: 2,6 kW / 294 V to 400 V d.c. plug for class I equipment 116
Figure D.3 – Standard sheet 3: positioning of the “+” and “−” pins/socket-contacts 117
Figure D.4 – Minimum gauges for checking the dimensions of the entry holes: C1 118
Figure D.5 – Maximum gauges for checking the dimensions of the entry holes: C2 118
Figure D.6 – Gauge for checking the first point of contact: C3 119
Figure D.7 – Gauges for checking the minimum withdrawal force (see 22.3) 119
Figure D.8 – Gauge for checking the maximum withdrawal force: C4max (see 22.2) 120

Table 1 – Relationship between rated power and connectable nominal cross-sectional areas or American Wire Gauge (AWG) size of copper conductors 24
Table 2 – Values for pull test for screw-type terminals 26

This document is a preview generated by EVS

Table 3 – Composition of conductors 27
Table 4 – Tightening torques for the verification of the mechanical strength of screw-type terminals 28
Table 5 – Relationship between rated power and connectable cross-sectional areas or AWG size of copper conductors for screwless terminals 30
Table 6 – Value for pull test for screwless-type terminals 32
Table 7 – Values for flexing under mechanical load test for copper conductors 32
Table 8 – Test current for the verification of electrical and thermal stresses in normal use for screwless terminals 33
Table 9 – Nominal cross-sectional areas or AWG size of rigid copper conductors for deflection test of screwless terminals 34
Table 10 – Deflection test forces 35
Table 11 – Forces to be applied to tabs 36
Table 12 – Relationship between tab size and maximum current 36
Table 13 – Forces to be applied to covers, cover-plates or actuating members whose fixing is not dependent on screws 38
Table 14 – External cable dimension limits for surface-type socket-outlets 40
Table 15 – Nominal cross-sectional areas of copper conductors and test currents for the temperature rise test 54
Table 16 – Maximum and minimum withdrawal force for plugs and socket-outlets 60
Table 17 – External dimensions of flexible cables to be accommodated by cord anchorages 60
Table 18 – Torque test values for cord anchorages 61
Table 19 – Maximum dimensions of flexible cables to be accommodated in rewirable accessories 62
Table 20 – Height of fall for impact tests 65
Table 21 – Torque test values for glands 68
Table 22 – Resistance to heat of different types or parts of accessories 72
Table 23 – Creepage distances, clearances and distances through insulating sealing compound 76
Table B.1 – Number of specimens needed for the tests according to 5.5 109

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

DIRECT CURRENT (DC) PLUGS AND SOCKET-OUTLETS FOR INFORMATION AND COMMUNICATION TECHNOLOGY (ICT) EQUIPMENT INSTALLED IN DATA CENTRES AND TELECOM CENTRAL OFFICES

Part 1: Plug and socket-outlet system for 2,6 kW

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62735-1, which is a Technical Specification, has been prepared by IEC technical committee 23: Electrical accessories.

This document is a preview generated by EVS

In this standard, the following print types are used:

– compliance statements: in *italic* type

The text of this Technical Specification is based on the following documents:

Enquiry draft	Report on voting
23/692/DTS	23/708A/RVC

Full information on the voting for the approval of this Technical Specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62735 series, published under the general title *Direct current (DC) plugs and socket-outlets for information and communication technology (ICT) equipment installed in data centres and telecom central offices*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International Standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

This document is a preview generated by EVS

DIRECT CURRENT (DC) PLUGS AND SOCKET-OUTLETS FOR INFORMATION AND COMMUNICATION TECHNOLOGY (ICT) EQUIPMENT INSTALLED IN DATA CENTRES AND TELECOM CENTRAL OFFICES

Part 1: Plug and socket-outlet system for 2,6 kW

This document is a preview generated by EVS

1 Scope

This part of IEC 62735, which is a Technical Specification, applies to plugs and fixed socket-outlets for class I equipment with two active contacts plus an earthing contact, a rated power of 2,6 kW and a rated voltage range from 294 V to 400 V d.c. They are intended to power d.c. information and communication technology equipment only, products according to IEC 60950.

The accessories according to this part of IEC 62735 are intended to be used by ordinary persons in data centres only where the value of the d.c. voltage distribution system is defined as follows:

– 380 V with a tolerance of ±20 V for installations with no backup battery or with a voltage regulation system;
– 380 V with a voltage range of 294 V to 400 V for installations with a backup battery where voltage regulation is not guaranteed;
– the voltage value between each live conductor and earth does not exceed 200 V d.c. during normal operation;
– there are two abnormal voltage ranges (duration below 10 min):
  - 260 V up to 294 V, and
  - above 400 V to 410 V.

The maximum current of the plug and the socket-outlet is

– 6,5 A when the voltage between live contacts is 400 V d.c.,
– 8,8 A when the voltage between live contacts is 294 V d.c.

and can rise up to 10 A when the voltage between live contacts decreases to 260 V d.c. for 10 min maximum.

The voltage between live conductors can fall down to 260 V d.c. when the voltage discharge value of the battery reaches the disconnecting level. The consequence is that the current increases accordingly.

The accessories according to this part of IEC 62735 do not require maintenance.

Plugs and socket-outlets covered by this part of IEC 62735 are intended for use in circuits where

– basic protection,
– an overcurrent protection (of 8,8 A or less for each socket-outlet or multiple socket-outlet),
– the fault protection (indirect contact protection), and
– additional protection

are already assured.

This part of IEC 62735 does not cover requirements for flush mounting boxes: however, it covers only those requirements for surface-type mounting boxes which are necessary for the tests on the socket-outlet.

NOTE 1 General requirements for mounting boxes are given in IEC 60670.

This part of IEC 62735 also applies to

– plugs incorporated in cord sets,
– plugs and socket-outlets incorporated in cord extension sets for data centres to be fixed to a wall or a rack,
– the cord extension set and multiple socket-outlets for data centres intended to be fixed to a wall or a rack, and
– socket-outlets which are a component of an assembly,

unless otherwise stated in the standard for the relevant assembly.

This part of IEC 62735 does not apply to

– single or multiple portable socket-outlets not fixed to a wall or a rack;
– plugs, socket-outlets and couplers for industrial purposes;
– plugs, socket-outlets and vehicle couplers for electric vehicles according to the IEC 61851 and IEC 62196 series;
– plugs and socket-outlets for household;
– appliance couplers;
– plugs, fixed and portable socket-outlets for extra-low voltage (ELV);

NOTE 2 ELV values are specified in IEC 60364-4-41.

– fixed socket-outlets combined with fuses, automatic switches, etc.

Socket-outlets with pilot lights are allowed provided that pilot lights comply with the relevant standard, if any.

Plugs and socket-outlets complying with this part of IEC 62735 are only suitable for use at ambient temperatures not normally exceeding +40 °C, but their average over a period of 24 h does not exceed +35 °C, with a lower limit of the ambient air temperature of −5 °C.

Socket-outlets complying with this part of IEC 62735 are only suitable for incorporation or mounting in equipment in such a way and in such a place that it is unlikely that the surrounding temperature exceeds 35 °C.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151:2001, *International Electrotechnical Vocabulary – Part 151: Electrical and magnetic devices* (available at: www.electropedia.org)

IEC 60068-2-31, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*

This document is a preview generated by EVS

IEC 60227 (all parts), *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60245 (all parts), *Rubber insulated cables – Rated voltages up to and including 450/750 V*

IEC 60352-2, *Solderless connections – Part 2: Crimped connections – General requirements, test methods and practical guidance*

IEC 60423, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60512-12-1, *Connectors for electronic equipment – Tests and measurements – Part 12-1: Soldering tests – Test 12a: Solderability, wetting, solder bath method*

IEC 60512-12-2, *Connectors for electronic equipment – Tests and measurements – Part 12-2: Soldering tests – Test 12b: Solderability, wetting, soldering iron method*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60695-2-11, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 61032, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61210, *Connecting devices – Flat quick-connect terminations for electrical copper conductors – Safety requirements*

ISO 1456, *Metallic coatings – Electrodeposited coatings of nickel, nickel plus chromium, copper plus nickel and of copper plus nickel plus chromium*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-151 and the following apply.

NOTE 1 Where the terms "voltage" and "current" are used, they imply r.m.s. values, unless otherwise specified.

NOTE 2 Throughout this part of IEC 62735, the word "earthing" is used for “protective earthing”.

NOTE 3 The term "accessory" is used as a general term covering plugs and socket-outlets; the term "portable accessory" covers plugs. Examples of the use of accessories are shown in Figure 1a.

3.1
plug
accessory having pins designed to engage with the contacts of a socket-outlet, also incorporating means for the electrical connection and mechanical retention of flexible cable

3.2
socket-outlet
accessory intended for frequent use by ordinary persons, having socket contacts designed to engage with the pins of a plug and having terminals, terminations or other means for the connection of cable and the like

Note 1 to entry: Throughout this part of IEC 62735, socket-outlets cover fixed socket-outlets, single and multiple socket-outlets for data centres to be fixed to a wall or a rack.

This document is a preview generated by EVS