

GAASIKÜTTEL TÖÖTAVAD ENDOTERMILISE
MOOTORIGA SOOJUSPUMBAD. OSA 4: KATSEMEETODID

Gas-fired endothermic engine driven heat pumps - Part
4: Test methods

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 16905-4:2017 sisaldab Euroopa standardi EN 16905-4:2017 ingliskeelset teksti.	This Estonian standard EVS-EN 16905-4:2017 consists of the English text of the European standard EN 16905-4:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 08.03.2017.	Date of Availability of the European standard is 08.03.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 27.080

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Gas-fired endothermic engine driven heat pumps - Part 4: Test methods

Pompes à chaleur à moteur endothermique alimenté
au gaz - Partie 4 : Méthodes d'essai

Gasbefeuerte endothermische Motor-Wärmepumpen -
Teil 4: Prüfverfahren

This European Standard was approved by CEN on 9 January 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	5
1 Scope.....	6
1.1 Scope of EN 16905 series.....	6
1.2 Scope of EN 16905-4.....	6
2 Normative references.....	7
3 Terms and definitions	7
4 Test methods	7
4.1 General.....	7
4.2 Basic principles method of calculation for the determination of capacities.....	7
4.2.1 Capacity.....	7
4.2.2 Engine heat recovery capacity.....	9
4.2.3 Heat input	11
4.2.4 Electrical power input.....	12
4.2.5 Gas utilization efficiency (GUE).....	16
4.2.6 Auxiliary energy factor (AEF)	17
4.2.7 Engine heat recovery efficiency (EHRE)	18
4.2.8 Primary energy factor (PER).....	19
4.3 Test apparatus.....	19
4.3.1 Arrangement of the test apparatus.....	19
4.3.2 Installation and connection of the appliance.....	20
4.4 Uncertainties of measurement.....	21
4.5 Test procedure	23
4.5.1 General.....	23
4.5.2 Non-cyclical operation	26
4.5.3 Cyclical operation	38
4.6 Test methods for electric power consumption during thermostat off mode, standby mode and off mode	42
4.6.1 Measurement of electrical power consumption during thermostat off mode.....	42
4.6.2 Measurement of the electrical power consumption during standby mode.....	42
4.6.3 Measurement of the electric power consumption during crankcase heater mode	42
4.6.4 Measurement of the electric power consumption during off mode	43
4.7 Test results — Data to be recorded	43
5 Heat recovery test for air-cooled multisplit systems.....	45
5.1 Test installation	45
5.1.1 General.....	45
5.1.2 Three-room calorimeter method	45
5.1.3 Three-room air-enthalpy method.....	45
5.1.4 Two-room air-enthalpy method	45
5.2 Test procedure	46
5.3 Test results	46
6 Test report.....	46
6.1 General information.....	46
6.2 Additional information	47
6.3 Rating test results	47

Annex A (normative) Calorimeter test method	48
A.1 General	48
A.2 Transient heating capacity test	51
A.3 Calibrated room-type calorimeter	51
A.4 Balanced ambient room-type calorimeter	52
A.5 Calorimeter and auxiliary equipment for water-cooled condenser tests.....	52
A.6 Calculations-cooling capacities	52
A.7 Calculations- heating capacities.....	54
A.7.1 General	54
Annex B (normative) Indoor air enthalpy test method	57
B.1 General	57
B.2 Test conditions	57
B.3 Application.....	57
B.4 Calculations-cooling capacities	57
B.5 Calculations-heating capacities.....	58
Annex C (normative) Symbols and units used in Annex A and B	59
Annex D (normative) Water enthalpy test method	61
D.1 General	61
D.2 Calculations.....	61
D.2.1 Measured cooling capacity.....	61
D.2.2 Measured heating capacity.....	61
D.2.3 Measured engine heat recovery capacity.....	62
Annex E (normative) Direct method for air-to-water (brine) and water (brine)-to-water (brine) appliances	63
E.1 General	63
E.2 Compensation system for air-to-water (brine) appliances.....	63
E.3 Compensation system for water(brine) to water (brine) appliances	64
Annex F (informative) Measurement control criteria for water (brine) to water (brine) appliances.....	65
F.1 General	65
F.2 Water (brine)-to-water (brine) heat pump in heating mode	65
F.3 Water (brine)-to-water (brine) chiller or chiller/heater in cooling mode	66
Annex G (normative) Determination of the pump efficiency.....	68
G.1 General	68
G.2 Hydraulic power of the pump	68
G.2.1 The pump is an integral part of the appliance	68
G.2.2 The pump is not an integral part of the appliance.....	68
G.3 Efficiency of the pump.....	69
Annex H (informative) Calculation procedure for determination of GUE, AEF and Cd values	71
H.1 Calculation procedure for determination of GUE values at part load (GUEPL).....	71
H.1.1 General	71
H.1.2 For air-to-air, brine-to-air and water-to-air units.....	71
H.1.3 For air-to-water, water-to-water and brine-to-water units.....	72
H.2 Calculation procedure for determination of AEF values at part load (AEFPL).....	72
H.2.1 General	72
H.2.2 For air-to-air, brine-to-air and water-to-air units.....	73
H.2.3 For air-to-water, water-to-water and brine-to-water units.....	73
H.3 Air-to-air and water-to-air units - Determination of the degradation coefficient Cd	74
H.3.1 General	74
H.3.2 Air-to-air units – Cooling mode.....	75

H.3.3	Air-to-air units – Heating mode	75
H.3.4	Water-to-air units – Cooling mode	75
H.3.5	Water-to-air units – Heating mode	75
H.4	Air-to-water units and water-to-water units - Determination of the degradation coefficient Cc	75
Annex I (informative)	“Individual” correction to include in the “global” electrical power input correction depending on the GEHP appliance	76
Annex J (informative)	Heating capacity tests - Flow chart and examples of different test sequences	83
J.1	Flow chart	83
J.2	Examples of test profiles	84
Annex K (informative)	Rating of indoor and outdoor units of multisplit and modular heat recovery multisplit system	89
K.1	General	89
K.2	Terms and definitions	89
K.3	Rating in indoor units	89
K.3.1	General	89
K.3.2	Air flow rate measurement	90
K.3.3	Measurement of the power input of indoor units	90
K.4	Rating of outdoor units	90
K.4.1	General	90
K.4.2	Test conditions	90
K.4.3	Test procedure	90
Annex L (informative)	Air flow measurement	91
L.1	General	91
L.2	Test installation	91
L.3	Test conditions	91
L.4	Air flow measurement	91
Annex ZA (informative)	Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 813/2013 aimed to be covered	92
Annex ZB (informative)	Relationship between this European Standard and the energy labelling requirements of Commission Delegated Regulation (EU) No 811/2013 aimed to be covered	93
Bibliography	95

European foreword

This document (EN 16905-4:2017) has been prepared by Technical Committee CEN/TC 299 “Gas-fired sorption appliances, indirect fired sorption appliances, gas-fired endothermic engine heat pumps and domestic gas-fired washing and drying appliances”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2017, and conflicting national standards shall be withdrawn at the latest by September 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA and Annex ZB, which is an integral part of this document.

This standard comprises the following parts under the general title, *Gas-fired endothermic engine driven heat pumps*:

- *Part 1: Terms and definitions;*
- *Part 2: Safety* (WI 00299025; currently in preparation);
- *Part 3: Test conditions;*
- *Part 4: Test methods;*
- *Part 5: Calculation of seasonal performances in heating and cooling mode.*

EN 16905-1, prEN 16905-2, EN 16905-3, EN 16905-4 and EN 16905-5 have been prepared to address the essential requirements of the European Directive 2009/142/EC relating to appliances burning gaseous fuels (see prEN 16905-2:201X, Annex ZA for safety aspects and EN 16905-5:2017, Annex ZA for rational use of energy aspects).

These documents are linked to the Energy Related Products Directive (2009/125/EC) in terms of tests conditions, tests methods and seasonal performances calculation methods under Mandate M/535; (see EN 16905-3:2017, Annex ZA, EN 16905-4:2017, Annex ZA, EN 16905-5:2017, Annex ZA and prEN 16905-2:201X, Annex ZB).

These documents will be reviewed whenever new mandates could apply.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

1.1 Scope of EN 16905 series

This European Standard specifies the requirements, test methods and test conditions for the rating and performance calculation of air conditioners and heat pumps using either air, water or brine as heat transfer media, with gas-fired endothermic engine driven compressors when used for space heating, cooling and refrigeration, hereafter referred to as “GEHP appliance”.

This European Standard only applies to appliances with a maximum heat input (based on net calorific value) not exceeding 70 kW at standard rating conditions.

This European Standard only applies to appliances under categories I_{2H} , I_{2E} , I_{2Er} , I_{2R} , $I_{2E(S)B}$, I_{2L} , I_{2LL} , I_{2ELL} , $I_{2E(R)B}$, I_{2ESi} , $I_{2E(R)}$, I_{3P} , I_{3B} , $I_{3B/P}$, II_{2H3+} , II_{2Er3+} , $II_{2H3B/P}$, $II_{2L3B/P}$, $II_{2E3B/P}$, $II_{2ELL3B/P}$, II_{2L3P} , II_{2H3P} , II_{2E3P} and II_{2Er3P} according to EN 437.

This European Standard only applies to appliances having:

- a) gas fired endothermic engines under the control of fully automatic control systems;
- b) closed system refrigerant circuits in which the refrigerant does not come into direct contact with the fluid to be cooled or heated;
- c) where the temperature of the heat transfer fluid of the heating system (heating water circuit) does not exceed 105 °C during normal operation;
- d) where the maximum operating pressure in the:
 - 1) heating water circuit (if installed) does not exceed 6 bar;
 - 2) domestic hot water circuit (if installed) does not exceed 10 bar.

This European Standard applies to appliances only when used for space heating or space cooling or for refrigeration, with or without heat recovery.

The appliances having their condenser cooled by air and by the evaporation of external additional water are not covered by this European Standard.

Packaged units, single split and multisplit systems are covered by this European Standard. Single duct and double duct units are covered by this European Standard.

The above appliances can have one or more primary or secondary functions.

This European Standard is applicable to appliances that are intended to be type tested. Requirements for appliances that are not type tested would need to be subject to further consideration.

In the case of packaged units (consisting of several parts), this European Standard applies only to those designed and supplied as a complete package.

NOTE All the symbols given in this text are used regardless of the language used.

1.2 Scope of EN 16905-4

This part of the EN 16905 series specifies the test methods for gas-fired endothermic engine driven heat pumps for heating and/or cooling mode including the engine heat recovery.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 437, *Test gases — Test pressures — Appliance categories*

EN 12102, *Air conditioners, liquid chilling packages, heat pumps and dehumidifiers with electrically driven compressors for space heating and cooling - Measurement of airborne noise - Determination of the sound power level*

EN 16905-1, *Gas-fired endothermic engine driven heat pumps — Part 1: Terms and definitions*

prEN 16905-2¹⁾, *Gas-fired endothermic engine driven heat pumps — Part 2: Safety*

EN 16905-3:2017, *Gas-fired endothermic engine driven heat pumps — Part 3: Test conditions*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 16905-1 apply.

4 Test methods

4.1 General

A steady-state or transient or cyclical operation test could be applied for 100 % load tests or for reduced load tests.

The sound power level is measured in the standard rating conditions as given in EN 16905-3 with the corresponding test methods according to EN 12102 considering that this standard, dedicated to determination of the sound power level could be used with appliances covered in the scope of the EN 16905 series.

4.2 Basic principles method of calculation for the determination of capacities

4.2.1 Capacity

4.2.1.1 Measured capacity

The measured heating or cooling capacity of air-to-air or water (brine)-to-air GEHP shall be determined by measurements in a calorimeter room (see Annex A) or by the air enthalpy method (see Annex B).

The measured heating or cooling capacity of air-to-water (brine) or water (brine)-to-water (brine) GEHP shall be determined in accordance with the water enthalpy method (see Annex D).

The measured heat recovery capacity of all GEHP shall be determined in accordance with the water enthalpy method (see Annex D).

1) Currently in preparation.