

Sanitary tapware - Automatic shut-off valves PN 10

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 816:2017 sisaldab Euroopa standardi EN 816:2017 ingliskeelset teksti.	This Estonian standard EVS-EN 816:2017 consists of the English text of the European standard EN 816:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 16.08.2017.	Date of Availability of the European standard is 16.08.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.060.01, 91.140.70

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Sanitary tapware - Automatic shut-off valves PN 10

Robinetterie sanitaire - Robinets à fermeture
automatique PN 10

Sanitärarmaturen - Selbstschlussarmaturen PN 10

This European Standard was approved by CEN on 24 April 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword	4
Introduction	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	7
4 Designation	7
5 Marking - Identification.....	7
5.1 Marking	7
5.2 Identification	8
6 Materials	8
6.1 Chemical and hygienic characteristics.....	8
6.2 Exposed surface condition and quality of coating	8
7 Backflow protection.....	8
8 Dimensional characteristics	8
8.1 General.....	8
8.2 Tap with visible body for horizontal surfaces (see Figure 1 and Table 3).....	9
8.3 Taps with visible body for mounting on vertical surfaces (see Figure 2 and Table 4).....	10
8.4 In-line tapware with threaded inlet and outlet	10
8.4.1 Inlets and outlets aligned (see Figure 3 and Table 5).....	10
8.4.2 Inlets and outlets at right angles (see Figure 4 and Table 5).....	11
8.5 Concealed tapware for vertical surfaces	11
8.6 Mixer for horizontal surface (see Figures 5, 6 and 7 and Table 6)	12
8.7 Mixer with visible body for mounting on vertical surfaces.....	16
8.7.1 Mixers with parallel inlets.....	16
8.7.2 Mixer with opposed inlets (see Figure 11 and Table 5).....	18
8.8 Nozzle outlets for use with flow rate regulators	18
8.9 Special cases	18
8.9.1 Special taps and mixers for installation on horizontal surfaces.....	18
8.9.2 Special taps and mixers for installation on vertical surfaces	19
9 Leaktightness characteristics.....	19
9.1 General.....	19
9.2 Leaktightness tests.....	19
9.2.1 Principle	19
9.2.2 Apparatus	19
9.2.3 Leaktightness of tapware upstream of the obturator	19
9.2.4 Leaktightness of tapware downstream of the obturator with the obturator open	20
9.3 Summary of the leaktightness tests	21
10 Pressure resistance characteristics	22
10.1 General.....	22
10.2 Test of mechanical behaviour	22
10.2.1 Principle	22
10.2.2 Apparatus	22

10.2.3	Test of the mechanical behaviour upstream of the obturator, with the obturator in the closed position	22
10.2.4	Test of mechanical behaviour downstream of the obturator, with the obturator in the open position	22
10.3	Summary of the pressure tests	23
11	Hydraulic characteristics.....	23
11.1	General	23
11.2	Test method.....	23
11.2.1	Principle.....	23
11.2.2	Test apparatus	23
11.2.3	Mounting of single self-closing taps.....	26
11.2.4	Mounting of mixers (see Figures 14 a), 14 b) and 14 c)).....	26
11.3	Principle of the flow test	27
11.4	Requirements.....	28
11.4.1	Flow rate	28
11.4.2	Flow rate curve	28
11.4.3	Flow duration.....	28
11.4.4	Specific characteristics of mixers	29
11.4.5	Testing at minimum pressure.....	31
12	Mechanical properties - Operating force	31
12.1	General	31
12.2	Procedure	31
12.3	Requirement.....	31
13	Mechanical endurance or wear resistance characteristics	31
13.1	General	31
13.2	Procedure	31
13.3	Cycle for a single tap	32
13.4	Cycle for a mixer.....	32
13.5	Minimum requirements	32
14	Acoustic characteristics	33
14.1	General	33
14.2	Procedure	33
14.2.1	Fitting and operating conditions for tapware	33
14.2.2	Test method.....	33
14.3	Requirements.....	33
14.3.1	Expression of the results.....	33
14.3.2	Determination of the acoustic group.....	33
14.3.3	Flow class.....	34
Annex A	(normative) Pressure take off tees	35
Annex B	(informative) Acoustic classification (example).....	37
B.1	Tapware with nozzle	37
B.2	Tapware with shower head outlet.....	37
B.3	Tapware with nozzle and shower or shower head outlet.....	37

European foreword

This document (EN 816:2017) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2018, and conflicting national standards shall be withdrawn at the latest by February 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 816:1996.

The main changes compares to the previous edition are:

- 1) water saving criteria were introduced;
- 2) the entire structure of the standard was revised;
- 3) normative references have been updated;
- 4) editorial changes and have been made throughout the entire document;
- 5) figures were redrawn.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this standard:

- 1) this standard provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- 2) it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

1 Scope

This European Standard is applicable to single and mixer taps with automatic shut-off for use with sanitary appliances installed in washrooms.

It does not apply to urinal or WC flushing valves or valves which open automatically.

The purpose of this standard is to specify the marking, identification, chemical/hygiene, dimensional, leaktightness, pressure resistance, hydraulic, mechanical endurance, and acoustical characteristics of automatic shut-off tapware.

The tests described in all the standard are type tests (laboratory tests) and not quality control tests carried out during manufacture

The conditions of pressure and temperature given in Table 1 apply:

Table 1 — Conditions for the use of self-closing tapware

(The pressures given are flow pressures)

	Limits of use	Recommended limits of operation
Dynamic pressure	0,05 MPa (0,5 bar) min.	$0,1 \text{ MPa} \leq P \leq 0,5 \text{ Mpa}$ ($1 \text{ bar} \leq P \leq 5 \text{ bar}$)
Static pressure	1 MPa (10 bar) max	–
Hot water temperature	Max $\leq 90 \text{ }^{\circ}\text{C}$	$55 \text{ }^{\circ}\text{C} \leq T \leq 65 \text{ }^{\circ}\text{C}$
Cold water temperature	–	$T \leq 25 \text{ }^{\circ}\text{C}$

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 246, *Sanitary tapware - General specifications for flow rate regulators*

EN 248, *Sanitary tapware - General specification for electrodeposited coatings of Ni-Cr*

EN 1717, *Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow*

EN 13618, *Flexible hose assemblies in drinking water installations - Functional requirements and test methods*

EN 13959, *Anti-pollution check valves - DN 6 to DN 250 inclusive family E, type A, B, C and D*

EN ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads - Part 1: Dimensions, tolerances and designation (ISO 228-1)*

EN ISO 3822-1, *Acoustics - Laboratory tests on noise emission from appliances and equipment used in water supply installations - Part 1: Method of measurement (ISO 3822-1)*

EN ISO 3822-2, *Acoustics - Laboratory tests on noise emission from appliances and equipment used in water supply installations - Part 2: Mounting and operating conditions for draw-off taps and mixing valves (ISO 3822-2)*

EN ISO 3822-4:1997, *Acoustics - Laboratory tests on noise emission from appliances and equipment used in water supply installations - Part 4: Mounting and operating conditions for special appliances (ISO 3822-4:1997)*

EN ISO 5167 (all parts), *Measurement of fluid flow by means of orifice plates, nozzles and venturi tubes inserted in circular cross section conduits running full (ISO 5167)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

automatic shut-off tapware

tapware in which opening is effected by operation of a device following which shut-off occurs automatically mechanical after a certain period or volume

Note 1 to entry: This period and /or volume may be adjustable by the manufacturer or installer.

4 Designation

An automatic shut-off tapware is designated according to Table 2:

Table 2 — Designation

Tapware	
Type of valve	Mechanical self-closing tap
Intended use	Basin, sink or shower
Nominal size	1/2, 3/4; male or female
Body	Single or multi-hole; visible, or concealed
Mounting method	Horizontal or vertical surfaces
Type of outlet	Fixed, moveable, spout, with or without flow rate regulator
Acoustic group and classification	Group I, or group II, or unclassified
Water saving properties	Yes / no
Flow rate class	Z, A, S, B, C, D
Reference to this European Standard	EN 816

EXAMPLE Mechanical self-closing basin tap 1/2 ", single visible body, horizontal surface, fixed nozzle outlet, group I, class A EN 816.

5 Marking - Identification

5.1 Marking

Tapware complying with this standard shall be permanently and indelibly marked on the body with the manufacturer's name or identification mark, and if applicable, the acoustic group and flow rate class.