

ÕHUKONDITIONEERID, VEDELIKJAHUTUSSEADMED JA
SOOJUSPUMBAD RUUMIDE KÜTTEKS JA JAHUTUSEKS
NING PROTSESSI JAHUTID ELEKTRIKOMPRESSORITEGA.
OSA 3: KATSEMEETODID

Air conditioners, liquid chilling packages and heat
pumps for space heating and cooling and process
chillers, with electrically driven compressors - Part 3:
Test methods

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 14511-3:2018 sisaldab Euroopa standardi EN 14511-3:2018 ingliskeelset teksti.	This Estonian standard EVS-EN 14511-3:2018 consists of the English text of the European standard EN 14511-3:2018.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 14.03.2018.	Date of Availability of the European standard is 14.03.2018.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 27.080, 91.140.30

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 14511-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2018

ICS 27.080; 91.140.30

Supersedes EN 14511-3:2013

English Version

Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 3: Test methods

Climatiseurs, groupes refroidisseurs de liquide et pompes à chaleur pour le chauffage et le refroidissement des locaux et refroidisseurs industriels avec compresseur entraîné par moteur électrique -
Partie 3: Méthodes d'essai

Luftkonditionierer, Flüssigkeitskühlsätze und Wärmepumpen für die Raumbeheizung und -kühlung und Prozess-Kühler mit elektrisch angetriebenen Verdichtern - Teil 3: Prüfverfahren

This European Standard was approved by CEN on 31 December 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	5
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 Tests for determination of capacities	7
4.1 Basic principles, method of calculation for the determination of capacities	7
4.1.1 Heating capacity	7
4.1.2 Cooling capacity	8
4.1.3 Heat recovery capacity	9
4.1.4 Capacity correction	9
4.1.5 Effective power input	12
4.1.6 Units on a distribution network of pressured water	13
4.1.7 Units for use with remote condenser	13
4.2 Test apparatus	14
4.2.1 Arrangement of the test apparatus	14
4.2.2 Installation and connection of the test object	14
4.3 Uncertainties of measurement	16
4.4 Test procedure	18
4.4.1 Settings	18
4.4.2 Output measurement for water (brine)-to-water (brine) and water (brine)-to-air units	20
4.4.3 Output measurement for cooling capacity of air-to-water (brine) and air-to-air units	21
4.4.4 Output measurement for heating capacity of air-to-air and air-to-water units	21
4.5 Test results	26
4.5.1 Data to be recorded	26
4.5.2 Cooling capacity and heat recovery capacity calculation	29
4.5.3 Heating capacity calculation	29
4.5.4 Effective power input calculation	30
5 Electrical consumptions for single duct and double duct units	30
5.1 Determination of power consumption due to standby mode	30
5.2 Determination of power consumption in off-mode	31
5.3 Electricity consumption	31
6 Air flow rate measurement of ducted units	31
7 Heat recovery test for air-cooled multisplit system	31
7.1 Test installation	31
7.1.1 General	31
7.1.2 Three-room calorimeter method	32
7.1.3 Three-room air-enthalpy method	32
7.1.4 Two-room air-enthalpy method	32
7.2 Test procedure	32
7.3 Test results	32
8 Test report	32
8.1 General information	32
8.2 Additional information	33

8.3	Rating test results	33
	Annex A (normative) Calorimeter test method	34
A.1	General	34
A.2	Calibrated room-type calorimeter	36
A.3	Balanced ambient room-type calorimeter	37
A.4	Calculations-cooling capacities	37
A.4.1	General	37
A.4.2	Total cooling capacity on the indoor-side	38
A.4.3	Total cooling capacity of liquid (water)-cooled equipment deducted from the condenser side	39
A.4.4	Latent cooling capacity (room dehumidifying capacity)	39
A.4.5	Sensible cooling capacity	39
A.4.6	Sensible heat ratio	39
A.5	Calculation-heating capacities	40
A.5.1	General	40
A.5.2	Determination of the heating capacity by measurements in the indoor-side room	40
A.5.3	Determination of the heating capacity by measurements in the outdoor-side room	40
A.5.4	Total heating capacity of liquid (water)-to-air unit deducted from the water side	41
	Annex B (normative) Indoor air enthalpy test method	42
B.1	General	42
B.2	Determination of the air flow rate	42
B.3	Calculations-cooling capacities	42
B.4	Calculations-heating capacities	43
	Annex C (informative) Conformance criteria	44
C.1	Liquid chilling packages	44
C.2	Calorimeter room method	44
C.3	Heat recovery of multisplit systems	44
	Annex D (informative) Symbols used in annexes	45
	Annex E (informative) Test at system reduced capacity	47
E.1	Test at system reduced capacity for multisplit system and modular heat recovery multisplit system	47
E.2	Selection of units	47
E.3	Test results	47
	Annex F (informative) Individual unit tests	48
F.1	General	48
F.1.1	Methods	48
F.1.2	Calorimeter method	48

F.1.3	Air-enthalpy method	48
F.2	Test results	48
F.3	Published results	48
	Annex G (normative) Determination of the liquid pump efficiency	49
G.1	General	49
G.2	Hydraulic power of the liquid pump	49
G.2.1	The liquid pump is an integral part of the unit	49
G.2.2	The liquid pump is not an integral part of the unit	49
G.3	Efficiency of integrated pumps	49
G.3.1	Glandless circulators	49
G.3.2	Dry motor pumps	50
G.4	Efficiency of non-integrated pumps	51
	Annex H (informative) Rating of indoor and outdoor units of multisplit and modular heat recovery multisplit systems	52
H.1	General	52
H.2	Terms and definitions	52
H.3	Rating of indoor units	53
H.3.1	General	53
H.3.2	Air flow rate measurement	53
H.3.3	Measurement of the power input of indoor units	53
H.4	Rating of outdoor units	53
H.4.1	General	53
H.4.2	Test procedure	53
	Annex I (normative) Air flow rate measurement	54
I.1	General	54
I.2	Test installation	54
I.3	Test conditions	54
I.4	Air flow measurement	54
	Annex ZA (informative) Relationship between this European Standard and the requirements of Commission regulation (EC) No 206/2012 aimed to be covered	55
	Annex ZB (informative) Relationship between this European Standard and the energy labelling requirements of Commission Delegated Regulation (EU) No 626/2011 aimed to be covered	56
	Bibliography	58

European foreword

This document (EN 14511-3:2018) has been prepared by Technical Committee CEN/TC 113 “Heat pumps and air conditioning units”, the secretariat of which is held by UNE.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2018, and conflicting national standards shall be withdrawn at the latest by March 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14511-3:2013.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Regulation No 206/2012 and EU Regulation No 626/2011.

For relationship with EU Regulation No 206/2012 and EU Regulation No 626/2011, see informative Annexes ZA and ZB, which are an integral part of this document.

The main changes with respect to the previous edition are listed below:

- a) the revision of Annexes A and B on the test methods;
- b) deletion of Annex C;
- c) the revision of Annex G (Annex H on the previous version) on liquid pumps corrections;
- d) the inclusion of process chillers into the scope of the EN 14511 series and of this Part 3.

Although this document has been prepared in the frame of the Commission Regulation (EU) No 206/2012 implementing Directive 2009/125/EC with regard to ecodesign requirements for air conditioners and comfort fans, it is also intended to support the Essential Requirements of the European Directive 2010/30/EU.

EN 14511 currently comprises the following parts:

- *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers with electrically driven compressors — Part 1: Terms and definitions,*
- *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 2: Test conditions,*
- *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 3: Test methods,*
- *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 4: Requirements.*

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria,

Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This document is a preview generated by EVS

1 Scope

1.1 The scope of EN 14511-1 is applicable.

1.2 This European Standard specifies the test methods for the rating and performance of air conditioners, liquid chilling packages and heat pumps using either air, water or brine as heat transfer media, with electrically driven compressors when used for space heating and cooling. These test methods also apply for the rating and performance of process chillers.

It also specifies the method of testing and reporting for heat recovery capacities, system reduced capacities and the capacity of individual indoor units of multisplit systems, where applicable.

This European Standard also makes possible to rate multisplit and modular heat recovery multisplit systems by rating separately the indoor and outdoor units.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14511-1:2018, *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 1: Terms and definitions*

EN 14511-2:2018, *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 2: Test conditions*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 14511-1:2018 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Tests for determination of capacities

4.1 Basic principles, method of calculation for the determination of capacities

4.1.1 Heating capacity

The heating capacity of air conditioners and of air-to-air or water(brine)-to-air heat pumps shall be determined by measurements in a calorimeter room (see Annex A) or by the air enthalpy method (see Annex B).

However, the heating capacity of air conditioners and of air-to-air heat pumps having a capacity below or equal to 12 kW for cooling, or heating if the unit has no cooling function, under the standard rating conditions of EN 14511-2 shall be determined by measurements in a calorimeter room.

For heating only units the limit of 12 kW applies to the heating capacity as given under the standard rating conditions of EN 14511-2.