
**Respiratory protective devices —
Methods of test and test equipment —**

**Part 14:
Measurement of sound level**

*Appareils de protection respiratoire — Méthodes d'essai et
équipement d'essai —*

Partie 14: Mesurage du niveau sonore



This document is a preview generated by EBS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword.....	iv
Introduction.....	vi
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	1
4 Prerequisites.....	1
5 General test requirements.....	2
6 Method A — Measurement of the noise level.....	2
6.1 Principle.....	2
6.2 Equipment.....	2
6.3 Procedure.....	2
6.4 Test report for method A.....	3
7 Method B — Measurement of warning sound level.....	3
7.1 Principle.....	3
7.2 Equipment.....	4
7.3 Procedure.....	4
7.4 Test report for method B.....	4
Annex A (normative) Application of uncertainty of measurement.....	5
Bibliography.....	7

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#).

The committee responsible for this document is ISO/TC 94, *Personal safety — Protective clothing and equipment*, Subcommittee SC 15, *Respiratory protective devices*.

ISO 16900 consists of the following parts, under the general title *Respiratory protective devices — Methods of test and test equipment*:

- *Part 1: Determination of inward leakage*
- *Part 2: Determination of breathing resistance*
- *Part 3: Determination of particle filter penetration*
- *Part 4: Determination of gas filter capacity and migration, desorption and carbon monoxide dynamic testing*
- *Part 5: Breathing machine, metabolic simulator, RPD headforms and torso, tools and verification tools*
- *Part 6: Mechanical resistance/strength of components and connections*
- *Part 7: Practical performance tests methods*
- *Part 8: Measurement of RPD air flow rates of assisted filtering RPD*
- *Part 9: Determination of carbon dioxide content of the inhaled air*
- *Part 10: Resistance to ignition, flame, radiant heat and heat*
- *Part 11: Determination of field of vision*
- *Part 12: Determination of volume-averaged work of breathing and peak respiratory pressures*
- *Part 13: RPD using regenerated breathable gas and special application mining escape RPD: Consolidated test for gas concentration, temperature, humidity, work of breathing, breathing resistance, elastance and duration*

— *Part 14: Measurement of sound level*

This document is a preview generated by EVS

Introduction

This part of ISO 16900 is intended as a supplement to the respiratory protective devices (RPD) performance standards. Test methods are specified for complete devices or parts of devices. If deviations from the test method given in this part of ISO 16900 are necessary, these deviations will be specified in the performance standards.

The following definitions apply in understanding how to implement an ISO International Standard and other normative ISO deliverables (TS, PAS, IWA):

- “shall” indicates a requirement;
- “should” indicates a recommendation;
- “may” is used to indicate that something is permitted;
- “can” is used to indicate that something is possible, for example, that an organization or individual is able to do something.

3.3.1 of the ISO/IEC Directives, Part 2 (sixth edition, 2011) defines a requirement as an “expression in the content of a document conveying criteria to be fulfilled if compliance with the document is to be claimed and from which no deviation is permitted.”

3.3.2 of the ISO/IEC Directives, Part 2 (sixth edition, 2011) defines a recommendation as an “expression in the content of a document conveying that among several possibilities one is recommended as particularly suitable, without mentioning or excluding others, or that a certain course of action is preferred but not necessarily required, or that (in the negative form) a certain possibility or course of action is deprecated but not prohibited.”

Respiratory protective devices — Methods of test and test equipment —

Part 14: Measurement of sound level

1 Scope

This part of ISO 16900 specifies a laboratory test method for determining the sound level generated by the complete respiratory protective device (RPD) and RPD warning sounds measured on a headform to which the RPD is fitted.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 16972, *Respiratory protective devices — Terms, definitions, graphical symbols and units of measurement*

IEC 61260-1, *Octave-band and fractional-octave-band filters — Part 1: Specifications*

IEC 61672-1, *Electroacoustics — Sound level meters — Part 1: Specifications*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16972 apply.

3.1

A-weighted equivalent continuous sound pressure level

$L_{p,A,eqT}$

10 times the logarithm to the base 10 of the ratio of the time average of the square of the A-weighted sound pressure, p_A , during a stated time interval of duration T (starting at t_1 and ending at t_2) to the square of the reference value, p_0 , expressed in decibels

$$\text{Note 1 to entry: } L_{p,A,eqT} = 10 \lg \left[\frac{\frac{1}{T} \int_{t_2}^{t_1} p_A^2(t) dt}{p_0^2} \right] \text{ dB, where the reference value, } p_0, \text{ is } 20 \mu\text{Pa.}$$

[SOURCE: ISO 9612:2009 [1], 3.1 modified]

4 Prerequisites

In order to implement this part of ISO 16900, at least the following parameters need to be specified in the relevant device standard:

- the number of RPD specimens;
- any prior conditioning or testing;
- the RPD operating conditions;