

ICS 13.220.20

English Version

**Fixed firefighting systems - Water spray systems - Design,
installation and maintenance**

Installations fixes de lutte contre l'incendie - Systèmes
d'extinction à pulvérisation d'eau - Conception, installation
et maintenance

Ortsfeste Brandbekämpfungsanlagen -
Sprühwasserlöschanlagen - Planung, Einbau und Wartung

This Technical Specification (CEN/TS) was approved by CEN on 9 September 2008 for provisional application.

The period of validity of this CEN/TS is limited initially to three years. After two years the members of CEN will be requested to submit their comments, particularly on the question whether the CEN/TS can be converted into a European Standard.

CEN members are required to announce the existence of this CEN/TS in the same way as for an EN and to make the CEN/TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force (in parallel to the CEN/TS) until the final decision about the possible conversion of the CEN/TS into an EN is reached.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Operating condition of water spray systems	7
4.1 Operation in the open air	7
4.2 Fire resisting compartments	7
4.3 Protection against frost	8
5 Fire hazards and system design	8
5.1 General	8
5.2 Protection of various hazards	8
5.3 Protection of flammable liquids with medium and high velocity water spray systems	12
5.4 Spray systems with additives for the protection of flammable liquids	17
6 Simultaneous operation of water spray installations	17
6.1 Deluge installations	17
6.2 Multiple control installations	18
7 Special considerations for water spray systems	18
7.1 General	18
7.2 Suitability of water sources	19
7.3 Choice of water supply	19
7.4 Water volume	19
7.5 Valves	19
7.6 Pipe work	20
7.7 Alarms and alarm devices	20
7.8 Commissioning test	20
8 System activation	21
8.1 General	21
8.2 Electrical detection systems	21
8.3 Pneumatic or hydraulic activation	21
8.4 Manual release	21
8.5 Multiple controls	21
9 Sprayer design characteristics and uses	21
9.1 General	21
9.2 Sprayer characteristics	22
9.3 Flow from sprayers	22
Annex A (informative) Exposure protection	23
A.1 General	23
A.2 System design and installation	23
Bibliography	29

Foreword

This document (CEN/TS 14816:2008) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

It is included in a series of European standards planned to cover:

- automatic sprinkler systems (EN 12259, EN 12845),
- gas extinguishing systems (EN 12094),
- powder systems (EN 12416),
- explosion protection systems (EN 26184),
- foam systems (EN 13565),
- hydrant and hose reel systems (EN 671),
- smoke and heat control systems (EN 12101).

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to announce this Technical Specification: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Introduction

Water spray systems can be suitable, in some instances, for extinguishment of fire and in others for prevention of fire spread, and may be independent of or supplementary to other forms of fire protection.

A water spray system consists of a water supply (or supplies) and one or more sprayers usually open; each system consists of a control valve set and a pipe array fitted with sprayers.

The design of specific systems may vary considerably, depending on the nature of the hazard and the basic purposes of protection. Because of these variations and the wide choice in the characteristics of sprayers, it is assumed that these systems are competently designed, installed and maintained. It is essential that their limitations as well as their capabilities be thoroughly understood by the designer.

It should not be assumed that the provision of a water spray system entirely obviates the need for other means of fighting fires and it is important to consider the fire precautions in the premises as a whole. Special measurement may also be required, for example bounding flammable liquid risks or the protection drain of flammable liquids spillage.

Structural fire resistance, escape routes, fire alarm systems, particular hazards needing other fire protection methods, provision of hose reels, fire hydrants and fire extinguishers, etc., safe working and goods handling methods, management supervision and good housekeeping all need consideration.

It is essential that water spray systems should be properly maintained to ensure operation when required. This routine is liable to be overlooked or given insufficient attention by supervisors. It is, however, neglected at peril to the lives of occupants of the premises and at the risk of crippling financial loss. The importance of proper maintenance cannot be too highly emphasized.

When water spray systems are out of service, extra attention should be paid to fire precautions and the appropriate authorities informed.

This standard is intended for use by those concerned with purchasing, designing, installing, testing, inspecting, approving, operating and maintaining water spray systems, in order that such equipment will function as intended throughout its life.

It is a basic assumption that this standard is for the use of companies employing personnel competent in the field of application with which it deals. The design, installation and maintenance of water spray systems should be undertaken only by trained and experienced personnel. Similarly, competent technicians should be used in the installation and testing of the equipment.

1 Scope

This Technical Specification specifies requirements and gives recommendations for the design, installation and maintenance of fixed deluge water spray systems internal and external to buildings and industrial plant and other premises on land. This Technical Specification covers only the use of the types of sprinklers and sprayers specified in EN 12259-1. The requirements and recommendations of this Technical Specification are also applicable to any addition, extension, repair or other modification to a water spray system. This Technical Specification does not deal with sprinkler systems.

It covers the hazards, provision of water supplies, components to be used, installation and testing of the system, maintenance, and the extension of existing systems, and identifies construction details of buildings which are necessary for the satisfactory performance of water spray systems complying with this Technical Specification.

The general principles may well apply to other uses (e.g. maritime use), for these other uses additional considerations will almost certainly have to be taken into account.

For water spray systems covered by this Technical Specification the authority shall be consulted.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1, *Fire detection and fire alarm systems – Part 1: Introduction*

EN 54-2, *Fire detection and fire alarm systems – Part 2: Control and indicating equipment*

EN 54-3, *Fire detection and fire alarm systems – Part 3: Fire alarm devices – Sounders*

EN 54-4, *Fire detection and fire alarm systems – Part 4: Power supply equipment*

EN 54-5, *Fire detection and fire alarm systems – Part 5: Heat detectors – Point detectors*

EN 54-10, *Fire detection and fire alarm systems – Part 10: Flame detectors – Point detectors*

EN 54-11, *Fire detection and fire alarm systems – Part 11: Manual call points*

EN 12094 (all parts), *Fixed firefighting systems - Components for gas extinguishing systems*

EN 12259-1, *Fixed firefighting systems – Components for sprinkler and water spray systems – Part 1: Sprinklers*

EN 12259-2, *Fixed firefighting systems – Components for sprinkler and water spray systems – Part 2: Wet alarm valve assemblies*

EN 12259-3, *Fixed firefighting systems – Components for automatic sprinkler and water spray systems – Part 3: Dry alarm valve assemblies*

prEN 12259-9, *Fixed firefighting systems – Components for sprinkler and water spray systems – Part 9: Deluge valve assemblies*

EN 12845:2004, *Fixed firefighting systems – Automatic sprinkler systems – Design, installation and maintenance*