

English version

**Home and Building Electronic Systems (HBES) -
Open communication system -
Interfaces -
Medium interface, twisted pair, class 1**

Home and Building Electronic Systems
(HBES) -
Open communication system -
Interfaces -
Medium interface, twisted pair, class 1

This Technical Report was approved by CENELEC on 2010-05-01.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This Technical Report was prepared by the Technical Committee CENELEC TC 205, Home and Building Electronic Systems (HBES), joined by the co-operating partner KNX Association.

This document supersedes R205-010:1996.

It was circulated for voting in accordance with the Internal Regulations, Part 2, Subclause 11.4.3.3 (simple majority) and was approved by CENELEC as CLC/TR 50552 on 2010-05-01.

This Technical Report relates to the HBES system as described in the EN 50090 series under the generic title "*Home and Building Electronic Systems (HBES)*", which comprises the following parts:

- Part 1: Standardization structure
 - Part 2: System overview
 - Part 3: Aspects of application
 - Part 4: media independent layers
 - Part 5: Media and media dependent layers
 - Part 6: Interfaces
 - Part 7: System management
 - Part 8: Conformity assessment of products
 - Part 9: Installation requirements
-

This document is a preview generated by EVS

Contents

1	Scope	5
2	Normative references	5
3	Terms, definitions and abbreviations	6
3.1	Terms and definitions	6
3.2	Abbreviations	6
4	Medium interface realisation type 1	6
4.1	Introduction	6
4.2	Technical characteristics	6
5	Medium interface realisation type 2	9
5.1	Introduction	9
5.2	Technical characteristics	9
5.3	Constructional features of the data rail	11
5.4	Constructional features of data rail cover	12
5.5	Data rail to wire connector	12
6	Medium interface connector type 3	13
6.1	Introduction	13
6.2	Constructional features	14
7	Medium interface connector type 4	14
7.1	Introduction	14
7.2	Constructional features	16
8	Medium interface connector type 5	18
8.1	Introduction	18
8.2	Requirements	18
8.3	Pin assignment of connector type 5	20
9	HBES TP overvoltage protector (secondary protector)	20
9.1	General requirements	20
9.2	Requirements for communication	20
9.3	Electrical safety requirements	20
9.4	Environmental conditions	21
9.5	EMC	21
9.6	Mechanical, dimensions	21
9.7	Electrical requirements	22
9.8	Installation	22

Figures

Figure 1 - Realisation type 1 - Principal diagram	8
Figure 2 - Example of a realisation type 1 with constructional features	8
Figure 3 - Colour coding of cable connector.....	9
Figure 4 - Example of a realisation type 2 with constructional features	11
Figure 5 - Data rail and data rail cover	11
Figure 6 - Constructional Features	12
Figure 7 - Constructional Features of Connector Type 3 Male and Female	14
Figure 8 - Example of a connector type 4 male single phase	16
Figure 9 - Example of a connector type 4 female single phase	17
Figure 10 - Example of a connector type 4 male three phase.....	17
Figure 11 - Example of a connector type 4 male three phase.....	18
Figure 12 - Example of a HBES TP overvoltage protector.....	21
Figure 13 - Connecting the overvoltage protector directly on a bus coupling unit, replacing the connector by the overvoltage protector	22
Figure 14 - Connecting the overvoltage protector at the existing connector at the bus coupling unit ..	23

This document is a preview generated by EVS

Introduction

In R205-010:1996 was published documenting the medium interface solutions for Twisted pair implementations of the then existing European home and building electronic systems, more specifically Batibus and EIB.

In 1997 the convergence process between the Batibus, EIB and EHSA was initiated, which resulted in 2003 in the publication of the KNX standard and in the subsequent submission of this standard by the KNX Association as CENELEC cooperating partner to CLC/TC 205. This resulted in a positive UAP vote of this standard as part of the EN 50090 series by the European National Committees.

This version intends to bring the description of the HBES medium interface up to date with the current technical situation.

1 Scope

This Technical Report describes the current realisations of Twisted Pair 1 medium interface solutions.

TP1 signal forms are not described in this technical report as they already form part of EN 50090-5-2.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50090-1 1)	Home and Building Electronic Systems (HBES) - Part 1: Standardization structure
EN 50090-2-2	Home and Building Electronic Systems (HBES) - Part 2-2: System overview - General technical requirements
EN 50090-5-2	Home and Building Electronic Systems (HBES) - Part 5-2: Media and media dependent layers - Network based on HBES Class 1, Twisted Pair
EN 60998-2-1	Connecting devices for low-voltage circuits for household and similar purposes - Part 2-1: Particular requirements for connecting devices as separate entities with screw-type clamping units (IEC 60998-2-1)
EN 60998-2-2	Connecting devices for low-voltage circuits for household and similar purposes - Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units (IEC 60998-2-2)
EN 60715:2001	Dimensions of low-voltage switchgear and controlgear - Standardized mounting on rails for mechanical support of electrical devices in switchgear and controlgear installations (IEC 60715:1981 + A1:1995)
EN 60669-1	Switches for household and similar fixed-electrical installations - Part 1: General requirements (IEC 60669-1)
EN 60603-7:2009	Connectors for electronic equipment - Part 7: Detail specification for 8-way, unshielded, free and fixed connectors (IEC 60603-7:2008)
EN 60999 (Series)	Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units (IEC 60999 (Series))
EN 61535	Installation couplers intended for permanent connection in fixed installations (IEC 61535)

1) Under consideration.

EN 61643-21:2001

Low voltage surge protective devices - Part 21: Surge protective devices connected to telecommunications and signalling networks - Performance requirements and testing methods (IEC 61643-21:2000 + corr. Mar. 2001)

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 50090-1 apply.

3.2 Abbreviations

M M
O O

4 Medium interface realisation type 1

4.1 Introduction

This connector type is used to connect the TP1 cable to TP1 devices and/or to connect two TP1 cable parts.

4.2 Technical characteristics

No	Requirements	Type 1	M/O
1	Standard for screw-less connector standard for connector with screw	EN 60998-2-2 EN 60998-2-1	M
2	Number of contacts/ways	≥ 2	M
3	Bus interruption	Connector shall allow disconnecting device without interrupting bus	M
4	Non-interchangeable with other connectors	Compliant by design or color	M
5	Coding measure	Coding: see Male socket: Pin diameter: $(1 \pm 0,05)$ mm Pin length: 6...8 mm Cable: Core diameter: 0,8...1,0 mm (no mix of different diameters allowed at same time) Strip length: 5...6 mm Figure 2	O
6	Clamping unit/ terminals	Screw-less or with screw	M
7	Wire cross section, wire type	0,8 mm-1,00 mm dia solid (AWG Cu 20-18) 0,5 mm ² (AWG Cu 20) stranded	O
8	Nr. of wires connectable per pole with identical diameter	$\geq 3 \times 0,8$ mm dia (AWG Cu 20) or $\geq 3 \times 1,0$ mm (AWG Cu 18)	O
9	Test probe access	min. 1 mm x 1 mm – shall be accessible in mounted condition	O
10	Male contact pins	1 mm \varnothing ($\pm 0,05$ mm), 6 to 8 mm long - tin coated	O