

First edition
2009-08-01

**Fire-safety engineering — Technical
information on methods for evaluating
behaviour and movement of people**

*Ingénierie de la sécurité incendie — Informations techniques sur les
méthodes d'évaluation du comportement et du mouvement des
personnes*



Reference number
ISO/TR 16738:2009(E)

© ISO 2009

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

This document is a preview generated by EVS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2009

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	iv
Introduction.....	v
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	1
4 Symbols.....	3
5 Integration of behaviour and movement into performance-based design.....	4
5.1 General.....	4
5.2 Basis of performance-based design for life safety.....	4
5.3 ASET calculations.....	4
5.4 RSET calculations.....	5
5.5 Evacuation strategies.....	6
5.6 Margin of safety.....	6
5.7 Elements used in the quantification of RSET.....	6
6 Design behavioural scenarios for quantification of RSET.....	8
7 Estimation of pre-travel activity times.....	9
8 Estimation of travel times.....	9
9 Interactions between pre-travel activity time, walking time and exit flow time.....	10
10 Calculation of escape and evacuation times for single enclosures and for multi-storey or multi-enclosure buildings.....	11
11 Effects of fire effluent and heat on ASET and RSET.....	12
11.1 General.....	12
11.2 Simple criteria based upon zero exposure.....	13
11.3 Willingness to enter smoke.....	14
11.4 Ability to move through smoke.....	14
11.5 Effects of smoke on walking speed.....	14
11.6 Effects of visibility or exposure to fire and heat.....	14
11.7 Effects of exposure to toxic gases.....	15
Annex A (informative) Guidance on the evaluation of detection and warning times.....	16
Annex B (informative) Pre-travel activity behaviours and determinants.....	18
Annex C (informative) Detailed information needed for RSET calculations.....	20
Annex D (informative) Design behavioural scenarios for derivation of default RSET variables.....	23
Annex E (informative) Pre-travel activity time distribution data and derivations.....	30
Annex F (informative) Evacuation start time of the verification methods for safe evacuation in Japan.....	38
Annex G (informative) Guidance on travel speeds and flow rates.....	40
Annex H (informative) Examples of interactions between pre-travel activity and travel times.....	52
Annex I (informative) Effects of smoke on walking speed.....	55
Bibliography.....	57

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

In exceptional circumstances, when a technical committee has collected data of a different kind from that which is normally published as an International Standard ("state of the art", for example), it may decide by a simple majority vote of its participating members to publish a Technical Report. A Technical Report is entirely informative in nature and does not have to be reviewed until the data it provides are considered to be no longer valid or useful.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO/TR 16738 was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 4, *Fire safety engineering*.

Introduction

This Technical Report provides information (sometimes called “advice” or “guidance”, although there is no intention to present mandatory guidance) on engineering methods currently available for the evaluation of life-safety aspects of a fire-safety engineering design for the built environment, including structures such as tunnels, underground complexes, ships and vehicles. Advice is presented on the evaluation and management of occupant behaviour, particularly escape behaviour, during a fire emergency and for the evaluation of occupant condition and capabilities, particularly in relation to the effects of exposure to fire effluent and heat.

The guidance focuses mainly on the evacuation of the occupants, although maintenance in place or relocation to an area of refuge or safety can be appropriate alternatives in some situations. A basic principle of performance-based (fire safety engineering) design is that the available safe-escape time (ASET) is greater than the required safe-escape time (RSET) by an adequate margin of safety.

Should a fire occur in which occupants can be exposed to fire effluent and/or heat, the objective of the fire safety engineering strategy is usually to ensure that such exposure does not significantly impede or prevent the safe escape (if required) of all of the occupants, without their experiencing or developing serious health effects.

Possible objectives for a fire-safety design can include ensuring that those occupants outside the area of fire origin are able to reach (or remain in) an area of safety without ever coming into contact with, or even being aware of, fire effluent and/or heat, while those inside the enclosure of fire origin are not subjected to life-threatening conditions. These are proposed as the main design criteria for the safety of the majority of occupants in multi-compartment structures.

There are, inevitably, some potential scenarios when some occupants do become aware of, or are exposed to, fire or fire effluent, particularly when the occupants are in the enclosure of fire origin. This can vary between seeing flames or smoke or exposure to slight smoke contamination, common in many fires, to life-threatening exposures. For all scenarios, it is important to be able to assess the likely behavioural responses and the effects of such experiences, either as part of the main design or as part of a fire risk assessment.

In order to achieve these evaluations, detailed input information is required in four main areas:

- building design and emergency life safety management strategy;
- occupant characteristics;
- fire simulation dynamics;
- intervention effects.

The response of occupants to a fire condition is influenced by a whole range of variables in these four categories, related to the characterization of the occupants in terms of their number, distribution within the building at different times, their familiarity with the building, their abilities, behaviours and other attributes; the characterization of the building, including its use, layout and services; the provision for warnings, means of escape and emergency management strategy; and the interaction of all these features with the developing fire scenario and provisions for emergency intervention (fire brigade and rescue facilities).

Guidance is provided on

- a) the evaluation of escape and evacuation times from buildings:
 - for occupants not directly affected by fire (for example, in building locations remote from the fire compartment),

- for occupants whose escape behaviour and, therefore RSET, is influenced by fire effluents and heat;
- b) the evaluation of ASET in relation to tenability limits due to fire effluents and heat.

NOTE Reference can be made to ISO 13571 for details of calculation methods used for the evaluation of tenability in relation to exposure to fire effluent and heat.

The time required for escape depends upon a series of processes consisting of

- time from ignition to detection;
- time from detection to the provision of a general evacuation warning to occupants;
- evacuation time, which has two major phases:
 - pre-travel activity time, which consists of the time required to recognize the emergency and then carry out a range of activities before the evacuation travel phase,
 - travel time (the time required for occupants to travel to a safe location).

Time from ignition to detection and from ignition to alarm are covered in ISO/TR 13387-7. In terms of pre-travel activity time recognition and response times, most research (see References [1], [2], [3], [4], [5], [6], [7], [8] and also ISO/TR 13387-8) has been essentially qualitative, describing the psychological, behavioural and physiological factors affecting detection and recognition of fires and the wide range of behaviours engaged in by groups of occupants. There are few methods available for the quantification of these phenomena and the interactions between them, although some data on response time distributions have been obtained from observations of behaviour during real or simulated emergencies; see References [4], [5] and [9]. These studies have shown that the overall times required for these behaviours can comprise the greatest part of the time required for escape.

Travel to and through exits and escape routes involves more physically based processes, which have been relatively well quantified and are amenable to relatively simple calculation methods for design purposes; see References [10], [11], [12] and [13]. Nevertheless, travel times can be affected by behaviours such as way-finding and exit choice. Also, certain physical phenomena, such as merging flows, have not been adequately evaluated; see References [11] and [14].

There are considerable interactions between the various aspects of pre-travel activity time and travel times in the determination of total evacuation times for groups of building occupants. This has considerable implications for design performance evaluations; see References [6], [14], [15] and [16].

It is expected that users of this Technical Report are appropriately qualified and competent in the fields of fire-safety engineering and fire risk assessment. It is particularly important that users understand the parameters within which particular methodologies can be used. Users are cautioned that methods developed for, and assumptions based on observations from, building evacuations might not be directly applicable to different occupancies or to other built environments, such as tunnels or ships.

Fire-safety engineering — Technical information on methods for evaluating behaviour and movement of people

1 Scope

This Technical Report is intended to provide information to designers, regulators and fire safety professionals on the engineering methods available for evacuation strategies in relation to the evaluation of life safety aspects of a fire safety engineering design. Information is presented on the evaluation, quantification and management of occupant behaviour, particularly escape behaviour, during a fire emergency.

This Technical Report addresses the parameters that underlie the basic principles of designing for life safety and provides information on the processes, assessments and calculations necessary to determine the location and condition of the occupants of the building, with respect to time.

This Technical Report provides information on methods for the quantification of the different aspects of human evacuation behaviour in a design context. It is intended for use together with the parts of ISO/TR 13387 and associated guidance documents and standards. These provide some of the information useful in performing a life safety evaluation and a means for incorporating the results of the life safety evaluation into the wider aspects of a fire safety engineering design.

The use of lifts (elevators) in emergency evacuations is not dealt with in this Technical Report.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/TR 13387-8, *Fire safety engineering — Part 8: Life safety — Occupant behaviour, location and condition*

ISO 13943, *Fire safety — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO/TR 13387-8 and ISO 13943 and the following apply.

NOTE It has been necessary to produce a number of new terms to identify particular elements of behaviour useful in the quantification of escape and evacuation times.

3.1

design behavioural scenario

qualitative description of occupant characteristics, the built environment and systems, and fire dynamics, identifying key aspects affecting escape behaviours and escape time

3.2

escape route

path forming that part of the means of escape from any point in a building to a final exit or other safe location