

Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Polypropylene (PP) - Part 1: Specifications for pipes, fittings and the system

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 1451-1:2017 sisaldab Euroopa standardi EN 1451-1:2017 ja selle paranduse EN 1451-1:2017/AC:2018 ingliskeelset teksti.	This Estonian standard EVS-EN 1451-1:2017 consists of the English text of the European standard EN 1451-1:2017 and its corrigendum EN 1451-1:2017/AC:2018.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 15.11.2017.	Date of Availability of the European standard is 15.11.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.040.01, 91.140.80

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 1451-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2017

ICS 23.040.01; 91.140.80

Supersedes EN 1451-1:1998

English Version

Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Polypropylene (PP) - Part 1: Specifications for pipes, fittings and the system

Systèmes de canalisations en plastiques pour l'évacuation des eaux-vannes et des eaux usées (à basse et à haute température) à l'intérieur de la structure des bâtiments - Polypropylène (PP) - Partie 1: Spécifications pour tubes, raccords et le système

Kunststoff-Rohrleitungssysteme zum Ableiten von Abwasser (niedriger und hoher Temperatur) innerhalb der Gebäudestruktur - Polypropylen (PP) - Teil 1: Anforderungen an Rohre, Formstücke und das Rohrleitungssystem

This European Standard was approved by CEN on 18 September 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

This document consolidates EN 1451-1:2017 and the corrigendum EN 1451:2017/AC:2018.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	4
1 Scope	6
2 Normative references	7
3 Terms and definitions	8
4 Symbols and abbreviations	11
4.1 Symbols	11
4.2 Abbreviations	11
5 Material	12
5.1 PP-compound	12
5.2 Additional requirement for pipe and fitting material for application area BD	12
5.3 Utilization of non-virgin material	13
5.4 Melt mass-flow rate	13
5.5 Thermal stability (OIT)	13
5.6 Sealing ring retaining means	13
5.7 Fire behaviour	13
6 General characteristics	14
6.1 Appearance	14
6.2 Colour	14
7 Geometrical characteristics	14
7.1 General	14
7.2 Dimensions of pipes	14
7.2.1 Outside diameters	14
7.2.2 Effective length of pipes	15
7.2.3 Chamfering	16
7.2.4 Wall thickness	16
7.3 Dimensions of fittings	18
7.3.1 Outside diameters	18
7.3.2 Design lengths	18
7.3.3 Wall thickness	18
7.4 Dimensions of sockets and pipe ends	19
7.4.1 Dimensions of ring seal sockets and spigot ends	19
7.4.2 Dimensions of pipe ends for butt fusion joints	23
7.5 Types of fittings	23
8 Mechanical characteristics	40
8.1 Mechanical characteristics of pipes	40
8.1.1 General characteristics	40
8.1.2 Additional characteristics for pipes	41
8.2 Mechanical characteristics of fittings for application area BD	42
9 Physical characteristics	43
9.1 Physical characteristics of pipes	43
9.2 Physical characteristics of fittings	44
10 Performance requirements	45
11 Sealing rings	46

12	Marking	46
12.1	General	46
12.2	Minimum required marking of pipes	46
12.3	Minimum required marking of fittings	47
12.4	Additional marking	48
Annex A	(normative) Utilization of non-virgin PP material	49
A.1	Own reprocessed material from pipes and fittings	49
A.2	External reprocessed and recycled materials with an agreed specification	49
A.2.1	Material from PP pipes and fittings	49
A.2.2	Material from PP products other than pipes and fittings	50
Annex B	(informative) Product standards	51
Bibliography	52

European foreword

This document (EN 1451-1:2017) has been prepared by Technical Committee CEN/TC 155 “Plastics piping systems and ducting systems”, the secretariat of which is held by NEN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2018, and conflicting national standards shall be withdrawn at the latest by May 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1451-1:1998.

EN 1451, *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure - Polypropylene (PP)* consists of the following parts:

- *Part 1: Specifications for pipes, fittings and the system*
- *Part 2: Guidance for the assessment of conformity (CEN/TS)*

The main changes with respect to the previous edition are:

- updating in accordance with the new template;
- updating of normative references;
- thermal stability (OIT) requirement is made valid in general;
- two new dimensions for nominal size and outside diameter have been added, 250 mm and 315 mm;
- alignment of the impact resistance requirements for BD applications with the UD applications in EN 1852-1;
- utilization of non-virgin PP materials are described in the new Annex A;
- Annex B has been deleted and the relevant text has been moved to the main standard;
- new Annex B “Product standards” has been added.

This document includes the corrigendum EN 1451-1:2017/AC:2018, which corrects a value for ' $d_{em, max}$ ' in Table 2.

System standards are based on the results of the work undertaken in ISO/TC 138 “Plastics pipes, fittings and valves for the transport of fluids”, which is a Technical Committee of the International Organization for Standardization (ISO).

They are supported by separate standards on test methods to which references are made throughout the system standard.

The system standards are consistent with general standards on functional requirements and on recommended practice for installation.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This document is a preview generated by EVS

1 Scope

This part of EN 1451 specifies the requirements for solid-wall polypropylene (PP) pipes, fittings and the system intended for:

- soil and waste discharge applications (low and high temperature) inside buildings (application area code “B”);
- soil and waste discharge applications (low and high temperature) for both inside buildings and buried in the ground within the building structure (application area code “BD”).

The intended use is reflected in the marking of products by “B” or “BD”.

NOTE 1 For use buried in the ground within the building structure are intended only those components marked with “BD”, with dimensions equal to or greater than 75 mm and nominal ring stiffness of at least SN4.

This part of EN 1451 is also applicable to PP pipes and fittings and the system intended for the following purposes:

- ventilating part of the pipework in association with discharge applications;
- rainwater pipework within the building structure.

It also specifies the test parameters for the test methods referred to in this standard.

This European Standard covers a range of nominal sizes, a range of pipes and fittings series and gives recommendations concerning colours.

NOTE 2 It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and any relevant national regulations and installation practices or codes, e.g. CEN/TR 13801 [1].

NOTE 3 Pipes, fittings and other components conforming to any of the plastics product standards listed in Annex B can be used with pipes and fittings conforming to this European Standard, provided they conform to the requirements for joint dimensions given in Clause 6 and to the requirements of Table 18.

This standard applies to pipes and fittings, marked with “B”, which are intended to be used inside buildings and outside buildings fixed onto the wall.

It applies to pipes and fittings, marked with “BD”, which are intended to be used for both inside buildings and buried in the ground within the building structure.

This standard is applicable to PP pipes and fittings of the following types:

- plain-ended,
- with integral elastomeric ring seal socket,
- for butt fusion joints,

whereby the fittings can be manufactured by injection-moulding or be fabricated from pipes and/or mouldings.

NOTE 4 EN 476 [2] specifies the general requirements for components used in discharge pipes, drains and sewers for gravity systems. Pipes and fittings conforming to this standard fully meet these requirements.

NOTE 5 For information about the chemical resistance of PP, guidance is given in ISO/TR 10358 [3] and for rubber materials in ISO/TR 7620[4].

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 681-1, *Elastomeric seals - Materials requirements for pipe joint seals used in water and drainage applications - Part 1: Vulcanized rubber*

EN 681-2, *Elastomeric Seals - Materials requirements for pipe joint seals used in water and drainage applications - Part 2: Thermoplastic elastomers*

EN 12099, *Plastics piping systems - Polyethylene piping materials and components - Determination of volatile content*

EN ISO 472, *Plastics - Vocabulary (ISO 472)*

EN ISO 580, *Plastics piping and ducting systems - Injection-moulded thermoplastics fittings - Methods for visually assessing the effects of heating (ISO 580)*

EN ISO 1043-1, *Plastics - Symbols and abbreviated terms - Part 1: Basic polymers and their special characteristics (ISO 1043-1)*

EN ISO 1133-1, *Plastics - Determination of the melt mass-flow rate (MFR) and melt volume-flow rate (MVR) of thermoplastics - Part 1: Standard method (ISO 1133-1)*

EN ISO 1167-1, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids - Determination of the resistance to internal pressure - Part 1: General method (ISO 1167-1)*

EN ISO 1167-2, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids - Determination of the resistance to internal pressure - Part 2: Preparation of pipe test pieces (ISO 1167-2)*

EN ISO 1183-2, *Plastics - Methods for determining the density of non-cellular plastics - Part 2: Density gradient column method (ISO 1183-2)*

EN ISO 2505, *Thermoplastics pipes - Longitudinal reversion - Test method and parameters (ISO 2505)*

EN ISO 3126, *Plastics piping systems - Plastics components - Determination of dimensions (ISO 3126)*

EN ISO 3451-1, *Plastics - Determination of ash - Part 1: General methods (ISO 3451-1)*

EN ISO 11357-6, *Plastics - Differential scanning calorimetry (DSC) - Part 6: Determination of oxidation induction time (isothermal OIT) and oxidation induction temperature (dynamic OIT) (ISO 11357-6)*

EN ISO 9969, *Thermoplastics pipes - Determination of ring stiffness (ISO 9969)*

☐AC☐ EN ISO 13254, *Thermoplastics piping systems for non-pressure applications - Test method for watertightness (ISO 13254)* ☐AC☐

☐AC☐ EN ISO 13255, *Thermoplastics piping systems for soil and waste discharge inside buildings - Test method for airtightness of joints (ISO 13255)* ☐AC☐

☐AC☐ EN ISO 13257, *Thermoplastics piping systems for non-pressure applications - Test method for resistance to elevated temperature cycling (ISO 13257)* ☐AC☐

EN ISO 13259, *Thermoplastics piping systems for underground non-pressure applications - Test method for leaktightness of elastomeric sealing ring type joints (ISO 13259)*

EN ISO 13263, *Thermoplastics piping systems for non-pressure underground drainage and sewerage - Thermoplastics fittings - Test method for impact strength (ISO 13263)*

EN ISO 13264, *Thermoplastics piping systems for non-pressure underground drainage and sewerage - Thermoplastics fittings - Test method for mechanical strength or flexibility of fabricated fittings (ISO 13264)*

EN ISO 3127, *Thermoplastics pipes — Determination of resistance to external blows — Round-the-clock method*

ISO 4065, *Thermoplastics pipes - Universal wall thickness table*

EN ISO 11173, *Thermoplastics pipes — Determination of resistance to external blows — Staircase method*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 472, EN ISO 1043-1 and the following apply.

3.1 application area code
code used in the marking of pipes and fittings to indicate the application area(s) for which they are intended, as follows:

- B: application area code for components intended for use above ground inside the building, or for components outside buildings fixed onto the wall;
- D: application code for the area under and within 1 m from the building where the pipes and fittings are buried in ground and are connected to the underground drainage and sewerage system;
- BD: application area code for components intended for use for both code B and code D application areas

Note 1 to entry: In D application areas, the existence of external forces from the surroundings in addition to the hot water discharge is usual.

Note 2 to entry: Other application area codes U and UD not covered by this standard are defined elsewhere, e.g. in EN 1852-1.

3.2 nominal size

3.2.1 nominal size

DN
numerical designation of the size of a component, other than a component designated by thread size, which is approximately equal to the manufacturing dimension, in millimetres

3.2.2 nominal size

DN/OD
nominal size, related to the outside diameter