
**Fire containment — Elements of building
construction —**

**Part 2:
Kitchen extract ducts**

Endiguement du feu — Éléments de construction —

Partie 2: Conduits de ventilation de la cuisine



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

This document is a preview generated by EVS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2009

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Test equipment	2
4.1 Fire outside duct	2
4.2 Fire inside duct	2
5 Test conditions	3
5.1 Fire outside duct	3
5.2 Fire inside duct	3
6 Instrumentation	3
6.1 Fire outside duct	3
6.2 Fire inside duct	3
7 Test construction	8
7.1 Fire outside duct	8
7.2 Fire inside duct	8
8 Test procedure	9
8.1 Fire outside duct	9
8.2 Fire inside duct	9
9 Performance criteria	11
9.1 Fire outside duct	11
9.2 Fire inside duct	11
10 Expression of results	11
11 Test report	12
Annex A (normative) Optional test equipment and instrumentation — Fire inside duct	13
Annex B (informative) Historical information	15
Bibliography	17

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 6944-2 was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 2, *Fire containment*.

ISO 6944 consists of the following parts, under the general title *Fire containment — Elements of building construction*:

- *Part 1: Ventilation ducts*
- *Part 2: Kitchen extract ducts*

Introduction

The purpose of this part of ISO 6944 is to measure the ability of a representative duct or duct assembly that is part of a kitchen extract duct system to resist the spread of fire from one fire compartment to another with the fire attack being from either the inside of the duct or from the outside of the duct. This part of ISO 6944 is applicable to vertical and horizontal ducts, with or without branches, taking into account joints and exhaust openings, as well as suspension devices and penetration points.

The test method representing a fire attack from the inside of the duct first simulates temperatures within a kitchen extract duct during normal operation followed by simulating the temperatures during a fire within the duct. For kitchen extract ducts, the inevitable build-up of grease on the inside surfaces can lead to a severe fire exposure and this is represented in the test method described in this part of ISO 6944. A burner assembly, attached to a horizontal L-shaped combustion chamber, develops the heat required to obtain the temperatures. The combustion chamber is attached to the sample kitchen extract duct assembly. The kitchen extract duct is also L-shaped with both horizontal and vertical components.

The test method representing a fire attack from the outside of the duct exposes the kitchen extract duct to furnace conditions defined in ISO 634-1. The test method includes provisions for assessment of the penetration seal surrounding the kitchen extract as the duct passes through a fire resistive barrier. The test method evaluates the structural integrity of the kitchen extract duct by having the duct restrained within the furnace during the fire exposure.

This document is a preview generated by EVS

Fire containment — Elements of building construction —

Part 2: Kitchen extract ducts

CAUTION — The attention of all persons concerned with managing and carrying out of this fire resistance test is drawn to the fact that fire testing can be hazardous and there is a possibility that toxic and/or harmful smoke and gases can be evolved during the test. Mechanical and operational hazards can also arise during the construction of the test elements or structures, their testing and disposal of test residues.

It is strongly recommended that the duct assembly be allowed to cool completely after the fire test before dismantling to minimize the possibility of the ignition of combustible residues.

An assessment of all potential hazards and risks to health shall be made and safety precautions shall be identified and provided. Written safety instructions shall be issued. Appropriate training shall be given to relevant personnel. Laboratory personnel shall ensure that they follow written safety instructions at all times.

1 Scope

This part of ISO 6944 establishes a method of test in which kitchen extract ducts are required to provide fire resistance. The requirements are intended to limit the spread of fire from the duct when a fire occurs within the duct and assesses the structural integrity of the duct when a fire occurs in the area surrounding the duct.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 834-1, *Fire-resistance tests — Elements of building construction — Part 1: General requirements*

ISO 6944-1:2008, *Fire containment — Elements of building construction — Part 1: Ventilation ducts*

ISO 13943, *Fire safety — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 6944-1, ISO 13943 and the following apply.

3.1

kitchen extract duct

exhaust duct intended for use in commercial kitchens