

This document is a preview generated by EVS

Monitoring and alarm receiving centre

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50518:2019 sisaldab Euroopa standardi EN 50518:2019 ingliskeelset teksti.	This Estonian standard EVS-EN 50518:2019 consists of the English text of the European standard EN 50518:2019.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 16.08.2019.	Date of Availability of the European standard is 16.08.2019.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.320

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 13.320

Supersedes EN 50518-1:2013, EN 50518-2:2013, EN 50518-3:2013 and all of its amendments and corrigenda (if any)

English Version

Monitoring and Alarm Receiving Centre

Centre de contrôle et de réception d'alarme

Alarmpfangsstelle

This European Standard was approved by CENELEC on 2019-02-06. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	6
Introduction	7
1 Scope	8
2 Normative references	9
3 Terms, definitions and abbreviations	10
3.1 Terms and definitions	10
3.2 Abbreviations.....	14
4 Planning	15
4.1 Categorization	15
4.2 Site selection	15
5 Construction – ARC structure	15
5.1 General.....	15
5.2 Walls, floor and ceiling – resistance against physical attack	15
5.2.1 Category I.....	15
5.2.2 Category II.....	16
5.3 Perimeter doorsets – resistance against physical attack and bullet attack	16
5.4 Glazed areas	16
5.4.1 Category I.....	16
5.4.2 Category II.....	16
5.5 Resistance against fire and smoke	16
5.6 Protection against the effect of lightning	16
5.7 Openings	16
5.7.1 General.....	16
5.7.2 Entrance to the ARC.....	17
5.7.3 Emergency entry	17
5.7.4 Emergency exit(s).....	17
5.7.5 Ventilation.....	17
5.7.6 Service inlets and outlets.....	18
5.7.7 Transfer hatch / chute.....	18
5.8 Location of data processing equipment.....	18
5.8.1 Category I.....	18
5.8.2 Category II.....	19
5.9 Communication cables	20
5.9.1 Category I.....	20
5.9.2 Category II.....	20
5.10 Facilities	20
5.10.1 Category I.....	20
5.10.2 Category II	20
6 Alarm systems of the ARC	20
6.1 Category I.....	20
6.1.1 General.....	20
6.1.2 External attack.....	21
6.1.3 Glazed areas	21
6.1.4 Fire	21
6.1.5 Entry / exit	21
6.1.6 Gas.....	21
6.1.7 Hold-up.....	21
6.1.8 Safety monitoring.....	21
2	

6.1.9	Messages from the ARC alarm systems	22
6.1.10	Video surveillance system.....	22
6.2	Category II.....	22
7	Electrical power supplies	22
7.1	Mains supply.....	22
7.2	Standby power supplies.....	22
7.2.1	General.....	22
7.2.2	UPS.....	22
7.2.3	Standby generators	23
8	Alarm Management System	23
8.1	General.....	23
8.2	Time synchronization of equipment	25
8.3	Recording and logging of events.....	25
8.4	Storage of master data	25
9	Operation of the ARC	26
9.1	Procedures – General.....	26
9.1.1	General.....	26
9.1.2	Creation, modification and cancellation of services or customer accounts	26
9.1.3	Message handling.....	26
9.1.4	Communication with response services	26
9.1.5	Individual services provided by the ARC.....	26
9.1.6	Alarm verification	26
9.1.7	Unexpected increase in alarm signals.....	26
9.1.8	Alarm transmission path failures	26
9.1.9	Controls to maintain quality of service.....	27
9.1.10	Installation, maintenance, protection, removal and reuse of assets under the control of the ARC	27
9.1.11	Monitoring and testing of equipment	27
9.1.12	Fault procedures and reporting	27
9.1.13	Information management	28
9.1.14	Data back-up	28
9.1.15	Confidentiality and classification of information	28
9.1.16	Relationships with essential suppliers	28
9.1.17	Administrative procedures	28
9.1.18	Physical access	28
9.1.19	Remote access	29
9.1.20	Operational continuity and emergencies	29
9.1.21	Emergency evacuation and re-entry	29
9.1.22	Emergency entry.....	29
9.1.23	Key performance indicators	29
9.2	Performance criteria – message handling.....	29
10	General Principles, Leadership, Governance, Management, and Staffing.....	30
10.1	General.....	30
10.2	Governance and Strategy	30
10.3	Legal and operational set-up	30
10.4	Management System.....	30
10.5	Staffing	32
10.5.1	General.....	32
10.5.2	Security screening and vetting	32
10.5.3	Training.....	32
Annex A	(informative) Typical ARC layout category I.....	33
Annex B	(informative) Security and technical implications of remote access to ARC data	34
B.1	General	34

B.2	Levels of access	34
B.3	Access to the system	34
B.4	Authorization for facilities	34
B.4.1	General	34
B.4.2	View only	34
B.4.3	Edit	35
B.4.4	Creation of a new record	35
B.4.5	Confirmation of changes made.....	35
B.5	Placing a system on test	35
B.6	Password management	35
Annex C	(informative) Alarm management system requirements	36
C.1	Structure of an AMS	36
C.1.1	General	36
C.1.2	Interface for interconnection with RCT (I_{RCT}).....	37
C.1.3	Interconnection with other AMS's (joining module)	37
C.1.4	Communication module.....	37
C.1.5	Information module	37
C.1.6	User Interface.....	37
C.2	Faults	37
C.2.1	General	37
C.2.2	Fault detection	37
C.2.3	Avoiding faults in manual data entries	37
C.2.4	Presentation of fault information.....	37
C.3	Message	38
C.3.1	Message acknowledgement	38
C.3.2	Alarm messages	38
C.3.3	Fault messages.....	38
C.3.4	Expected messages	38
C.3.5	Other received messages	38
C.3.6	Message queue.....	38
C.3.7	Input priorities	39
C.3.8	Alert indication	39
C.3.9	Message acceptance.....	39
C.4	Information to be presented	39
C.4.1	Information to be presented relating to messages	39
C.4.2	Information to be presented relating to fault information received from alarm systems	40
C.4.3	Failure of the means of presentation of information	40
C.5	Logging	40
C.5.1	General	40

C.5.2	Time stamps for logging	40
C.5.3	Master data log (Log M1)	41
C.5.4	Event log's	41
C.5.5	Access levels	42
C.5.6	Access to database	42
C.5.7	Access to alarm management system	42
C.5.8	Access to alarm management system configuration data	42
C.5.9	Access to log data	42
C.6	Monitoring of interconnection with the receiving centre transceiver	43
	Bibliography	44

European foreword

This document (EN 50518:2019) has been prepared by CLC/TC 79, "Alarm systems".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-02-06
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2022-02-06

This documents supersedes EN 50518-1:2013, EN 50518-2:2013 and EN 50518-3:2013.

EN 50518:2017 includes the following significant technical changes with respect to EN 50518-1:2013, EN 50518-2:2013 and EN 50518-3:2013:

- referenced based standards were updated to the latest versions;
- definitions were updated;
- the scope was extended to include fire, access, CCTV, social alarms and other alarms;
- two categories ARC's are described, category I and category II. A category I ARC will be designed, constructed and operated to a higher standard with respect to construction, security and integrity than a category II ARC;
- a chapter was added which describes the management tools that shall be in place in the ARC;
- an informative annex was added which describes security and technical implications of remote access to ARC data;
- an informative annex was added which describes requirements for an alarm management system.

This revision was prepared to bring the procedures up-to-date with current technical developments, taking account of changes in the basic standards and the experience gained in the use of the standard.

Introduction

This European Standard applies to all Monitoring and Alarm Receiving Centres (MARC's) that monitor and/or receive and/or process (alarm) messages that require an emergency response.

The abbreviation MARC describes the full functional scope of a Monitoring and Alarm Receiving centre. In all existing EN 50131 series under CLC/TC 79, "Alarm systems", the abbreviation ARC is used. To avoid confusion and to achieve consistency in terminology the abbreviation ARC will be used throughout this standard, where MARC is equivalent to ARC.

The function of receiving, processing and initiating response actions by (human or non-human) intervention is not limited to only those messages as generated by Intruder and Hold-up Alarm Systems (I&HAS). The whole series of standards under CLC/TC 79, "Alarm systems", encompasses video surveillance systems (EN 62676), social alarm systems (EN 50134), access control systems (EN 60839-11) and audio and video door entry systems. All of these systems can send information, including alarms, to one or more ARC's for further processing, evaluation and intervention.

Alarm information generated by other systems such as fire detection and fire alarm systems, (vehicle) tracking and tracing systems, man guarding or telecommunication network supervision is regularly transmitted to one or more ARC's for further processing, evaluation and intervention.

In all of these circumstances, criminal action and/or emergency situations can jeopardize the safety and security of people and/or properties. The central locations where the receiving, processing and initiation of intervention take place should comply with the requirements of this standard.

Figure 1 shows the chain of events of the total alarm process.




Figure 1 — Chain diagram of the total alarm process

It is noted that this European Standard cannot supersede any legislative requirements deemed necessary by a National Government to control the security sector on a national basis. This standard cannot interfere with all those items that are regulated by (inter)national regulations concerning external services (for example water, waste water, fuel supplies for gas and/or oil and mains power supplies).

1 Scope

This document specifies the minimum requirements for monitoring, receiving and processing of alarm messages generated by alarm systems taking place as a part of the total fire, safety and security solution.

For the purpose of this document, the term “alarm” is used in the broad sense to include fault, status and other messages received from one or more of a range of safety and security alarm systems such as but not limited to fire detection and fire alarm systems, fixed firefighting systems, intrusion and hold-up alarm systems, access control systems, video surveillance systems, social alarms systems and combinations of such systems.

This document gives requirements for two categories of ARC, category I and category II. A category I ARC will be designed, constructed and operated to a higher standard with respect to construction, security and integrity than a category II ARC.

The categorization is determined according to the type(s) of alarm messages handled.

Category I: ARCs handling messages from security applications:

- I&HAS's;
- access control systems;
- VSS in security applications that require an emergency response (for example loss prevention);
- people monitoring, lone workers and object tracking systems for security applications;
- alarm messages handled by category II ARCs;
- combinations of the above systems.

Category II: ARC's handling messages from non-security applications:

- fire alarm systems;
- fixed firefighting systems;
- social alarm systems;
- audio/video door entry systems;
- VSS in non-security applications (for example traffic flow);
- people monitoring, lone workers and object tracking systems for non-security applications;
- lifts emergency systems;
- combinations of the above systems.

The requirements apply to ARC's (whether established in single or multiple sites) monitoring and processing alarms generated by systems installed at other locations and also to ARC's monitoring solely alarms from systems within their own site.

The document includes functional and specific requirements supporting the services of an ARC.

The document does NOT apply to:

- alarm systems used for non-civil purposes;
- alarm systems for medical or health applications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54 (series), *Fire detection and fire alarm systems*

EN 179, *Building hardware — Emergency exit devices operated by a lever handle or push pad, for use on escape routes — Requirements and test methods*

EN 356, *Glass in building — Security glazing — Testing and classification of resistance against manual attack*

EN 1063, *Glass in building — Security glazing — Testing and classification of resistance against bullet attack*

EN 1125, *Building hardware — Panic exit devices operated by a horizontal bar, for use on escape routes — Requirements and test methods*

EN 1522, *Windows, doors, shutters and blinds — Bullet resistance — Requirements and classification*

EN 1627, *Pedestrian doorsets, windows, curtain walling, grilles and shutters — Burglar resistance — Requirements and classification*

EN 13501-2, *Fire classification of construction products and building elements — Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN 13637, *Building hardware — Electrically controlled exit systems for use on escape routes — Requirements and test methods*

EN 14846, *Building hardware — Locks and latches — Electromechanically operated locks and striking plates - Requirements and test methods*

EN 15713, *Secure destruction of confidential material — Code of practice*

EN 50131-1, *Alarm systems — Intrusion and hold-up systems — Part 1: System requirements*

EN 50134-7, *Alarm systems — Social alarm systems — Part 7: Application guidelines*

EN 50136-1, *Alarm systems — Alarm transmission systems and equipment — Part 1: General requirements for alarm transmission systems*

EN 50136-3, *Alarm systems — Alarm transmission systems and equipment — Part 3: Requirements for Receiving Centre Transceiver (RCT)*

EN 50272-2, *Safety requirements for secondary batteries and battery installations — Part 2: Stationary batteries*

EN 50600 (series), *Information technology — Data centre facilities and infrastructures*

EN 62040-1, *Uninterruptible power systems (UPS) — Part 1: General and safety requirements for UPS (IEC 62040-1)*

EN 62305-2, *Protection against lightning — Part 2: Risk management*

EN 62676-4, *Video surveillance systems for use in security applications — Part 4: Application guidelines*