
**Fire detection and fire alarm
systems —**

**Part 24:
Fire alarm loudspeakers**

Systèmes de détection d'incendie et d'alarme —

Partie 24: Haut-parleurs pour systèmes d'alarme vocale



This document is a preview generated by EBS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	v
Introduction	vii
1 Scope	1
2 Normative references	1
3 Terms, definitions, symbols and abbreviated terms	2
3.1 Terms and definitions	2
3.2 Abbreviated terms	4
4 Requirements	4
4.1 Compliance	4
4.2 Frequency response limits	5
4.3 Durability	5
4.4 Construction	5
4.4.1 Provision for external conductors	5
4.4.2 Materials	6
4.4.3 Ingress protection	6
4.4.4 Access	6
5 Tests	6
5.1 General	6
5.1.1 Atmospheric conditions for tests	6
5.1.2 Operating conditions for tests	6
5.1.3 Mounting arrangements	7
5.1.4 Tolerances	7
5.1.5 Frequency response measurement and sensitivity calculation	7
5.1.6 Frequency response measurement and sensitivity calculation for loudspeakers requiring dedicated system equalization	8
5.1.7 Provision for tests	8
5.1.8 Test schedule	9
5.2 Reproducibility	10
5.2.1 Object of the test	10
5.2.2 Test procedure	10
5.2.3 Requirements	10
5.3 Rated impedance	10
5.3.1 Object of the test	10
5.3.2 Test procedure	10
5.3.3 Requirements	11
5.4 Horizontal and vertical coverage angles	11
5.4.1 Object of the test	11
5.4.2 Test procedure	11
5.4.3 Requirements	12
5.5 Maximum sound pressure level	12
5.5.1 Object of the test	12
5.5.2 Test procedure	12
5.5.3 Requirements	13
5.6 Rated noise power (durability)	13
5.6.1 Object of the test	13
5.6.2 Test procedure	13
5.6.3 Requirements	13
5.7 Dry heat (operational)	14
5.7.1 Object of the test	14
5.7.2 Test procedure	14
5.7.3 Requirements	14
5.8 Dry heat (endurance)	14

5.8.1	Object of the test	14
5.8.2	Test procedure	15
5.8.3	Requirements	15
5.9	Cold (operational)	15
5.9.1	Object of the test	15
5.9.2	Test procedure	15
5.9.3	Requirements	16
5.10	Damp heat, cyclic (operational)	16
5.10.1	Object of the test	16
5.10.2	Test procedure	16
5.10.3	Requirements	17
5.11	Damp heat, steady-state (endurance)	17
5.11.1	Object of the test	17
5.11.2	Test procedure	17
5.11.3	Requirements	18
5.12	Damp heat, cyclic (endurance)	18
5.12.1	Object of the test	18
5.12.2	Test procedure	18
5.12.3	Requirements	18
5.13	Sulfur dioxide (SO ₂) corrosion (endurance)	18
5.13.1	Object of the test	18
5.13.2	Test procedure	19
5.13.3	Requirements	19
5.14	Shock (operational)	19
5.14.1	Object of the test	19
5.14.2	Test procedure	19
5.14.3	Requirements	20
5.15	Impact (operational)	20
5.15.1	Object of the test	20
5.15.2	Test procedure	20
5.15.3	Requirements	21
5.16	Vibration, sinusoidal (operational)	21
5.16.1	Object of the test	21
5.16.2	Test procedure	21
5.16.3	Requirements	22
5.17	Vibration, sinusoidal (endurance)	22
5.17.1	Object of the test	22
5.17.2	Test procedure	23
5.17.3	Requirements	23
5.18	Ingress protection	24
5.18.1	Object of the test	24
5.18.2	Enclosure of the loudspeaker	24
5.18.3	Test procedure	24
5.18.4	Requirements	25
6	Test report	25
7	Marking	25
8	Data	26
	Annex A (normative) Acoustical measurements	27
	Annex B (normative) Measuring rated noise power (durability)	32
	Annex C (informative) Loudspeaker physical references	37
	Bibliography	39

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

This second edition cancels and replaces the first edition (ISO 7240-24:2010), of which it constitutes a minor revision.

It also incorporates the Amendment ISO 7240-24:2010/Amd, 1:2013.

ISO 7240 consists of the following parts, under the general title *Fire detection and fire alarm systems*:

- *Part 1: General and definitions*
- *Part 2: Control and indicating equipment*
- *Part 3: Audible alarm devices*
- *Part 4: Power supply equipment*
- *Part 5: Point-type heat detectors*
- *Part 6: Carbon monoxide fire detectors using electro-chemical cells*
- *Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization*
- *Part 8: Point-type fire detectors using a carbon monoxide sensor in combination with a heat sensor*
- *Part 9: Test fires for fire detectors [Technical Specification]*
- *Part 10: Point-type flame detectors*
- *Part 11: Manual call points*
- *Part 12: Line type smoke detectors using a transmitted optical beam*
- *Part 13: Compatibility assessment of system components*

- *Part 14: Design, installation, commissioning and service of fire detection and fire alarm systems in and around buildings*
- *Part 15: Point-type fire detectors using smoke and heat sensors*
- *Part 16: Sound system control and indicating equipment*
- *Part 17: Short-circuit isolators*
- *Part 18: Input/output devices*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Routing equipment*
- *Part 22: Smoke-detection equipment for ducts*
- *Part 23: Visual alarm devices*
- *Part 24: Fire alarm loudspeakers*
- *Part 25: Components using radio transmission paths*
- *Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*
- *Part 28: Fire protection control equipment*

The following part is under preparation:

- *Part 29: Video fire detectors*

Introduction

The purpose of a fire alarm loudspeaker as a component of a fire alarm system (see ISO 7240-19) is to provide intelligible warning to people in or within the vicinity of a building in which a fire emergency has occurred and to enable such person(s) to take appropriate measures in accordance with a predetermined evacuation plan.

The primary reason for using a fire alarm system, instead of coded warnings given by aural alarm indicators (see ISO 7240-3), is to reduce the time taken for those at risk to recognize that an emergency exists and to give clear instructions about what to do next. This means that fire alarm loudspeakers are required to achieve a minimum acoustical performance, as well as constructional and environmental requirements, to be suitable for use in a fire alarm system.

This part of ISO 7240 recognizes that the exact nature of the acoustical requirements for fire alarm loudspeakers varies according to the nature of the space into which they are installed. It therefore specifies the minimum requirements that apply to fire alarm loudspeakers and a common method for testing their operational performance against parameters specified by the manufacturers.

This part of ISO 7240 gives common requirements for the construction and robustness of fire alarm loudspeakers as well as their performance under climatic and mechanical conditions that are likely to occur in the service environment. As the types of loudspeaker considered in this part of ISO 7240 are passive electromechanical devices not involving sensitive electronic circuits, electromagnetic compatibility (EMC) tests have not been included. The loudspeakers have been classified for either an indoor or an outdoor application environment category.

This part of ISO 7240 requires that manufacturers specify certain characteristics in a consistent manner so that designers can make objective decisions about which loudspeaker to use in specific applications.

Fire detection and fire alarm systems —

Part 24:

Fire alarm loudspeakers

1 Scope

This part of ISO 7240 specifies requirements, test methods and performance criteria for loudspeakers intended to broadcast a warning of fire between a fire detection and alarm system and the occupants of a building (see ISO 7240-1:2014, Figure 1, item C).

This part of ISO 7240 specifies loudspeakers for two types of application environment: type A, generally for indoor use, and type B, generally for outdoor use.

This part of ISO 7240 does not cover loudspeakers for special applications, for example, loudspeakers for use in hazardous applications, if such applications require additional or other requirements or tests other than those given in this part of ISO 7240.

This part of ISO 7240 is not intended to cover addressable loudspeakers or loudspeakers with active components.

Audible alarm indicators are covered in ISO 7240-3.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

IEC 60068-1, *Environmental testing — Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing — Part 2-1: Tests — Test A: Cold*

IEC 60068-2-2, *Environmental testing — Part 2-2: Tests — Test B: Dry heat*

IEC 60068-2-6, *Environmental testing — Part 2-6: Tests — Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing — Part 2-27: Tests — Test Ea and guidance: Shock*

IEC 60068-2-30, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-42, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections*

IEC 60068-2-75, *Environmental testing — Part 2-75: Tests — Test Eh: Hammer tests*

IEC 60068-2-78, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state*

IEC 60268-1, *Sound system equipment — Part 1: General*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*

IEC 60695-11-10, *Fire hazard testing — Part 11-10: Test flames — 50 W horizontal and vertical flame test methods*

IEC 60695-11-20, *Fire hazard testing — Part 11-20: Test flames — 500 W flame test methods*

IEC 61260, *Electroacoustics — Octave-band and fractional-octave-band filters*

IEC 61672-1, *Electroacoustics — Sound level meters — Part 1: Specifications*

3 Terms, definitions, symbols and abbreviated terms

For the purposes of this document, the terms, definitions and symbols given in ISO 7240-1 and the following apply.

3.1 Terms and definitions

3.1.1

1/3 octave

frequency band as defined in IEC 61260

3.1.2

coverage angle

smallest angle between two directions on either side of the reference axis at which the sound pressure level is 6 dB less than the sound pressure level on the reference axis

Note 1 to entry: This angle is measured in the vertical and horizontal planes.

3.1.3

free-field condition

acoustical environment in which the sound pressure decreases with the distance, r , from a point source according to a $1/r$ law, with an accuracy of $\pm 10\%$, in the region that is occupied by the sound field between the loudspeaker system and the microphone during the measurements

EXAMPLE An anechoic room, a quiet outdoor space.

3.1.4

frequency response

sound pressure level at a distance of 4 m from the reference point on the reference axis, produced at 1/3 octave frequency bands, from 100 Hz to 10 kHz (centre frequencies)

Note 1 to entry: This is also referred to as magnitude or amplitude response.

3.1.5

ground plane measurement

measurement under half-space free-field conditions used to simulate a free-field condition in which the loudspeaker is mounted above an acoustically totally reflective boundary surface and aimed so that its reference axis points towards a measurement microphone that is placed directly on the boundary surface

Note 1 to entry: In order to achieve measurement results that are comparable with a free-field condition, ground-plane measurements need to be corrected by -6 dB at all frequencies.

3.1.6

half-space free-field condition

acoustical environment that is confined by a plane of sufficient size and in which the free-field exists in a hemisphere, so that the sound pressure from a point source mounted in the surface of that plane decreases in the manner defined in the free-field condition

EXAMPLE A half-space anechoic room.

3.1.7

horizontal plane

virtual plane of the loudspeaker containing the reference axis, as specified by the manufacturer

Note 1 to entry: There may be several horizontal planes corresponding to several reference axes.