

SISENDRÕHULE KUNI 100 BAARI ETTE NÄHTUD GAASI
TURVA-SULGURSEADMED

Gas safety shut-off devices for inlet pressure up to 10
MPa (100 bar)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 14382:2019 sisaldab Euroopa standardi EN 14382:2019 ingliskeelset teksti.	This Estonian standard EVS-EN 14382:2019 consists of the English text of the European standard EN 14382:2019.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 21.08.2019.	Date of Availability of the European standard is 21.08.2019.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.060.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Gas safety shut-off devices for inlet pressure up to 10 MPa (100 bar)

Clapets de sécurité pour pressions amont jusqu'à 10
MPa (100 bar)

Gas-Sicherheitsabsperreinrichtungen für
Eingangsdrücke bis 10 MPa (100 bar)

This European Standard was approved by CEN on 23 April 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	5
1 Scope.....	7
2 Normative references.....	8
3 Terms and definitions.....	9
3.1 General terms and definition of type of gas safety shut-off devices.....	9
3.2 Terms and definition of components of safety devices.....	10
3.3 Terms, symbols and definitions related to the functional performance.....	16
3.4 Possible values of all variables.....	17
3.5 Terms, symbols and definitions related to the set value of the trip pressure.....	17
3.6 Terms, symbols and definitions related to the flow.....	18
3.7 Terms, symbols and definitions related to accuracy and some other performances.....	18
3.8 Terms, symbols and definitions related to the design and tests.....	19
3.9 Summary of symbols, terms, subclauses and units.....	21
4 Construction requirements.....	22
4.1 Basic requirements.....	22
4.2 Materials.....	25
4.3 Strength of housings and other parts.....	26
4.4 Strength of elastomeric diaphragms.....	29
5 Functional and characteristic requirements.....	30
5.1 General.....	30
5.2 Accuracy group.....	31
5.3 Response time.....	32
5.4 Relatching difference and unlatching.....	32
5.5 Closing force.....	32
5.6 Endurance and accelerated ageing.....	33
5.7 Strength of the trip mechanism, valve seat and closing member against the dynamic impact of flowing gas.....	33
5.8 Antistatic characteristics.....	33
5.9 Flow coefficient.....	33
5.10 Final visual inspection.....	33
6 Testing.....	34
6.1 General.....	34
6.2 Tests.....	34
6.3 Type test.....	35
6.4 Selection of test samples.....	35
6.5 Routine tests.....	36
6.6 Production surveillance.....	36
7 Test and verification methods.....	36
7.1 Dimensional check and visual inspection.....	36
7.2 Materials check.....	36
7.3 Verification of the strength of parts under pressure.....	36

7.4	Verification of the strength of parts transmitting actuating forces	36
7.5	Shell and inner metallic partition walls strength test.....	37
7.6	Alternative shell and inner metallic partition walls strength test	37
7.7	External tightness test	37
7.8	Internal sealing test.....	38
7.9	Test method and acceptance criteria to verify the antistatic characteristics	38
7.10	Accuracy group	38
7.11	Response time.....	43
7.12	Relatching difference and unlatching	44
7.13	Verification of closing force	45
7.14	Endurance and accelerated ageing	45
7.15	Resistance to gas of non-metallic parts	45
7.16	Verification of the strength of the trip mechanism, valve seat and closing member against dynamic impact of flowing gas	45
7.17	Final visual inspection	46
8	Field surveillance	46
9	Documentation	47
9.1	Documentation related to type test	47
9.2	Documentation related to the routine tests.....	47
9.3	Documentation related to production surveillance in accordance with 6.6.....	47
9.4	Operating instructions.....	48
9.5	Information on sizing.....	48
10	Marking	49
10.1	General requirements.....	49
10.2	Basic requirements.....	49
10.3	Other additional requirements	49
10.4	Markings for the various connections.....	50
10.5	Identification of auxiliary devices	50
11	Packaging and transportation of finished product	50
Annex A (informative)	Ice formation.....	51
A.1	General	51
A.2	Requirements.....	51
A.3	Tests	51
Annex B (informative)	Compliance evaluation)	52
B.1	General	52
B.2	Introduction.....	52
B.3	Procedure	52
B.4	Manufacturer's compliance evaluation	53
B.5	Issue of the certificate of compliance	53
Annex C (informative)	Pressure drop and flow coefficient	54
C.1	Calculation method for pressure drop throughout the SSD.....	54
C.2	Test method for the determination of the flow coefficients	55
Annex D (normative)	Alternative test method for verification of the strength of the trip mechanism, valve seat and closing member.....	56

D.1	Test method	56
D.2	Test method for the determination of the dynamic factor C_T	56
D.3	Test method for a series of SSDs	57
Annex E (informative)	Sizing equation	59
Annex F (informative)	Inspection certificate	60
Annex G (informative)	Order specification	62
G.1	General	62
G.2	Minimum specifications	62
G.3	Optional specifications	63
Annex H (informative)	Acceptance test	64
Annex I (informative)	Suitability of safety shut-off device for damp operating conditions - Test procedure, requirement and acceptance criteria	65
Annex J (normative)	Vent limiter	66
J.1	General	66
J.2	Scope	66
J.3	Terms, symbols and definitions	66
J.4	Requirements	67
J.5	Testing and acceptance criteria	68
J.6	Documentation	69
J.7	Specific marking on vent limiter	69
Annex K (informative)	Glossary	70
Annex L (informative)	Environmental Provisions	73
Annex ZA (informative)	Relationship between this European Standard and the Essential Requirements of Directive 2014/68/EU aimed to be covered	76
Bibliography		78

European foreword

This document (EN 14382:2019) has been prepared by Technical Committee CEN/TC 235 “Gas pressure regulators and associated safety devices for use in gas transmission and distribution”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2020, and conflicting national standards shall be withdrawn at the latest by February 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14382:2005+A1:2009.

In comparison with the previous edition, the following technical modifications have been made:

- normative references have been updated;
- terms and definitions have been added;
- classification of two in series SSDs as safety accessory to PED;
- full reference to EN 334:2019 for end connections, flange rating, nominal and face to face dimensions, materials (metallic and non-metallic), verification of strength of pressure bearing parts;
- statistical strength test on the basis of PED provisions;
- antistatic characteristics;
- vent limiter as possible fixture to be assembled in the SSDs;
- integration of environmental requirements;
- alignment of normative references (Clause 2), Annex G, Annex ZA and its relevant clauses to CEN rules.

The standard has been editorially revised.

This document can be used as a guideline for gas safety shut off devices outside the ranges specified in this standard.

This edition has introduced the application of statistical strength testing for series produced pressure and safety accessories on the basis of EU Directive 2014/68/EU Annex I article 3.2.2 and Guideline H-14. Safety shut-off devices dealt with in this document are standard safety shut-off devices and, when used in pressure regulating stations complying with EN 12186 or EN 12279, they are considered as standard pressure equipment in accordance with Clause 2 a) of Art. 1 of Pressure Equipment Directive 2014/68/EU (PED).

For standard safety shut-off devices used in pressure regulating stations complying with EN 12186 or EN 12279, Table ZA.1 given in Annex ZA includes all applicable Essential Requirements given in Annex I of PED except external corrosion resistance for applications in corrosive environments.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Republic of North Macedonia, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This document specifies constructional, functional, testing marking and sizing requirements and documentation of gas safety shut-off devices:

- for inlet pressures up to 100 bar and nominal diameters up to DN 400;
- for an operating temperature range from $-20\text{ }^{\circ}\text{C}$ to $+60\text{ }^{\circ}\text{C}$;

which operate with fuel gases of the 1st and 2nd family as defined in EN 437, used in the pressure regulating stations in accordance with EN 12186 or EN 12279, in transmission and distribution networks and also in commercial and industrial installations.

“Gas safety shut-off devices” will hereafter be called “SSDs” except in titles.

For standard safety shut-off devices when used in pressure regulating stations complying with EN 12186 or EN 12279, Annex ZA lists all applicable Essential Safety Requirements of Directive 2014/68/EU (PED).

This document considers the following temperature classes/types of SSDs:

- temperature class 1: operating temperature range from $-10\text{ }^{\circ}\text{C}$ to $60\text{ }^{\circ}\text{C}$;
- temperature class 2: operating temperature range from $-20\text{ }^{\circ}\text{C}$ to $60\text{ }^{\circ}\text{C}$;
- functional class A: SSDs that close when damage to the pressure detecting element occurs or when external power fails and whose re-opening, is possible only manually;
- functional class B: SSDs that do not close when damage to the pressure detecting element occurs but provide suitable and reliable protection and whose re-opening, is possible only manually;
- type IS: (integral strength type);
- type DS: (differential strength type).

SSDs complying with the requirements of this document may be declared as “in conformity with EN 14382” and bear the mark “EN 14382”.

The material and functional requirements specified in this document may be applied to SSDs which use thermal energy or the effects of electrical energy to trip the operation of the closing member. For these SSDs the operational parameters are not specified in this document.

The SSD may incorporate a vent limiter, complying with the requirements in Annex J.

This standard for some paragraphs and sub clauses makes full reference to EN 334:2019.

This document does not apply to:

- SSDs upstream from/on/in domestic gas-consuming appliances which are installed downstream of domestic gas meters;
- SSDs designed to be incorporated into pressure-regulating devices used in service lines¹ with volumetric flow rate $\leq 200\text{ m}^3/\text{h}$ at normal conditions and inlet pressure $\leq 5\text{ bar}$.

¹ The service lines are those defined in EN 12279

Continued integrity of safety shut-off devices is ensured by periodic functional checks. For periodic functional checks it is common to refer to national regulations/standards where existing or users/manufacturers practices.

This document considers the reaction of the SSDs functional class A to the specified reasonable expected failures in terms of “fail close” behaviour, but it should be considered that there are other types of failures whose consequences cannot bring to the same reactions (these risks are covered via redundancy as per EN 12186) and that residual hazards should be reduced by a suitable surveillance in use / maintenance.

In this document, both safety shut-off devices that can be classified as “safety accessories” by themselves according to the Pressure Equipment Directive (2014/68/EU) as well as safety shut-off devices that can be used to provide the necessary pressure protection through redundancy (e.g. shutoff device integrated in a pressure regulator, shut-off device with a second shut-off device) are considered. Addition of environmental considerations;

The provisions in this document are in line with the state of art at the moment of writing.

This document does not intend to limit the improvement of actual provisions (materials, requirements, test methods, acceptance criteria, etc.) or the developing of new provisions for SSDs where they are suitable to ensure an equivalent level of reliability.

Some clauses of this standard should be re-considered at the time when characteristics for non-conventional gases will be available.

Gas safety shut-off devices according to this European standard do not have their own source of ignition and therefore are not within the scope of European Directive 2014/34/EU. Any additional component (e.g. proximity switch, travel transducer etc.) should be independently considered in the framework of assemblies per ATEX Guideline to the application of Directive 2014/34/EU of the European Parliament and of the Council of 26th February 2014, edition December 2017, §§42 and 43.

The document includes also environmental considerations.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 334:2019, *Gas pressure regulators for inlet pressures up to 100 bar*

EN 1092-1:2007+A1:2013, *Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, PN designated - Part 1: Steel flanges*

EN 1092-2:1997, *Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, PN designated - Part 2: Cast iron flanges*

EN 1092-3:2003, *Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, PN designated - Part 3: Copper alloy flanges*

EN 1092-4:2002, *Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, PN designated - Part 4: Aluminium alloy flanges*

EN 1349:2009, *Industrial process control valves*

EN 1759-1:2004, *Flanges and their joint - Circular flanges for pipes, valves, fittings and accessories, Class designated - Part 1: Steel flanges, NPS 1/2 to 24*

EN 1759-3:2003, *Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, Class designated - Part 3: Copper alloy flanges*

EN 1759-4:2003, *Flanges and their joint - Circular flanges for pipes, valves, fittings and accessories, class designated - Part 4: Aluminium alloy flanges*

EN 10204:2004, *Metallic products - Types of inspection documents*

EN 12186:2014, *Gas infrastructure - Gas pressure regulating stations for transmission and distribution - Functional requirements*

EN 12279:2000, *Gas supply systems - Gas pressure regulating installations on service lines - Functional requirements*

EN 13906-1:2013, *Cylindrical helical springs made from round wire and bar - Calculation and design - Part 1 : Compression springs*

EN 13906-2:2013, *Cylindrical helical springs made from round wire and bar - Calculation and design - Part 2: Extension springs*

EN 13906-3:2014, *Cylindrical helical springs made from round wire and bar - Calculation and design - Part 3: Torsion springs*

EN 60534-1:2005, *Industrial-process control valves - Part 1: Control valve terminology and general considerations*

ISO 7005-2:1998, *Metallic flanges — Part 2: Cast iron flanges*

3 Terms and definitions

For the purposes of this document, the following terms, definitions and symbols apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

NOTE Annex K lists all definitions and terms in alphabetic order for the English language, the relevant translation in French and German language and the relevant sub clause of this clause.

3.1 General terms and definition of type of gas safety shut-off devices

3.1.1

gas safety shut-off device

device whose function is to stay in the open position under normal operating conditions and to shut-off the gas flow automatically and completely when the monitored pressure exceeds the pre-set values (over-pressure monitoring and/or under-pressure monitoring)

3.1.2

direct acting gas shut-off device

SSD in which the pressure detecting element is directly connected to the trip mechanism

Note 1 to entry: See Figure 1.