
Ductile iron pipes and fittings — Seal coats for cement mortar linings

Tuyaux et raccords en fonte ductile — Seal coats pour les revêtements de mortier de ciment



This document is a preview generated by EBS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Performance test requirements	2
4.1 Short-term sealing efficiency.....	2
4.2 Long-term sealing efficiency.....	2
4.3 Cyclic pressure.....	2
5 Routine test requirements	3
5.1 General.....	3
5.2 Visual appearance.....	3
5.3 Coating thickness.....	3
5.4 Adhesion.....	3
6 Marking	3
Annex A (normative) Short-term sealing efficiency	4
Annex B (normative) Long-term sealing efficiency	6
Annex C (normative) Cyclic pressure test	10
Annex D (normative) Coating thickness measurement using test film	12
Annex E (normative) Adhesion test	14
Bibliography	16

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 5, *Ferrous metal pipes and metallic fittings*, Subcommittee SC 2, *Cast iron pipes, fittings and their joints*.

This second edition cancels and replaces the first edition (ISO 16132:2004), of which it constitutes a minor revision.

Introduction

The intended purpose of a seal coat is to reduce the contact between a cement mortar lining and the contents of a water main, thereby restricting the leaching of inorganic materials into the water supply.

Seal coats are usually specified where the pipeline is to convey soft waters and/or where residence times are very long. Supply water quality data for such pipelines should be discussed between the prospective client and the seal coated pipe supplier to ensure the suitability of the product for use.

Attention is drawn to the fact that seal coated cement mortar lined surfaces in contact with, or likely to come into contact with, potable water need to conform to the requirements of national or international water supply or water quality regulations. Approval may be required for the individual components of the system, or for the combined system, depending upon the requirements of those national or international water supply or water quality regulations when used

- in accordance with the product manufacturer's instructions for use, and
- under any other appropriate conditions defined for that product within any published list of substances, products and processes approved to those water supply or water quality regulations.

Ductile iron pipes and fittings — Seal coats for cement mortar linings

1 Scope

This International Standard specifies the requirements for seal coatings for factory application to the surfaces of cement mortar linings, which are factory applied to the interior of ductile iron pipes and fittings.

It provides the performance requirements for short-term sealing efficiency, long-term durability and cyclic pressure, as well as the routine testing requirements for visual appearance, coating thickness and adhesion.

This International Standard is applicable to products for potable and other water applications.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 2439, *Flexible cellular polymeric materials — Determination of hardness (indentation technique)*

ISO 2808, *Paints and varnishes — Determination of film thickness*

ISO 10523, *Water quality — Determination of pH*

ASTM D 3330, *Standard Test Method for Peel Adhesion of Pressure-Sensitive Tape*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

ductile iron

type of cast iron used for pipes, fittings and accessories in which graphite is present primarily in spheroidal form

3.2

fitting

casting other than a pipe, which allows pipeline deviation or change of direction or bore

Note 1 to entry: Flanged sockets, flanged spigots and collars are also classified as fittings.

3.3

test film

film of consistent thickness and density, morphologically stable at the temperature of the substrate during seal coat application, used as a surrogate surface for the measurement of coating thicknesses

3.4

pipe

casting of uniform bore, with straight axis, having either socket, spigot or flanged ends

Note 1 to entry: This does not apply to flanged sockets or flanged spigots and collars, which are classified as fittings.