

TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-3: Using IEC 61850 for condition monitoring diagnosis and analysis**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-3: Using IEC 61850 for condition monitoring diagnosis and analysis**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-3318-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	9
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references.....	13
3 Terms, definitions, abbreviations, acronyms and conventions	13
3.1 Terms and definitions	13
3.2 Abbreviations, acronyms and conventions.....	14
4 Use cases	32
5 GIS (Gas Insulated Switchgear)	32
5.1 Summary	32
5.2 GIS overview	33
5.3 GIS use case diagrams	34
5.3.1 Gas compartments.....	34
5.3.2 Circuit breaker and switches	38
5.3.3 Operating mechanism	42
5.3.4 Monitoring issues for POW (Point-on-wave switching controller).....	49
5.4 Preliminary modelling approach.....	53
5.4.1 GIS data modelling example.....	53
5.4.2 GIS gas modelling.....	53
5.4.3 Circuit breaker modelling.....	54
5.4.4 Switches modelling	55
5.4.5 PD monitoring by UHF method	55
6 Power transformer	56
6.1 Summary	56
6.2 Transformer overview.....	56
6.3 Transformer CMD use case diagram.....	57
6.3.1 Dissolved gas and moisture in oil supervision	57
6.3.2 Partial discharge (PD) supervision.....	59
6.3.3 Temperature supervision.....	61
6.3.4 Solid insulation aging supervision.....	63
6.3.5 Bubbling temperature supervision.....	66
6.3.6 Bushing supervision	67
6.3.7 Cooling supervision.....	69
6.3.8 Ancillary sensors supervision	72
6.4 Preliminary modelling approach.....	74
6.4.1 Dissolved gas and moisture in oil supervision	74
6.4.2 Partial discharge (PD) supervision.....	75
6.4.3 Transformer supervision.....	75
6.4.4 Solid insulation aging supervision.....	75
6.4.5 Bubbling temperature supervision (use SIML)	75
6.4.6 Bushing supervision	76
6.4.7 Cooling supervision.....	76
6.4.8 Ancillary sensors supervision	76
7 Load tap changer (LTC).....	76
7.1 Summary	76

7.2	Load tap changer overview	77
7.3	Constraints/assumptions/design considerations	77
7.4	Data flow	79
7.5	Use case diagram	80
7.5.1	Monitoring LTC operation properties	81
7.5.2	Monitoring LTC operation counts	83
7.5.3	Monitoring contact abrasion	84
7.5.4	Monitoring LTC oil temperature and flow	86
7.5.5	Monitoring operation of oil filter unit	88
7.6	Data description table	89
7.6.1	Monitoring operation property	89
7.6.2	Monitoring operation counts	91
7.6.3	Monitoring contact abrasion	92
7.6.4	Monitoring LTC oil temperature and flow	92
7.6.5	Monitoring operation of oil filter unit	93
8	Underground cable (UGC)	94
8.1	Summary	94
8.2	Underground cable overview	94
8.2.1	General	94
8.2.2	XLPE (cross-linked polyethylene insulated) cable	94
8.2.3	OF (Oil Filled) cable	95
8.3	Constraints/assumptions/design considerations	95
8.4	Data flow	95
8.5	Use case diagram	97
8.5.1	General	97
8.5.2	Thermal aging supervision	97
8.5.3	Supervision of cable parts cracking	98
8.5.4	Insulation aging supervision	101
8.5.5	Water-tree supervision	102
8.5.6	Supervision of earth fault without circuit breaker trip	104
8.5.7	Oil aging supervision	106
8.5.8	Oil leak supervision	107
8.6	Data description table	109
8.6.1	Sensor items held in existing LNs	109
8.6.2	Sensor items requiring a new LN	109
8.6.3	Supervising items held in existing LNs	110
8.6.4	Supervising items requiring new DO's in an existing LN	110
8.6.5	Supervising items requiring a new LN	110
9	Transmission line (TL)	110
9.1	Summary	110
9.2	Transmission line overview	111
9.2.1	Overhead transmission line (OHTL)	111
9.2.2	Line sensor unit	112
9.3	TL CMD use case diagram	113
9.3.1	Line condition supervisor	113
9.3.2	Tower condition supervisor	114
9.3.3	Insulator condition supervisor	116
9.3.4	Surrounding area supervisor	118
9.4	Data description table	121

10	Auxiliary power system	121
10.1	Summary	121
10.2	Auxiliary power system overview	122
10.2.1	General	122
10.2.2	Legend of diagrams	122
10.2.3	Secured DC system from AC input power	122
10.2.4	Secured AC system from DC input with AC backup	123
10.2.5	Secured AC system from AC input with AC backup	123
10.3	Data flow	124
10.4	Use case diagram	124
10.5	Data modelling	126
10.5.1	Functional breakdown	126
11	Communication Requirements	128
11.1	General issues	128
11.2	Response behaviour requirements (6.4 of IEC 61850-5:2013)	129
11.3	Requirements for data integrity (Clause 14 of IEC 61850-5:2013)	129
11.4	Communication requirements for the WAN	129
11.5	Performance issue	130
11.6	Plug and Play	130
12	Asset Management	130
12.1	Definition	130
12.2	Comparison of asset management to other systems	130
12.3	IEC 61850 services for Asset Management	131
12.3.1	General	131
12.3.2	Data set	132
12.3.3	Log	132
12.3.4	Report	132
12.3.5	Polling	133
12.3.6	SCSM	133
12.4	CMD	133
12.5	Conclusion	133
12.6	Maintenance	133
12.7	ERP Update	136
13	Logical node classes	139
13.1	General	139
13.2	Abstract Logical Nodes (AbstractLNs_90_3)	140
13.2.1	General	140
13.2.2	<<abstract>> LN: Battery Charger Name: BatteryChargerLN	141
13.3	Logical nodes for tanks (LNGroupK)	143
13.3.1	General	143
13.3.2	LN: Tank Name: KTNKExt	145
13.3.3	LN: Tower Name: KTOW	146
13.4	Logical nodes for metering and measurement (LNGroupM)	147
13.4.1	General	147
13.4.2	LN: Meteorological information Name: MMETExt	148
13.5	Logical nodes for supervision and monitoring (LNGroupS)	150
13.5.1	General	150
13.5.2	LN: Battery Name: SBAT	153

13.5.3	LN: Circuit breaker supervision Name: SCBRExt.....	155
13.5.4	LN: Cooling Group Supervision Name: SCGR.....	156
13.5.5	LN: Equipment Ageing Model Name: SEAM.....	158
13.5.6	LN: Fire Supervision Name: SFIR.....	159
13.5.7	LN: Insulation medium supervision (liquid) Name: SIMLExt.....	160
13.5.8	LN: Insulation moisture supervision (solid) Name: SIMS.....	165
13.5.9	LN: Tap changer supervision Name: SLTCExt.....	167
13.5.10	LN: Power Transformer supervision Name: SPTRExt.....	169
13.5.11	LN: Saturation temperature supervision Name: SSTP.....	171
13.6	Logical nodes for instrument transformers and sensors (LNGroupT).....	172
13.6.1	General.....	172
13.6.2	LN: Density Sensor Name: TDEN.....	173
13.6.3	LN: Torque Name: TTRQ.....	174
13.6.4	LN: UHF Sensor Name: TUHF.....	175
13.7	Logical nodes for power transformers (LNGroupY).....	176
13.7.1	General.....	176
13.7.2	LN: Power Transformer Supervision Name: YPTRExt.....	177
13.8	Logical nodes for further power system equipment (LNGroupZ).....	179
13.8.1	General.....	179
13.8.2	LN: Auxiliary network Name: ZAXNExt.....	182
13.8.3	LN: Battery Name: ZBATExt.....	183
13.8.4	LN: Bushing Name: ZBSHExt.....	185
13.8.5	LN: Battery Charger Name: ZBTC.....	186
13.8.6	LN: Power cable Name: ZCABExt.....	187
13.8.7	LN: Converter Name: ZCONExt.....	189
13.8.8	LN: Generator Name: ZGENExt.....	190
13.8.9	LN: Power overhead line Name: ZLINEExt.....	192
13.8.10	LN: UPS (Uninterruptable Power Supply) Name: ZUPS.....	194
14	Data object name semantics and enumerations.....	196
14.1	Data semantics.....	196
14.2	Enumerated data attribute types.....	204
14.2.1	General.....	204
14.2.2	BatteryChargerType90_3Kind enumeration.....	204
14.2.3	BatteryTestResult90-3Kind enumeration.....	205
14.2.4	BatteryType90_3Kind enumeration.....	205
14.2.5	ChargerOperationKind enumeration.....	205
14.2.6	ExternalDeviceModeKind enumeration.....	206
14.2.7	OperationFailureModeKind enumeration.....	206
14.2.8	SystemOperationModeKind enumeration.....	206
15	SCL enumerations (from DOEnums_90_3).....	207
Annex A (informative) Usage of “T” logical node and “S” logical node in CMD application.....		209
Bibliography.....		210
Figure 1 – CMD Modelling Concept.....		32
Figure 2 – GIS CMD Overview.....		34
Figure 3 – GIS use case diagram.....		35
Figure 4 – Abrasion monitoring use case.....		39

Figure 5 – Switch monitoring use case	41
Figure 6 – Operating mechanism monitoring use case	43
Figure 7 – Maintenance planning use case	48
Figure 8 – CB operating time monitoring use case	50
Figure 9 – GIS internal structure	53
Figure 10 – Example of 3 phases compartment modelling	54
Figure 11 – Example of 3 phases CB modelling	54
Figure 12 – Example of 3 phases switch modelling	55
Figure 13 – Example of PD monitoring modelling	55
Figure 14 – Transformer principle	56
Figure 15 – Typical power transformer	57
Figure 16 – Use case for oil supervision	58
Figure 17 – Partial discharge (PD) use case	60
Figure 18 – Use case for temperature supervision	62
Figure 19 – Use case for solid insulation aging supervision	64
Figure 20 – Use case for bubbling temperature supervision	66
Figure 21 – Use case for bushing supervision	68
Figure 22 – Use case for cooling supervision	70
Figure 23 – Use case for ancillary sensors supervision	73
Figure 24 – Structure of load tap changer	77
Figure 25 – Configuration of LTC CMD system	78
Figure 26 – Data flows for LTC CMD (part 1)	79
Figure 27 – Data flows for LTC CMD (part 2)	80
Figure 28 – Data flows for LTC CMD (part 3)	80
Figure 29 – Use case for monitoring LTC operation properties	81
Figure 30 – Use case for monitoring LTC operation counts	83
Figure 31 – Use case for monitoring contact abrasion	84
Figure 32 – Use case for monitoring LTC oil temperature and flow	86
Figure 33 – Use case for monitoring operation of oil filter unit	88
Figure 34 – An online system monitoring OF (Oil Filled) cable conditions	94
Figure 35 – Cable cross-section drawing	95
Figure 36 – Supervisions of UGC and their data flows	96
Figure 37 – Supervisions of OF cables and their data flows	97
Figure 38 – Use case for thermal aging supervision	97
Figure 39 – A sensor detecting cable positions in 3 dimensions	99
Figure 40 – Use case for supervision of cable parts cracking	99
Figure 41 – Use case for insulation aging supervision	101
Figure 42 – Use case for water-tree supervision	102
Figure 43 – Use case for supervision of earth fault without circuit breaker trip	104
Figure 44 – Use case for oil aging supervision	106
Figure 45 – Use case for oil leak supervision	107
Figure 46 – Example configuration of OHTL tower cluster	112
Figure 47 – Line sensor unit	112

Figure 48 – Use case for line condition supervisor	113
Figure 49 – Use case for tower condition supervisor	115
Figure 50 – Use case for insulator condition supervisor	117
Figure 51 – Use case for surrounding area supervisor	119
Figure 52 – Legend of diagrams	122
Figure 53 – Secured DC system from AC input power	123
Figure 54 – Secured AC system from DC input with AC backup	123
Figure 55 – Secured AC system from AC input with AC backup.....	124
Figure 56 – Data flow of auxiliary power system	124
Figure 57 – Use case for auxiliary power system	125
Figure 58 – Secured DC system from AC input power	127
Figure 59 – Secured AC system from DC input with AC backup	127
Figure 60 – Secured AC system from AC input with AC backup.....	128
Figure 61 – Communication architecture for CMD	129
Figure 62 – Reporting and logging model (conceptual) from IEC 61850-7-1.....	132
Figure 63 – Use case for maintenance	134
Figure 64 – Use case for ERP update.....	137
Figure 65 – Class diagram LogicalNodes_90_3::LogicalNodes_90_3	140
Figure 66 – Class diagram AbstractLNs_90_3::AbstractLNs_90_3	141
Figure 67 – Class diagram LNGroupK::LNGroupK	144
Figure 68 – Class diagram LNGroupM::LNGroupM	148
Figure 69 – Class diagram LNGroupS::LNGroupS1	151
Figure 70 – Class diagram LNGroupS::LNGroupS2.....	152
Figure 71 – Class diagram LNGroupT::LNGroupT	173
Figure 72 – Class diagram LNGroupY::LNGroupY	177
Figure 73 – Class diagram LNGroupZ::LNGroupZ1	180
Figure 74 – Class diagram LNGroupZ::LNGroupZ2	181
Figure 75 – Class diagram DOEnums_90_3::DOEnums_90_3.....	204
Figure A.1 – Decomposition of functions into interacting LN on different levels: Examples for generic function with tele control interface, protection function and measuring/metering function (from IEC 61850-5:2003)	209
Table 1 – Normative abbreviations for data object names	14
Table 2 – Data objects of BatteryChargerLN.....	142
Table 3 – Data objects of KTNKExt	145
Table 4 – Data objects of KTOW	146
Table 5 – Data objects of MMETExt	149
Table 6 – Data objects of SBAT	154
Table 7 – Data objects of SCBRExt.....	155
Table 8 – Data objects of SCGR.....	157
Table 9 – Data objects of SEAM.....	158
Table 10 – Data objects of SFIR.....	160
Table 11 – Data objects of SIMLExt	161
Table 12 – Data objects of SIMS	166

Table 13 – Data objects of SLTCEExt.....	167
Table 14 – Data objects of SPTRExt	170
Table 15 – Data objects of SSTP.....	171
Table 16 – Data objects of TDEN	174
Table 17 – Data objects of TTRQ	175
Table 18 – Data objects of TUHF	176
Table 19 – Data objects of YPTRExt	178
Table 20 – Data objects of ZAXNExt	182
Table 21 – Data objects of ZBATExt.....	183
Table 22 – Data objects of ZBSHExt	185
Table 23 – Data objects of ZBTC.....	186
Table 24 – Data objects of ZCABExt	188
Table 25 – Data objects of ZCONExt.....	190
Table 26 – Data objects of ZGENExt	191
Table 27 – Data objects of ZLINExt.....	193
Table 28 – Data objects of ZUPS	195
Table 29 – Attributes defined on classes of LogicalNodes_90_3 package.....	196
Table 30 – Literals of BatteryChargerType90_3Kind	204
Table 31 – Literals of BatteryTestResult90-3Kind	205
Table 32 – Literals of BatteryType90_3Kind	205
Table 33 – Literals of ChargerOperationKind	206
Table 34 – Literals of ExternalDeviceModeKind	206
Table 35 – Literals of OperationFailureModeKind	206
Table 36 – Literals of SystemOperationModeKind.....	207

generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND
SYSTEMS FOR POWER UTILITY AUTOMATION –****Part 90-3: Using IEC 61850 for condition monitoring
diagnosis and analysis**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61850-90-3, which is a technical report, has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
57/1522/DTR	57/1654/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The CMD (Condition Monitoring Diagnosis) which diagnoses power grid health status has been one of the major issues to improve the reliability of the power system by preventing a potential failure in advance. Since too many different information modelling, information exchange, and configuration techniques for CMD in various forms from many vendors are currently used, they need to be standardized within the IEC.

IEC 61850 is intended to be used to communicate with the condition monitoring equipment. A seamless communication with the sensor network is also desirable.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-3: Using IEC 61850 for condition monitoring diagnosis and analysis

1 Scope

Since the outcome of this work will affect several parts of IEC 61850, in a first step, this technical report has been prepared to address the topic from an application specific viewpoint across all affected parts of IEC 61850. This approach is similar to what is done as an example with IEC 61850-90-1 for the communication between substations. Once this technical report has been approved, the affected parts of the standard will be amended with the results from the report.

The major part of the work will consist in defining new logical nodes that contain the information for condition monitoring. It is important that the existing standards are analyzed with regard to information that is already available today. The information available in these logical nodes can as well be useful for asset management systems.

Another important aspect is a homogenous modelling approach that is to be used as well by other domains with a similar scope. Therefore, this technical report will include a chapter that describes the basic modelling approach that was used.

This technical report will address communication aspects related to specific sensor networks that are widely used as well as information exchange towards asset management systems where the IEEE PC37.239 is applicable, but it is not specific for the Condition Based Monitoring.

Several IEC technical committees cooperate to achieve harmonized (unified) models for CMD applications. Other areas of IEC work affected by the information contained in this technical report are: Overhead lines; Power transformers; Switchgear and controlgear; Electrical cables; Instrument transformers; and Wind turbines.

The parameters which are identifying this new namespace are:

- Namespace Version: 2015
- Namespace Revision: A
- UML model file which reflects this namespace edition: wg10uml02v18a-wg18uml02v11b-wg17uml02v17c-jwg25uml02v04c.eap, UML model version WG10UML02v18
- Namespace release date: 2015-10-05
- Namespace name: "(Tr)IEC61850-90-3:A"

The namespace "(Tr)IEC61850-90-3:A" is considered as "transitional" since the models are expected to be included in next editions of IEC 61850-7-4xx International Standards (IS). Potential extensions/modifications may happen if/when the models are moved to the International Standard status. Only the new data objects and CDCs which are not said to be inherited from existing LNs will be tagged with this namespace name. The others should still refer to the namespace where they are primarily defined."

Clauses 13 through 15 and their subclauses including XML enumerations are automatically generated from the UML model.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TS 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-5:2013, *Communication networks and systems for power utility automation – Part 5: Communication requirements for functions and devices models 3*

IEC 61850-7-2:2010, *Communication networks and systems for power utility automation – Part 7-2: Basic communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-4:2010, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

IEC 62271-203:2011, *High-voltage switchgear and controlgear – Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

3 Terms, definitions, abbreviations, acronyms and conventions

3.1 Terms and definitions

For the purposes of this document, the terms and definitions provided in IEC TS 61850-2 and the following apply.

3.1.1

sensor

device that measures a physical quantity and converts it into a (digital) signal which can be read by an observer or by an instrument.

3.1.2

expert system

computer that contains the knowledge and analytical skills of one or more human experts, related to a specific subject

3.1.3

water tree

phenomenon that could lead to insulation degradation or breakdown by penetration of water or foreign materials into cable jacket

3.1.4

line sensor unit

sensor unit composed of current, temperature, and wind, etc. to supervise the overhead line

3.1.5

cable

a bundle of insulated wires through which an electric current can be passed. Cable types are gas, oil, solid state, etc.

3.1.6

overhead line

wire through which an electric current can be passed