

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electricity metering data exchange – The DLMS/COSEM suite –
Part 7-5: Local data transmission profiles for Local Networks (LN)**

**Échange des données de comptage de l'électricité – La suite DLMS/COSEM –
Partie 7-5: Profils de transmission de données locales pour réseaux locaux (LN)**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electricity metering data exchange – The DLMS/COSEM suite –
Part 7-5: Local data transmission profiles for Local Networks (LN)**

**Échange des données de comptage de l'électricité – La suite DLMS/COSEM –
Partie 7-5: Profils de transmission de données locales pour réseaux locaux (LN)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220.20; 35.100.01; 91.140.50

ISBN 978-2-8322-3326-9

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	10
3 Terms, definitions and abbreviations	11
3.1 Terms and definitions	11
3.2 Abbreviations	11
4 Targeted communication environments	11
5 Use of the communication layers for these profiles	12
5.1 Information related to the use of the standards specifying the lower layers	12
5.2 Structure of the profile.....	12
5.3 Use of the lower layers.....	13
5.3.1 Overview	13
5.3.2 Physical layer	14
5.3.3 MAC layer.....	14
5.3.4 Data link layer.....	14
5.4 Service mapping and adaptation layers.....	14
5.4.1 For the default HDLC based data link layer.....	14
5.4.2 For other lower layers	15
5.5 Registration and connection management.....	15
6 Identification and addressing scheme.....	15
6.1 General identification and addressing scheme	15
6.2 Addressing for the default HDLC based data link layer.....	15
6.3 Addressing for other data link layers.....	15
7 Specific considerations for the application layer services.....	15
7.1 Overview	15
7.2 Application Association establishment and release: ACSE services.....	15
7.3 xDLMS services	15
7.4 Security mechanisms	16
7.5 Transferring long application messages.....	16
7.6 Media access, bandwidth and timing considerations.....	16
8 Communication layer configuration and management	17
9 The COSEM application process (AP).....	17
9.1 Model and services	17
9.2 COSEM interface classes (IEC 62056-6-2) to configure the LDTI	18
9.3 Security environment (not valid for legacy mode)	19
9.4 Restrictions for interfaces supporting “Legacy operating modes”	20
10 Additional considerations for the use of this profile – Safety	21
Annex A (normative) Media specific profile: Optical interface	22
A.1 IEC 62056-21 port.....	22
A.2 IEC 62056-21 port operating in legacy mode.....	23
Annex B (normative) Media specific Profile: TP with carrier signalling Interface.....	25
B.1 IEC 62056-3-1 port.....	25
B.2 IEC 62056-3-1 port operating in legacy mode	26
Annex C (normative) Media specific profile: EIA-485, TIA-232-F interface	29

C.1 Electrical port RS485/232	29
Annex D (normative) Media specific profile: M-Bus EN 13757-2	31
D.1 M-Bus with the HDLC based data link layer	31
Annex E (normative) IP profile	33
E.1 IP profile	33
Annex F (informative) LDTI configuration examples	35
F.1 Example 1: only one value (active energy A+) pushed	35
Annex G (informative) LDTI encoding examples	37
G.1 xDLMS APDUs used (without protection and without general-block-transfer)	37
G.2 Example 1: Only one value is pushed	37
G.3 Example 2: The OBIS code and one value is pushed	38
Index	40
Figure 1 – LDTI DLMS/COSEM client as part of a consumer device	9
Figure 2 – LDTI DLMS/COSEM client as part of a local adaptor	9
Figure 3 – Entities and interfaces of a smart metering system	12
Figure 4 – IEC 62056-7-5 LDTI interface in the context of the smart metering architecture	12
Figure 5 – Local data transmission reference model	13
Figure 6 – LDTI – the interface to a pre-established DLMS/COSEM LDTI client	18
Figure 7 – Interface classes modelling the push operation	19
Figure 8 – Example of a security environment for an LDTI using global keys	20
Figure 9 – LDTI – operating in “legacy mode”	21
Figure A.1 – Structure of the optical interface profile	22
Figure A.2 – Structure of the optical interface – “operating in legacy mode” – profile	24
Figure B.1 – Structure of the TP with carrier signalling profile	25
Figure B.2 – Structure of the TP with carrier signalling – “operating in legacy mode” – profile	27
Figure C.1 – Structure of the RS485/232 profile	29
Figure D.1 – Structure of the “M-Bus with HDLC based data link layer” profile	31
Figure E.1 – Structure of the IP profile	33
Table 1 – Features of communication profiles using DLMS/COSEM compatible and legacy protocol modes	9
Table 2 – Conformance block for the LDTI association	16
Table 3 – Configuration of a LDTI operating in “legacy mode”	20
Table A.1 – Mandatory setup attribute values for an optical IEC 62056-21 interface supporting IEC 62056-5-3	23
Table A.2 – Mandatory setup attribute values for an optical IEC 62056-21 operating in the “legacy mode”	24
Table B.1 – Mandatory setup attribute values for a TP IEC 62056-3-1 supporting IEC 62056-5-3	26
Table B.2 – Mandatory setup attribute values for a TP IEC 62056-3-1 operating in the “legacy mode”	28
Table C.1 – Mandatory setup attribute values for an electrical RS485/232 IEC 62056-21 interface supporting IEC 62056-5-3	30

Table D.1 – Mandatory setup attribute values for an M-Bus port with HDLC based data link layer.....	32
Table E.1 – Mandatory setup attribute values for an IP port	34
Table F.1 – Configuration example: one value pushed every 10 s via optical port.....	35

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICITY METERING DATA EXCHANGE –
THE DLMS/COSEM SUITE –****Part 7-5: Local data transmission profiles for Local Networks (LN)****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this International Standard may involve the use of a maintenance service concerning the stack of protocols on which the present standard IEC 62056-7-5 is based.

The IEC takes no position concerning the evidence, validity and scope of this maintenance service.

The provider of the maintenance service has assured the IEC that he is willing to provide services under reasonable and non-discriminatory terms and conditions for applicants throughout the world. In this respect, the statement of the provider of the maintenance service is registered with the IEC. Information may be obtained from:

DLMS User Association
Zug/Switzerland
www.dlms.com

International Standard IEC 62056-7-5 has been prepared by technical committee 13: Electrical energy measurement and control.

The text of this standard is based on the following documents:

CDV	Report on voting
13/1605/CDV	13/1650/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62056 series, published under the general title *Electricity metering data exchange – The DLMS/COSEM suite*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

As defined in IEC 62056-1-0, the IEC 62056 DLMS/COSEM suite provides specific communication profile standards for communication media relevant for smart metering.

Such communication profile standards specify how the COSEM data model and the DLMS/COSEM application layer can be used on the lower, communication media-specific protocol layers.

Communication profile standards refer to communication standards that are part of the IEC 62056 DLMS/COSEM suite or to any other open communication standard.

This International Standard specifies DLMS/COSEM communication profiles for transmitting metering data modelled by COSEM interface objects through Local Data Transmission Interfaces (LDTI). The LDTI may be part of a meter or of a Local Network Access Point (LNAP) hosting a DLMS/COSEM server.

The specification of the communication profiles follows the rules defined in IEC 62056-5-3:2016, Annex A.

A major driver for the introduction of smart metering is to provide the consumer with suitable metering information to optimise his/her energy consumption and/or production. For that purpose, smart meters are equipped with local interfaces providing metering data for the consumer on consumer devices.

IEC 62056-21 and IEC 62056-3-1 are communication standards that specify direct local data exchange and data exchange through local networks. They provide protocol modes that support the DLMS/COSEM application layer and thus the COSEM object model. They also specify legacy modes that do not support the DLMS/COSEM application layer.

In order to allow connecting legacy consumer equipment to the LDTI, this International Standard also specifies communication profiles using protocol modes that do not support the DLMS/COSEM application layer.

It is assumed, however, that in all cases the metering application is modelled by COSEM interface objects.

It is also assumed that the meter has interfaces that fully support DLMS/COSEM and allow the configuration of the local data transmission interface by a DLMS/COSEM client.

The requirements on the physical type of the interface, the choice of the data transmitted and the transmitting pattern highly depends on the markets and projects the meter is designed for.

ELECTRICITY METERING DATA EXCHANGE – THE DLMS/COSEM SUITE –

Part 7-5: Local data transmission profiles for Local Networks (LN)

1 Scope

This part of IEC 62056 specifies DLMS/COSEM communication profiles for transmitting metering data modelled by COSEM interface objects through a Local Data Transmission Interface (LDTI). The LDTI may be part of a meter or of a Local Network Access Point (LNAP) hosting a DLMS/COSEM server.

The main body of this standard specifies the common aspects of the different communication profiles for the LDTI interface.

The Annexes specify the communication protocol specific elements. The Annexes form an integral part of this International Standard.

Annex A (normative) specifies a communication profile using the protocol specified in IEC 62056-21. Clause A.1 specifies the communication profile that supports the DLMS/COSEM application layer and Clause A.2 specifies the communication profile using the legacy Mode D. The physical interface is the optical interface specified in IEC 62056-21:2002, 4.3.

Annex B (normative) specifies a communication profile using the protocol specified in IEC 62056-3-1. Clause B.1 specifies the communication profile that supports the DLMS/COSEM application layer and Clause B.2 specifies the communication profile using the legacy mode. The physical interface is twisted pair using carrier signalling known as the Euridis Bus.

Annex C (normative) specifies a communication profile based on the DLMS/COSEM 3-layer, connection oriented HDLC based profile specified in IEC 62056-7-6. The physical interface is RS 485 or TIA-232-F.

Annex D (normative) specifies a communication profile using the physical layer specified in EN 13757-2 and the HDLC based data link layer specified in IEC 62056-46. The physical interface is twisted pair with baseband signalling.

Annex E (normative) specifies a communication profile using UDP/IP. The physical layer is out of the scope of this International Standard.

The communication profiles in Clauses A.1, B.1, and Annexes C, D and E support the DLMS/COSEM application layer.

Annex F (informative) specifies an LDTI configuration example.

Annex G (informative) provides encoding examples.

Additional communication profiles for other media/communication protocols may be added in the future.

Table 1 shows the features of communication profiles using DLMS/COSEM compatible and legacy protocol modes.

Table 1 – Features of communication profiles using DLMS/COSEM compatible and legacy protocol modes

Feature	Communication profiles supporting	
	DLMS/COSEM compatible modes	Legacy modes
Application model	COSEM interface objects; any attribute value can be transmitted	COSEM interface objects; a limited set of attribute values can be transmitted
Data formats	A-XDR encoded	Protocol specific (typically ASCII strings)
DLMS/COSEM application layer support	Yes (xDLMS APDUs)	No
Cryptographic protection	COSEM attributes and COSEM APDUs	Out of scope (protocol specific)
Data transmission triggers	Time or event based, controlled by COSEM interface objects. Refresh rate can support time-critical applications.	Time or event based. Interface specific restrictions may apply.

The consumer device may directly support the LDTI communication protocol and data formats. In this case the LDTI DLMS/COSEM client is part of the consumer device as shown in Figure 1.

When the consumer device does not support the LDTI communication protocol and data formats then a local adaptor is necessary converting the communication medium and protocol of the LDTI to the communication means of the consumer device. In this case, the local adaptor may be part of the meter or LNAP as shown in Figure 2. The local adaptor and the data exchange between the local adaptor and the consumer device are out of the scope of this International Standard.

This difference is not relevant for this standard, so the arrangement shown in Figure 1 is assumed.

The consumer device is also out of the scope of this International Standard.



Figure 1 – LDTI DLMS/COSEM client as part of a consumer device




Figure 2 – LDTI DLMS/COSEM client as part of a local adaptor

The scope of these communication profiles is restricted to aspects concerning the use of communication protocols in conjunction with the DLMS/COSEM data models. Data structures specific to a communication protocol should be defined in the specific protocol standards. Any project specific definitions of data structures and data contents shall be provided in project specific companion specifications.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-300, *International Electrotechnical Vocabulary – Electrical and electronic measurements and measuring instruments – Part 311: General terms relating to measurements – Part 312: General terms relating to electrical measurements – Part 313: Types of electrical measuring instruments – Part 314: Specific terms according to the type of instrument*

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*
Amendment 1:2009
Amendment 2:2013

IEC TR 62051, *Electricity metering – Glossary of terms*

IEC TR 62051-1, *Electricity metering – Data exchange for meter reading, tariff and load control – Glossary of terms – Part 1: Terms related to data exchange with metering equipment using DLMS/COSEM*

IEC 62052-31 *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests*

IEC 62056-1-0, *Electricity metering data exchange – The DLMS/COSEM suite – Part 1-0: Smart metering standardization framework*

IEC 62056-21:2002, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 21: Direct local data exchange*

IEC 62056-3-1:2013, *Electricity metering data exchange – The DLMS/COSEM suite – Part 3-1: Use of local area networks on twisted pair with carrier signalling*

IEC 62056-46: 2002, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 46: Data link layer using HDLC protocol*
Amendment 1:2006

IEC 62056-4-7:2015, *Electricity metering data exchange – The DLMS/COSEM suite – Part 4-7: DLMS/COSEM transport layer for IP networks*

IEC 62056-5-3:2016, *Electricity metering data exchange – The DLMS/COSEM suite – Part 5-3: DLMS/COSEM application layer*

IEC 62056-6-1:2015, *Electricity metering data exchange – The DLMS/COSEM suite – Part 6-1: Object Identification System (OBIS)*

IEC 62056-6-2:2016, *Electricity metering data exchange – The DLMS/COSEM suite – Part 6-2: COSEM interface classes*

IEC 62056-9-7, *Electricity metering data exchange – The DLMS/COSEM suite – Part 9-7: Communication profile for TCP-UDP/IP networks*

ISO/IEC 13239:2002, *Information technology – Telecommunications and information exchange between systems – High-level data link control (HDLC) procedures*

EN 13757-2, *Communication systems for and remote reading of meters – Part 2: Physical and link layer*

3 Terms, definitions and abbreviations

For the purposes of this document, the terms and definitions in IEC 60050-300, IEC TR 62051, IEC TR 62051-1 as well as the following apply.

NOTE Where there is a difference between the definitions in the glossary and those contained in product standards produced by TC 13, then the latter take precedence in applications of the relevant standard.

3.1 Terms and definitions

3.1.1

communication medium

physical medium to transmit signals carrying information

3.1.2

Local Data Transmission Interface

LDTI

interface providing data at the location of the DLMS/COSEM server device

3.2 Abbreviations

AA	Application Association
AARE	A-Associate Response – an APDU of the ACSE
AARQ	A-Associate Request – an APDU of the ACSE
AP	Application Process
LDTI	Local Data Transmission Interface
Sys-T	System Title as defined in IEC 62056-5-3:2016

4 Targeted communication environments

This clause identifies the communication environment(s), for which the communication profiles are specified.

Figure 4 shows the LDTI in the context of the smart metering architecture introduced in IEC 62056-1-0. Typically the LDTI is part of the metering device and therefore covers the H1 interface.

NOTE The data transmitted via the LDTI is generic enough to support any consumer application; i.e. it is not limited to „Simple Consumer Displays“.

However, it is also possible that the LDTI becomes part of an LNAP supporting the H2 interface as shown in Figure 3 and Figure 4. For both cases the scope as defined in Clause 1