

Information technology - Data centre facilities and
infrastructures - Part 4-3: Renewable Energy Factor

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50600-4-3:2016 sisaldab Euroopa standardi EN 50600-4-3:2016 ingliskeelset teksti.	This Estonian standard EVS-EN 50600-4-3:2016 consists of the English text of the European standard EN 50600-4-3:2016.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 23.12.2016.	Date of Availability of the European standard is 23.12.2016.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 35.020, 35.110, 35.160

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 35.020; 35.110; 35.160

English Version

Information technology - Data centre facilities and infrastructures - Part 4-3: Renewable Energy Factor

Technologie de l'information - Installation et infrastructures
de centres de traitement de données - Partie 4-3 :
Coefficient d'énergie renouvelable

Informationstechnik - Einrichtungen und Infrastrukturen von
Rechenzentren - Teil 4-3: Anteil erneuerbarer Energien

This European Standard was approved by CENELEC on 2016-10-10. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword	3
Introduction	4
1 Scope	7
2 Normative references	7
3 Terms, definitions, abbreviations and symbols	7
3.1 Terms and definitions	7
3.2 Abbreviations	8
3.3 Symbols	8
4 Relevance of Renewable Energy Factor	8
5 Determination of Renewable Energy Factor	8
5.1 General	8
5.2 Total data centre energy consumption	9
5.3 Total data centre energy consumption in mixed-use buildings	10
6 Measurement of Renewable Energy Factor	10
7 Directions for use of Renewable Energy Factor	11
8 Reporting of Renewable Energy Factor	11
Annex A (informative) Renewable Energy Factor and authorities issuing a renewable energy certificate	12
Annex B (informative) Examples of Renewable Energy Factor calculation	13
Annex C (informative) Renewable Energy Factor calculation as a summation of the usage of renewable energy in different time intervals	18
Bibliography	19

Figures

Figure 1 — Schematic relationship between the EN 50600 series of documents	5
Figure B.1 — Grid energy purchased without RE certificates	13
Figure B.2 — RE certificates purchased and retired for 20 % of the energy owned and controlled by the data centre	14
Figure B.3 — RE certificates for locally generated RE are retired by the data centre	15
Figure B.4 — Locally generated energy sold to the utility with RE certificates retired by the data centre	16
Figure B.5 — Case of on-site RE generation exceeding the data centre's consumption	17

Tables

Table A.1 — Description of REF and authorities issuing a RE certificate	12
---	----

European foreword

This document (EN 50600-4-3:2016) has been prepared by CLC/TC 215 “Electrotechnical aspects of telecommunication equipment”.

The following dates are proposed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) [2017-09-10]
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) [2019-10-10]

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Regarding the various parts in the EN 50600 series, see the Introduction.

Introduction

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres need to provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of carbon footprint) and with respect to economic considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting, or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control and physical security. Effective management and operational information is required to monitor achievement of the defined needs and objectives.

This series of European Standards specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, facility managers, ICT managers, project managers, main contractors;
- 2) architects, consultants, building designers and builders, system and installation designers;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

At the time of publication of this European Standard, the EN 50600 series will comprise the following standards and documents:

- EN 50600-1, *Information technology — Data centre facilities and infrastructures — Part 1: General concepts*;
- EN 50600-2-1, *Information technology — Data centre facilities and infrastructures — Part 2-1: Building construction*;
- EN 50600-2-2, *Information technology — Data centre facilities and infrastructures — Part 2-2: Power distribution*;
- EN 50600-2-3, *Information technology — Data centre facilities and infrastructures — Part 2-3: Environmental control*;
- EN 50600-2-4, *Information technology — Data centre facilities and infrastructures — Part 2-4: Telecommunications cabling infrastructure*;

- EN 50600-2-5, *Information technology — Data centre facilities and infrastructures — Part 2-5: Security systems*;
- EN 50600-3-1, *Information technology — Data centre facilities and infrastructures — Part 3-1: Management and operational information*;
- EN 50600-4-1, *Information technology — Data centre facilities and infrastructures — Part 4-1: Overview of and general requirements for key performance indicators*;
- EN 50600-4-2, *Information technology — Data centre facilities and infrastructures — Part 4-2: Power Usage Effectiveness*;
- EN 50600-4-3, *Information technology — Data centre facilities and infrastructures — Part 4-3: Renewable Energy Factor*;
- CLC/TR 50600-99-1, *Information technology — Data centre facilities and infrastructures — Part 99-1: Recommended practices for energy management*.

The inter-relationship of the standards within the EN 50600 series is shown in Figure 1.




Figure 1 — Schematic relationship between the EN 50600 series of documents

EN 50600-2-X standards specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

In today’s digital society data centre growth, and power consumption in particular, is an inevitable consequence and that growth will demand increasing power consumption despite the most stringent energy efficiency strategies. This makes the need for key performance indicators that cover the effective use of resources (including but not limited to energy) and the reduction of CO₂ emissions essential.

NOTE 1 Within the EN 50600-4-X series, the term “resource usage effectiveness” is more generally used for KPIs in preference to “resource usage efficiency”, which is restricted to situations where the input and output parameters used to define the KPI have the same units.

In order to enable the optimum resource effectiveness of data centres a suite of effective KPIs is needed to measure and report on resources consumed in order to develop an improvement roadmap.

These standards are intended to accelerate the provision of operational infrastructures with improved resource usage effectiveness.

This European Standard specifies the Renewable Energy Factor (REF), which provides a quantitative metric for the actual use of renewable energy, in the form of electricity, in a data centre.

NOTE 2 This standard adopts the ISO/IEC definition of renewable energy, but defers to the definition that apply within local jurisdiction(s).

The use of and the demand for renewable energy becomes increasingly popular since it reduces or replaces the use of non-renewable energy sources. In many countries, legislation promotes the use of renewable energy and gives incentives in order to increase the diversity of energy dependence and improve the social sustainability. In several countries, governments have targets for the use of renewable energy and/or companies have a target for the use of renewable energy among all electricity consumed. The use of renewable energy as one of the sources to power data centre becomes increasingly important as their electricity consumption has risen to a significant share of the total global electricity consumption.

This European Standard is intended for use by data centre managers. The use of the Renewable Energy Factor as a key performance indicator allows data centre managers to improve a data centre's energy procurement portfolio and increase the diversity of energy dependence. Data centre managers can confirm their achievement of the use of renewable energy to their national or corporate targets.

Additional standards in the EN 50600-4-X series will be developed, each describing a specific KPI for resource usage effectiveness or efficiency.

The EN 50600-4-X series does not specify limits or targets for any KPI and does not describe or imply, unless specifically stated, any form of aggregation of individual KPIs into a combined nor an overall KPI for data centre resource usage effectiveness or efficiency.

This series of European Standards does not address the selection of information technology and network telecommunications equipment, software and associated configuration issues.

1 Scope

This European Standard:

- a) defines the Renewable Energy Factor (REF) of a data centre;
- b) specifies a methodology to calculate and to present the REF;
- c) provides information on the correct interpretation of the REF.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50600-1, *Information technology - Data centre facilities and infrastructures - Part 1: General concepts*

ISO 8601, *Data elements and interchange formats — Information interchange — Representation of dates and times*

3 Terms, definitions, abbreviations and symbols

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 50600-1 and the following apply.

3.1.1

renewable energy

energy obtained from a renewable energy source

Note 1 to entry: Criteria to categorize an energy as renewable can differ amongst jurisdictions, based on local environmental or other reasons.

[SOURCE: EN ISO/IEC 13273-2:2016, 3.1.6, modified – The information regarding the changes that were brought to the original definition in IEC 60050-617:2009, 617-04-11 were removed.]

3.1.2

renewable energy certificate

tradable, contractual instrument that represents a proof that a certain amount of electricity (or other type of energy) was generated from a renewable energy source

3.1.3

Renewable Energy Factor

ratio of the renewable energy owned and controlled by a data centre to the total data centre energy

3.1.4

renewable energy source

energy source not depleted by extraction as it is naturally replenished at a rate faster than it is extracted

Note 1 to entry: Renewable energy source excludes recovered or wasted energy.

Note 2 to entry: Organic fraction of municipal waste may be considered as a renewable energy source.

Note 3 to entry: Whether the energy stored in a technical system is renewable or not depends upon the nature of the original energy source.

Note 4 to entry: Criteria to categorize an energy as renewable can differ amongst jurisdictions, based on local environmental or other reasons.

[SOURCE: EN ISO/IEC 13273-2:2016, 3.1.5, modified – The information regarding the changes that were brought to the original definition in CEN/CLC/TR 16103:2010, 4.1.3 were removed.]