INTERNATIONAL STANDARD

ISO 7176-5

Second edition 2008-06-01

Wheelchairs —

Part 5:

Determination of dimensions, mass and manoeuvring space

Fauteuils roulants —

Partie 5: Détermination des dimensions, de la masse et de l'espace de manoeuvre




PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below





COPYRIGHT PROTECTED DOCUMENT

© ISO 2008

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office Case postale 56 • CH-1211 Geneva 20 Tel. + 41 22 749 01 11 Fax + 41 22 749 09 47 E-mail copyright@iso.org Web www.iso.org

Published in Switzerland

Contents

Page

Forewo	ord	٠١	
Introdu	Introductionv		
1	Scope		
2	Normative references	1	
3	Terms and definitions	2	
4	Wheelchair classes and occupant mass groups	22	
4.1	General	22	
4.2	Classes of electrically powered wheelchairs	22	
4.3	Occupant mass groups	22	
5	Toet apparatue	22	
	Test apparatus	22	
6			
7	Preparation of the test wheelchair	27	
7.1	General	27	
7.2	Wheelchair equipment	27	
7.3	Wheelchair adjustment	27	
7.4	Final check	32	
7.5	Positioning	32	
7.6	Loading of the wheelchair	32	
7.7	Records	34	
7.8	I ISO AT NANA SNACO NALIAO ANA TAAT SNACOINGILIAOS	32	
7.9	Wheel rotation	34	
7.10	Asymmetrical design of test wheelchair	35	
Q	Required measurements	35	
8 8 1	Required measurements	35	
8.1	Required measurements General Full overall length	35 35	
8.1 8.2	Required measurements General Full overall length	35 35 36	
8.1 8.2 8.3	Wheel rotation Asymmetrical design of test wheelchair Required measurements General Full overall length Overall width Handgrip height	35 35 36	
8.1 8.2 8.3 8.4	Required measurements General Full overall length Overall width Handgrip height Stowage length	35 36 36 36	
8.1 8.2 8.3 8.4 8.5	Required measurements General Full overall length Overall width Handgrip height Stowage length	35 36 36 36	
8.1 8.2 8.3 8.4 8.5 8.6	Required measurements General Full overall length Overall width Handgrip height Stowage length Stowage width Stowage height	35 36 36 36 37	
8.1 8.2 8.3 8.4 8.5 8.6 8.7	Stowage length	36 37 37	
8.1 8.2 8.3 8.4 8.5 8.6 8.7	Stowage length Stowage width Stowage height Rising	36 37 37	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8	Stowage length Stowage width Stowage height Rising	36 37 37	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9	Stowage length Stowage width Stowage height Rising	36 37 37	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11	Stowage length Stowage width Stowage height Rising	36 37 37	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12	Stowage length Stowage width Stowage height Rising	36 37 37	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter	36 37 37 37 37 38 38	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance	36 37 37 37 38 38 38	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor	36 37 37 37 37 38 38 38 38 38 38	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor Required doorway entry depth	36 37 37 37 38 38 38 38	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16 8.17	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor Required doorway entry depth Required corridor width for side opening	36 37 37 37 37 38 38 38 38 38 39 39	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16 8.17	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter. Ground clearance Required width of angled corridor Required doorway entry depth Required corridor width for side opening Disclosure of information	36 37 37 37 38 38 38 39 39	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16 8.17 9	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor Required doorway entry depth Required corridor width for side opening Disclosure of information General	36 36 37 37 38 38 38 39 39	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16 8.17 9	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor Required doorway entry depth Required corridor width for side opening Disclosure of information General Wheelchairs with handrims	36 37 37 37 38 38 38 38 39 39 39	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16 8.17 9	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor Required doorway entry depth Required corridor width for side opening Disclosure of information General	36 37 37 37 38 38 38 38 39 39 39	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16 8.17 9	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor Required doorway entry depth Required corridor width for side opening Disclosure of information General Wheelchairs with handrims Wheelchairs without handrims	36 36 37 37 38 38 38 38 39 39 39 39 41	
8.1 8.2 8.3 8.4 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 8.13 8.14 8.15 8.16 8.17 9	Stowage length Stowage width Stowage height Rising Total mass Mass of heaviest part Pivot width Reversing width Turning diameter Ground clearance Required width of angled corridor Required doorway entry depth Required corridor width for side opening Disclosure of information General Wheelchairs with handrims	36 37 37 37 37 38 38 38 38 39 39 39 41 41	

ISO 7176-5:2008(E)

Annex A (informative)	Technical dimensions	. 45
Annex B (informative)	Pivot width and reversing width	. 59
Annex C (informative)	Turning diameter	. 69
Annex D (informative)	Wheelchair longitudinal axis and wheelchair centre-point	. 74
Annex E (informative)	Guidelines and recommendations for wheelchair design and performance	. 75
Bibliography		. 79

This document is a preview denetated by this

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 7176-5 was prepared by Technica committee ISO/TC 173, Assistive products for persons with disability, Subcommittee SC 1, Wheelchairs.

This second edition cancels and replaces the first edition (ISO 7176-5:1986) which has been technically revised.

ISO 7176 consists of the following parts, under the general title Wheelchairs:

- Part 1: Determination of static stability
- Part 2: Determination of dynamic stability of electric vineelchairs
- Part 3: Determination of effectiveness of brakes
- Part 4: Energy consumption of electric wheelchairs and scooters for determination of theoretical distance range
- Part 5: Determination of dimensions, mass and manoeuvring space
- Part 6: Determination of maximum speed, acceleration and deceleration of electric wheelchairs
- Part 7: Measurement of seating and wheel dimensions
- Part 8: Requirements and test methods for static, impact and fatigue strengths (
- Part 9: Climatic tests for electric wheelchairs
- Part 10: Determination of obstacle-climbing ability of electrically powered wheelchairs
- Part 11: Test dummies
- Part 13: Determination of coefficient of friction of test surfaces
- Part 14: Power and control systems for electrically powered wheelchairs and scooters Requirements and test methods

© ISO 2008 – All rights reserved

ISO 7176-5:2008(E)

- Part 15: Requirements for information disclosure, documentation and labelling
- Part 16: Resistance to ignition of upholstered parts Requirements and test methods
- Part 19: Wheeled mobility devices for use as seats in motor vehicles
- Part 21: Requirements and test methods for electromagnetic compatibility of electrically powered wheelchairs and motorized scooters, and battery chargers
- Part 22: Set-up procedures
- Indicest me document is a preview denotated by Files Part 23: Requirements and test methods for attendant-operated stair-climbing devices
- Part 24: Requirements and test methods for user-operated stair-climbing devices
- Part 26: Vocabulary

νi

Introduction

The purpose of this part of ISO 7176 is to provide technical definitions together with appropriate measurement procedures for measuring important dimensions and masses of manual wheelchairs and electrically powered wheelchairs including scooters, which can be used to estimate the appropriateness for a given environment.

A new approach is used for the pre-selection of the reference size from a wheelchair model with a range of various dimensions by introducing reference dimensions of the intended occupant. This new approach ensures repeatable and comparable test results.

The information in this part of ISO 7176 is intended for three main reader groups:

- prescribers and occupants of wheelchairs;
- architects and public authorites;
- manufacturers, wheelchair providers, clinicians and test laboratories.

Features that are important to whee chair occupants, architects and public authorities, such as overall dimensions and the estimation of the space needed and general manoeuvrability, are contained in Clause 8. Values for the different features are disclosed in the wheelchair's specification sheet. The values can be used to determine, before purchase, the wheelchair's suitability in relation to specific requirements and needs.

The technical features of a wheelchair which to of importance to manufacturers, wheelchair providers, clinicians and test laboratories, such as items to be considered when manufacturing, setting up, adjusting, repairing or testing wheelchairs, are included in AnnexA.

Technical Report ISO/TR 13570-1^[1] is also available, giving a simplified explanation of the different parts of ISO 7176.

Technical Report, ISO/TR 13570-2^[2], is under consideration

© ISO 2008 – All rights reserved

Inis document is a preview denetated by EUS

Wheelchairs —

Part 5:

Determination of dimensions, mass and manoeuvring space

1 Scope

This part of ISO 7176 specifies methods for the determination of wheelchair dimensions and mass.

This includes specific methods for the determination of outside dimensions when the wheelchair is occupied by a reference occupant and the required manoeuvring space needed for wheelchair manoeuvres commonly carried out in daily life.

This part of ISO 7176 specifies requirements for the disclosure of the dimensions and masses and contains five informative annexes.

Annex A specifies methods for the determination of technical dimensions that can be important to the performance of the wheelchair.

Annex B provides detailed information about pivot width and reversing width.

Annex C provides detailed information about the turning diameter.

Annex D provides details on determining the wheelchair logitudinal axis and wheelchair centre-point.

Annex E provides technical guidelines and recommendations for many of the measurements specified to facilitate improved understanding, design and construction of wheelchairs.

This part of ISO 7176 is applicable to manual wheelchairs and petrically powered wheelchairs (including scooters).

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7176-7, Wheelchairs — Part 7: Measurement of seating and wheel dimensions

ISO 7176-11, Wheelchairs — Part 11: Test dummies

ISO 7176-13, Wheelchairs — Part 13: Determination of coefficient of friction of test surfaces

ISO 7176-15, Wheelchairs — Part 15: Requirements for information disclosure, documentation and labelling

ISO 7176-22:2000, Wheelchairs — Part 22: Set-up procedures

ISO 7176-26, Wheelchairs — Part 26: Vocabulary

© ISO 2008 – All rights reserved