

Compressors and condensing units for refrigeration -
Performance testing and test methods - Part 2:
Condensing units

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 13771-2:2017 sisaldab Euroopa standardi EN 13771-2:2017 ingliskeelset teksti.	This Estonian standard EVS-EN 13771-2:2017 consists of the English text of the European standard EN 13771-2:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 06.09.2017.	Date of Availability of the European standard is 06.09.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.140, 27.200

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 13771-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2017

ICS 23.140; 27.200

Supersedes EN 13771-2:2007

English Version

Compressors and condensing units for refrigeration - Performance testing and test methods - Part 2: Condensing units

Compresseurs et unités de condensation pour la
réfrigération - Essais de performance et méthodes
d'essais - Partie 2 : Unités de condensation

Kältemittel-Verdichter und Verflüssigungssätze für die
Kälteanwendung - Leistungsprüfung und
Prüfverfahren - Teil 2: Verflüssigungssätze

This European Standard was approved by CEN on 26 July 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents**Page**

European foreword	3
1 Scope	4
2 Normative references	4
3 Terms, definitions and symbols	4
3.1 Terms and definitions	4
3.2 Symbols	7
3.3 Refrigerant circuit state points	10
4 Uncertainty of measurement and test conditions	10
4.1 Uncertainty of performance data	10
4.2 Uncertainty of measurement	10
4.3 Test conditions	12
5 General requirements	13
5.1 Test equipment	13
5.2 Calculation methods	13
5.3 Requirements for the selection of test methods	15
5.4 Test procedure	15
5.5 Pressure and temperature measuring points	15
5.6 Oil circulation	16
5.7 Refrigerant composition	16
5.8 Calibration and requirements regarding measurement uncertainty	16
5.9 Source of refrigerant data	17
5.10 Test setup for air cooled condensing units	17
6 Test methods	18
6.1 General	18
6.2 List of test methods	18
6.3 Method A: secondary fluid calorimeter on the suction side	19
6.4 Method B: dry system refrigerant calorimeter on the suction side	20
6.5 Method C: Water cooled condenser calorimeter	22
6.6 Method D: Refrigerant gas flow meter on the suction side (see 6.6)	23
6.7 Method E: refrigerant flow meter in the liquid line	24
7 Determination of the power absorbed by the condensing unit	26
7.1 General	26
7.2 Calculation	26
8 Test report	27
8.1 General	27
8.2 Test data	28
8.3 Test results	28
8.4 Overview of test values	28
Bibliography	30

European foreword

This document (EN 13771-2:2017) has been prepared by Technical Committee CEN/TC 113 “Heat pumps and air conditioning units”, the secretariat of which is held by UNE.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2018, and conflicting national standards shall be withdrawn at the latest by March 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13771-2:2007.

The following significant changes compared to the previous edition have been incorporated in this European Standard:

- a) alignment of symbols and indexes with EN 13771-1;
- b) introduction of a new Figure 1 “Condensing unit configurations” and revision of the Figures 2 to 7;
- c) introduction of the new Clause 4 “Uncertainty of measurement and test conditions”;
- d) specification of a detailed test room and setup description to reduce testing uncertainty, aligned with EN 327 and EN 14511-3;
- e) adoption to transcritical operation and cyclic capacity control.

EN 13771 consists of the following parts, under general title *Compressors and condensing units for refrigeration — Performance testing and test methods*:

- *Part 1: Refrigerant compressors*
- *Part 2: Condensing units*

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard applies only to condensing units for refrigeration and describes a number of selected performance test methods. These methods provide sufficiently accurate results for the determination of the refrigerating capacity, power absorbed, refrigerant mass flow and the coefficient of performance.

This European Standard applies only to performance tests conducted at the manufacturer's works or wherever the instrumentation and load stability for testing to the accuracy required is available.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 378-1, *Refrigerating systems and heat pumps - Safety and environmental requirements - Part 1: Basic requirements, definitions, classification and selection criteria*

EN 378-2, *Refrigerating systems and heat pumps - Safety and environmental requirements - Part 2: Design, construction, testing, marking and documentation*

ISO 817, *Refrigerants — Designation and safety classification*

3 Terms, definitions and symbols

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1.1

refrigerating capacity

Q

(condensing unit) product of the refrigerant mass flow and the difference between the specific enthalpy of the refrigerant at the inlet of the condensing unit (Figure 1, point 11) and the specific enthalpy of the fluid at the outlet of the condensing unit (Figure 1, point 12)

Note 1 to entry: The outlet (point 12) of condensing unit depends on design (single stage or two stage or internal heat exchangers, see Figure 1 a), b), c) and d).