

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



**Electricity metering equipment (a.c.) – Particular requirements –
Part 24: Static meters for reactive energy at fundamental frequency (classes
0,5 S, 1 S and 1)**

**Équipement de comptage de l'électricité (c.a.) – Exigences particulières –
Partie 24: Compteurs statiques d'énergie réactive à la fréquence fondamentale
(classes 0,5 S, 1 S et 1)**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



**Electricity metering equipment (a.c.) – Particular requirements –
Part 24: Static meters for reactive energy at fundamental frequency (classes
0,5 S, 1 S and 1)**

**Équipement de comptage de l'électricité (c.a.) – Exigences particulières –
Partie 24: Compteurs statiques d'énergie réactive à la fréquence fondamentale
(classes 0,5 S, 1 S et 1)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220.20; 91.140.50

ISBN 978-2-8322-3765-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

This document is a preview generated by EVS

REDLINE VERSION

VERSION REDLINE



**Electricity metering equipment (a.c.) – Particular requirements –
Part 24: Static meters for reactive energy at fundamental frequency (classes
0,5 S, 1 S and 1)**

**Équipement de comptage de l'électricité (c.a.) – Exigences particulières –
Partie 24: Compteurs statiques d'énergie réactive à la fréquence fondamentale
(classes 0,5 S, 1 S et 1)**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
INTRODUCTION TO AMENDMENT 1	7
1 Scope.....	8
2 Normative references	9
3 Terms and definitions	9
4 Standard electrical values	9
5 Mechanical requirements.....	9
6 Climatic conditions.....	10
7 Electrical requirements	10
7.1 General.....	10
7.2 Power consumption.....	10
7.2.1 General	10
7.2.2 Voltage circuits.....	10
7.2.3 Current circuits.....	10
7.3 Influence of short-time overcurrents	11
7.4 Influence of self-heating.....	12
7.5 AC voltage test	12
8 Accuracy requirements	12
8.1 General.....	12
8.2 Limits of error due to variation of the current.....	12
8.3 Limits of error due to influence quantities.....	13
8.3.1 General	13
8.3.2 Tests of the influence of DC and even harmonics in the current circuit	15
8.3.3 Continuous magnetic induction of external origin	15
8.3.4 Harmonics	15
8.4 Test of starting and no-load condition	15
8.4.1 General	15
8.4.2 Initial start-up of the meter.....	16
8.4.3 Test of no-load condition	16
8.4.4 Starting.....	16
8.5 Meter constant.....	16
8.6 Accuracy test conditions	16
8.7 Interpretation of test results	18
Annex A (normative) Test circuit diagram for DC and even harmonics	19
Annex B (normative) Electromagnet for testing the influence of externally produced magnetic fields	21
Annex C (informative) Geometric representation of active and reactive power	22
Annex D (informative) Effect of phase displacement	24
D.1 Phase displacement and matching of current transformers and meters for reactive energy	24
Annex E (informative) Treatment of harmonics and tests for harmonics	25
E.1 Non-sinusoidal conditions and reactive power definition.....	25
E.2 Tests for accuracy under non-sinusoidal conditions	25
E.3 Fifth harmonic test	26

Bibliography.....	27
Figure A.1 – Test circuit diagram for half-wave rectification	19
Figure A.2 – Half-wave rectified waveform	20
Figure B.1 – Electromagnet for testing the influence of externally produced magnetic fields.....	21
Figure C.1 – Recommended geometric representation	22
Figure C.2 – Alternative geometric representation	23
Table 1 – Power consumption in voltage circuits for single-phase and polyphase meters including the power supply	10
Table 2 – Power consumption in current circuits	11
Table 3 – Variations due to short-time overcurrents	11
Table 4 – Variations due to self-heating	12
Table 5 – AC Voltage tests	13
Table 6 – Percentage error limits (single-phase meters and polyphase meters with balanced loads)	13
Table 7 – Percentage error limits (polyphase meters carrying a single-phase load, but with balanced polyphase voltages applied to voltage circuits)	13
Table 8 – Influence quantities	13
Table 9 – Starting current	16
Table 10 – Voltage and current balance	17
Table 11 – Reference conditions.....	18
Table 12 – Interpretation of test results.....	18
Table D.1 – Limits of phase displacement for measuring current transformers and corresponding measurement error for reactive energy measurement	24

preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICITY METERING EQUIPMENT (a.c.) –
PARTICULAR REQUIREMENTS –****Part 24: Static meters for reactive energy at fundamental frequency
(classes 0,5 S, 1 S and 1)**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 62053-24 bears the edition number 1.1. It consists of the first edition (2014-06) [documents 13/1569/FDIS and 13/1578/RVD] and its amendment 1 (2016-11) [documents 13/1703/FDIS and 13/1717/RVD]. The technical content is identical to the base edition and its amendment.

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 62053-24 has been prepared by IEC technical committee 13: Electrical energy measurement and control.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC series 62053, under the general title *Electricity metering equipment (a.c.) – Particular requirements*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 2 years from the date of publication.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 62053 is to be used with the following relevant parts of the IEC 62052, IEC 62053 and IEC 62059 series, *Electricity metering equipment*:

IEC 62052-11:2003, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 11: Metering equipment*
Amendment 1 (2016)

IEC 62052-31:2015, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests*

IEC 62053-21:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)*

IEC 62053-22:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)*

IEC 62053-31:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 31: Pulse output devices for electromechanical and electronic meters (two wires only)*

IEC 62053-52:2005, *Electricity metering equipment (a.c.) – Particular requirements – Part 52: Symbols*

IEC 62053-61:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 61: Power consumption and voltage requirements*

IEC 62059-11:2002, *Electricity metering equipment (a.c.) – Dependability – Part 11: General concepts*

IEC 62059-21:2002, *Electricity metering equipment (a.c.) – Dependability – Part 21: Collection of meter dependability data from the field*

IEC 62059-31-1:2008, *Electricity metering equipment – Dependability – Part 31-1: Accelerated reliability testing – Elevated temperature and humidity*

IEC 62059-32-1:2011, *Electricity metering equipment – Dependability – Part 32-1: Durability – Testing of the stability of metrological characteristics by applying elevated temperature*

IEC 62059-41:2006, *Electricity metering equipment – Dependability – Part 41: Reliability prediction*

This part is a standard for type testing electricity meters. It covers the particular requirements for meters, used indoors and outdoors. It does not deal with special implementations (such as metering-part and/or displays in separate housings).

This standard is intended to be used in conjunction with IEC 62052-11. When any requirement in this standard concerns an item already covered in IEC 62052-11, the requirements of this standard take precedence over the requirements of IEC 62052-11.

This standard distinguishes:

- between transformer operated meters of accuracy class index 0,5 S and 1 S and direct connected meters of accuracy class index 1;
- between protective class I and protective class II meters;
- between meters for use in networks equipped with or without earth fault neutralizers.

The test levels are regarded as minimum values that provide for the proper functioning of the meter under normal working conditions. For special application, other test levels might be necessary and should be agreed on between the user and the manufacturer.

INTRODUCTION TO AMENDMENT 1

The purpose of this amendment is to identify and remove all safety related requirements and tests of IEC 62053-24:2014 that are replaced and extended by the complete set of requirements and tests in IEC 62052-31:2015.

This document is a preview generated by EVS

ELECTRICITY METERING EQUIPMENT (a.c.) – PARTICULAR REQUIREMENTS –

Part 24: Static meters for reactive energy at fundamental frequency (classes 0,5 S, 1 S and 1)

1 Scope

This part of IEC 62053 applies only to newly manufactured transformer operated static var-hour meters of accuracy classes 0,5 S, and 1 S as well as direct connected static var-hour meters of accuracy class 1, for the measurement of alternating current electrical reactive energy in 50 Hz or 60 Hz networks and it applies to their type tests only.

This standard uses a conventional definition of reactive energy where the reactive power and energy is calculated from the fundamental frequency components of the currents and voltages only. See Clause 3.

NOTE 1 This differs from the approach of IEC 62053-23, where reactive power and energy is defined only for sinusoidal signals. In this standard reactive power and energy is defined for all periodic signals. Reactive power and energy is defined in this way to achieve proper reproducibility of measurements with meters of different designs. With this definition, reactive power and energy reflects the generally unnecessary current possible to compensate with capacitors rather than the total unnecessary current.

It applies only to static var-hour meters for indoor and outdoor application consisting of a measuring element and register(s) enclosed together in a meter case. It also applies to operation indicator(s) and test output(s). If the meter has a measuring element for more than one type of energy (multi-energy meters), or when other functional elements, like maximum demand indicators, electronic tariff registers, time switches, ripple control receivers, data communication interfaces, etc., are enclosed in the meter case, then the relevant standards for these elements also apply.

NOTE 2 IEC 61869-2:2012 describes transformers having a measuring range of $0,05 I_n$ to I_{max} for accuracy classes 0,2, 0,5, 1 and 2, and transformers having a measuring range of $0,01 I_n$ to I_{max} for accuracy classes 0,2 S and 0,5 S. As the measuring range of a meter and its associated transformers have to be matched and as only transformers of classes 0,2 S / 0,5 S have the current error and phase displacement characteristics suitable to operate a class 0,5 S / 1 S meter respectively as specified in this standard, the measuring range of the transformer operated meters will be $0,01 I_n$ to I_{max} . Reactive meters intended to be used together with non-S transformers are, therefore, not covered by this standard.

It does not apply to:

- var-hour meters where the voltage across the connection terminals exceeds 600 V (line-to-line voltage for meters for polyphase systems);
- portable meters;
- data interfaces to the register of the meter;
- reference meters.

The dependability aspect is covered by the standards of the IEC 62059 series.

The safety aspect is covered by IEC 62052-31:2015.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62052-11:2003, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 11: Metering equipment*
Amendment 1 (2016)

IEC 62052-31:2015, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62052-11 apply with the following exception:

3.1

reactive power

Q

reactive power Q in a single phase system is defined for steady-state and periodic signals as

$$Q = U_1 * I_1 * \sin \phi_1$$

where U_1 and I_1 are the r.m.s. values of the fundamental frequency components of the voltage and the current respectively, and

ϕ_1 is the phase angle between them. The reactive power in poly-phase system is the algebraic sum of the per-phase reactive powers:

$$Q = U_{L1} * I_{L1} * \sin \phi_{L1} + U_{L2} * I_{L2} * \sin \phi_{L2} + \dots$$

where

L1 and L2 are the first and second phase of the system.

Note 1 to entry: For direction of flow and sign of reactive power, see Annex C.

Note 2 to entry: The actual algorithm used for the calculation of reactive power is not of importance as long as the meter meets requirements of this standard. See also Annex E.

Note 3 to entry: While meters for active energy have to measure active energy including harmonic components, reactive energy meters according to this standard have to measure fundamental component reactive energy, with minimum influence from harmonics.

4 Standard electrical values

The values given in IEC 62052-11 apply.

5 Mechanical requirements

The requirements of IEC 62052-11 apply.