

**Gaasirõhuregulaatorid sisendrõhule kuni 100 baari  
KONSOLIDEERITUD TEKST**

Gas pressure regulators for inlet pressures up to 100  
bar CONSOLIDATED TEXT

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 334:2005+A1:2009 sisaldab Euroopa standardi EN 334:2005+A1:2009 ingliskeelset teksti.</p> <p>Standard on kinnitatud Eesti Standardikeskuse 23.02.2009 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 21.01.2009.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 334:2005+A1:2009 consists of the English text of the European standard EN 334:2005+A1:2009.</p> <p>This standard is ratified with the order of Estonian Centre for Standardisation dated 23.02.2009 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.</p> <p>Date of Availability of the European standard text 21.01.2009.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

ICS 23.060.40

Võtmesõnad:

### Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:  
Aru 10 Tallinn 10317 Eesti; [www.evs.ee](http://www.evs.ee); Telefon: 605 5050; E-post: [info@evs.ee](mailto:info@evs.ee)

English Version

**Gas pressure regulators for inlet pressures up to 100 bar**

Appareils de régulation de pression de gaz (régulateurs)  
pour des pressions amont jusqu'à 100 bar

Gas-Druckregelgeräte für Eingangsdrücke bis 100 bar

This European Standard was approved by CEN on 23 December 2004 and includes Amendment 1 approved by CEN on 8 December 2008.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: rue de Stassart, 36 B-1050 Brussels**

## Contents

	page
Foreword.....	5
1 Scope .....	6
2 Normative references .....	7
3 Terms, definitions and symbols.....	9
3.1 <b>A1</b> General terms and definitions of types of gas pressure regulators <b>A1</b> .....	9
3.2 <b>A1</b> Terms and definitions of components of gas pressure regulators <b>A1</b> .....	12
3.3 <b>A1</b> Terms, symbols and definitions of components of functional performance <b>A1</b> .....	14
3.3.7 <b>A1</b> Terms, symbols and definitions of functional performance <b>A1</b> .....	16
3.4 <b>A1</b> Terms, symbols and definitions related to design and tests <b>A1</b> .....	20
4 Construction requirements.....	22
4.1 Basic requirements .....	22
4.1.1 General.....	22
4.1.2 <b>A1</b> Gas pressure regulators with associated safety devices .....	23
4.1.3 End connections .....	25
4.1.4 Flange ratings .....	25
4.1.5 Nominal sizes and face-to-face dimensions .....	25
4.1.6 Sealing of the adjusting device .....	29
4.1.7 <b>A1</b> Springs .....	29
4.1.8 Replaceable parts that may be affected by erosion or abrasion .....	29
4.2 Materials .....	29
4.2.1 Requirements for metallic materials.....	29
4.2.2 Requirements for elastomers (including vulcanized rubbers) .....	34
4.2.3 Requirements for non metallic materials different from those in 4.2.2 .....	34
4.3 Strength of housings.....	35
<b>A1</b> .....	35
4.3.1 Body and its inner metallic partition walls <b>A1</b> .....	35
4.3.2 Flanges .....	35
4.3.3 <b>A1</b> Other pressure containing parts .....	35
4.3.4 Inner metallic partition walls .....	37
4.3.5 Minimum values of safety factor .....	37
4.3.6 Welded joint coefficient .....	38
5 Functional requirements .....	38
5.1 General.....	38
5.1.1 Mounting position.....	38
5.1.2 Sound emission .....	38
5.2 Shell strength, external tightness and internal sealing.....	39
5.2.1 Shell strength.....	39
5.2.2 External tightness.....	40
5.2.3 Internal sealing .....	40
5.3 Control classifications .....	40
5.3.1 Accuracy under stable conditions .....	40
5.3.2 Lock-up behaviour.....	40
5.3.3 Stable conditions .....	41
5.4 Final visual inspection .....	41
5.5 Fail-close conditions .....	42
6 Gas pressure regulator sizing .....	42
6.1 Flow behaviour .....	42

6.2	Sizing equations for the calculation of volumetric flow rates of a gas pressure regulator with its control member in its mechanically fully open position .....	43
6.2.1	Normal calculations .....	43
6.2.2	Practical calculations .....	43
6.2.3	Simplified calculations .....	43
6.3	Calculation of the maximum accuracy flow rate .....	44
6.4	Inherent flow characteristics .....	44
6.5	Calculation of volumetric flow rates for partially open gas pressure regulators .....	44
6.6	Flow coefficient .....	44
7	Testing .....	45
7.1	General .....	45
7.2	Tests .....	45
7.3	Type test .....	46
7.4	Selection of test samples .....	47
7.5	Routine tests .....	47
7.6	Production surveillance .....	47
7.7	Test and verification methods .....	47
7.7.1	Dimensional check and visual inspection .....	47
7.7.2	Materials check .....	47
7.7.3	Verification of the strength of pressure containing parts and inner metallic partition walls .....	48
7.7.4	Shell and inner metallic partition walls strength test .....	49
7.7.5	Alternative shell and inner metallic partition walls strength test .....	50
7.7.6	External tightness test .....	50
7.7.7	Functional tests .....	51
7.7.8	Final visual inspection .....	64
8	Documentation .....	64
8.1	Documentation related to type test .....	64
8.1.1	Documentation required prior to type test .....	64
8.1.2	Test report .....	64
8.2	Documentation related to the routine tests .....	64
8.2.1	Documentation provided at the request of the customer .....	64
8.2.2	Documentation provided with the regulator .....	65
8.3	Documentation related to production surveillance in accordance with 7.6 .....	65
8.3.1	Documentation to be available for production surveillance .....	65
8.3.2	Production surveillance report .....	66
9	Marking .....	66
9.1	General requirements .....	66
9.2	Markings for the various connections .....	67
9.3	Marking of integrated safety devices .....	67
Annex A	(informative) Alternative methods for the determination of the accuracy class, the lock-up pressure class, the maximum accuracy flow rate, the flow coefficients and the verification of the hysteresis band .....	68
A.1	General .....	68
A.2	Test methods .....	68
A.2.1	Direct acting gas pressure regulator .....	68
A.2.2	Pilot controlled gas pressure regulators .....	69
A.3	Determination of flow coefficients for larger capacity regulators .....	70
Annex B	(informative) Inspection certificate .....	76
Annex C	(informative) Acceptance test .....	78
Annex D	(informative) Compliance evaluation <sup>1)</sup> .....	79
D.1	General .....	79
D.2	Introduction .....	79
D.3	Procedure .....	79
D.4	Manufacturer's compliance evaluation .....	80
D.5	Issue of the certificate of compliance .....	80

<b>Annex E</b> (informative) <b>▣ A1</b> <b>Seat leakage (alternative requirement) ▣ A1</b> .....	<b>81</b>
<b>Annex F</b> (normative) <b>Creep (venting) relief device</b> .....	<b>82</b>
<b>F.1</b> <b>General</b> .....	<b>82</b>
<b>F.2</b> <b>Terms and definitions</b> .....	<b>82</b>
<b>F.3</b> <b>Requirements</b> .....	<b>82</b>
<b>F.3.1</b> <b>Construction</b> .....	<b>82</b>
<b>F.3.2</b> <b>Functional requirements</b> .....	<b>82</b>
<b>F.4</b> <b>Testing</b> .....	<b>82</b>
<b>F.5</b> <b>Type test</b> .....	<b>83</b>
<b>F.6</b> <b>Routine tests</b> .....	<b>83</b>
<b>F.7</b> <b>Documentation</b> .....	<b>83</b>
<b>F.8</b> <b>Marking</b> .....	<b>83</b>
<b>Annex G</b> (informative) <b>Order specification</b> .....	<b>84</b>
<b>G.1</b> <b>General</b> .....	<b>84</b>
<b>G.2</b> <b>Minimum specifications</b> .....	<b>84</b>
<b>G.2.1</b> <b>Details of construction</b> .....	<b>84</b>
<b>G.2.2</b> <b>Dimensions</b> .....	<b>84</b>
<b>G.2.3</b> <b>Performance</b> .....	<b>84</b>
<b>G.3</b> <b>Optional specifications</b> .....	<b>85</b>
<b>Annex H</b> (normative) <b>Materials</b> .....	<b>87</b>
<b>H.1</b> <b>Steel materials for pressure containing parts and inner metallic partition walls</b> .....	<b>87</b>
<b>H.2</b> <b>Metallic materials different from steel materials for pressure containing parts and inner metallic partition walls</b> .....	<b>93</b>
<b>H.3</b> <b>Materials for fixtures, integral process and sensing lines, connectors and fasteners</b> .....	<b>98</b>
<b>Annex I</b> (informative) <b>▣ A1</b> <b>Glossary</b> .....	<b>101</b>
<b>Annex ZA</b> (informative) <b>Relationship between this European Standard and the Essential Requirements of EU Directive 97/23/EC</b> .....	<b>103</b>
<b>Bibliography</b> .....	<b>105</b>

## Foreword

This document (EN 334:2005+A1:2009) has been prepared by Technical Committee CEN/TC 235 "Gas pressure regulators and associated safety devices for use in gas transmission and distribution", the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2009, and conflicting national standards shall be withdrawn at the latest by July 2009.

This document includes Amendment 1, approved by CEN on 2008-12-08.

This document supersedes A1 EN 334:2005 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive 97/23/EC.

For relationship with EU Directive 97/23/EC, see informative Annex ZA, which is an integral part of this document.

Gas pressure regulators dealt with in this document are standard gas pressure regulators and, when used in pressure regulating stations complying with EN 12186 or EN 12279, they are considered as standard pressure equipment in accordance with Clause 3.1 of Art. 1 of Pressure Equipment Directive 97/23/EC (PED).

For standard gas pressure regulators used in pressure regulating stations complying with EN 12186 or EN 12279, Table ZA.1 given in Annex ZA includes all applicable Essential Requirements given in Annex I of PED, A1 except the external corrosion resistance in case of environmental conditions where corrosion is likely to occur A1.

The normative Annex H of this document lists some suitable materials for pressure containing parts, inner metallic partition walls, fasteners and connectors. Other materials may be used when complying with the restrictions given in Table 5.

A1 *deleted text* A1

A1 Continued A1 integrity of gas pressure regulators is assured by periodic functional checks. For periodic functional checks it is common to refer to national regulations/standards where existing or users/manufacturers practices.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

## 1 Scope

**A1** This document specifies constructional, functional, testing and marking requirements, sizing and documentation of gas pressure regulators used in the pressure regulating stations in accordance with EN 12186 or EN 12279: **A1**

- for inlet pressures up to 100 bar and nominal diameters up to DN 400;
- for an operating temperature range from -20 °C to +60 °C,

which operate with fuel gases of the 1<sup>st</sup> and 2<sup>nd</sup> family in accordance with EN 437 in transmission and distribution networks and also in commercial and industrial installations.

"Gas pressure regulators" hereafter will be called "regulators" except in the titles.

**A1** For standard regulators when used in pressure regulating stations complying with EN 12186 or EN 12279, Annex ZA lists all applicable Essential Requirements except the external corrosion resistance in case of environmental conditions where corrosion is likely to occur. **A1**

**A1** This document considers the following classes/types of regulators: **A1**

- class 1: operating temperature range from -10 °C to 60 °C;
- class 2: operating temperature range from -20 °C to 60 °C;

**A1**

- type IS: (integral strength type);
- type DS: (differential strength type). **A1**

This document applies to regulators which use the pipeline gas as a source of control energy unassisted by any external power source.

The regulator may incorporate a creep (venting) relief device, complying with the requirements in Annex F.

The regulators complying with the requirements of this document may be declared as "in compliance with EN 334" and bear the marking "EN 334".

This document does not apply to:

- regulators upstream from/on/in domestic gas-consuming appliances which are installed downstream of domestic gas meters;

**A1**

- regulators incorporated into pressure-regulating devices used in service lines<sup>1</sup> with volumetric flow rate ≤ 200 m<sup>3</sup>/h at normal conditions and inlet pressure ≤ 5 bar; **A1**
- regulators for which a specific document exists (e.g. EN 88, etc.);
- industrial process control valves in accordance with EN 1349.

---

<sup>1)</sup> **A1** The services lines are those defined in EN 12279. **A1**

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including amendments) applies.

☐<sub>A1</sub> deleted text ☐<sub>A1</sub>

☐<sub>A1</sub> EN 287-1, *Qualification test of welders – Fusion welding – Part 1: Steel*

☐<sub>A1</sub> EN 473:2000 ☐<sub>A1</sub>, *Non destructive testing – Qualification and certification of NDT personnel – General principles*

☐<sub>A1</sub> deleted text ☐<sub>A1</sub>

☐<sub>A1</sub> EN 970:1997 ☐<sub>A1</sub>, *Non-destructive examination of fusion welds – Visual examination*

☐<sub>A1</sub> deleted text ☐<sub>A1</sub>

☐<sub>A1</sub> EN 1092-1:2007, *Flanges and their joints – Circular flanges for pipes, valves, fittings and accessories, PN designated – Part 1: Steel flanges*

EN 1092-2:1997, *Flanges and their joints – Circular flanges for pipes, valves, fittings and accessories, PN designated – Part 2: Cast iron flanges*

EN 1092-3:2003, *Flanges and their joints – Circular flanges for pipes, valves, fittings and accessories, PN designated – Part 3: Copper alloy flanges*

EN 1092-4:2002, *Flanges and their joints – Circular flanges for pipes, valves, fittings and accessories, PN designated – Part 4: Aluminium alloy flanges* ☐<sub>A1</sub>

EN 1349, *Industrial process control valves*

☐<sub>A1</sub> EN 1418:1997 ☐<sub>A1</sub>, *Welding personnel – Approval testing of welding operators for fusion welding and resistance weld setters for fully mechanised and automatic welding of metallic materials*

☐<sub>A1</sub> deleted text ☐<sub>A1</sub>

☐<sub>A1</sub> EN 1759-1, *Flanges and their joint – Circular flanges for pipes, valves, fittings and accessories, Class designated – Part 1: Steel flanges, NPS ½ to 24*

EN 1759-3, *Flanges and their joints – Circular flanges for pipes, valves, fittings and accessories, Class designated – Part 3: Copper alloy flanges*

EN 1759-4, *Flanges and their joint – Circular flanges for pipes, valves, fittings and accessories, class designated – Part 4: Aluminium alloy flanges* ☐<sub>A1</sub>

EN 10045-1, *Metallic materials – Charpy impact test – Part 1: Test method*

☐<sub>A1</sub> EN 10204:2004 ☐<sub>A1</sub>, *Metallic products – Types of inspection documents*

☐<sub>A1</sub> EN 10226-1, *Pipe threads where pressure tight joints are made on the threads – Part 1: Taper external threads and parallel internal threads – Dimensions, tolerances and designation*

EN 10226-2, *Pipe threads where pressure tight joints are made on the threads – Part 2: Taper external threads and taper internal threads – Dimensions, tolerances and designation* ☐<sub>A1</sub>

EN 12186, *Gas supply systems – Gas pressure regulating stations for transmission and distribution – Functional requirements*

EN 12279, *Gas supply systems – Gas pressure regulating installations on service lines – Functional requirements*

EN 12516-1:2005, *Industrial valves – Shell design strength – Part 1: Tabulation method for steel valves shells*

EN 12516-2:2004, *Industrial valves – Shell design strength – Part 2: Calculation method for steel valve shells*

EN 12516-4:2008, *Industrial valves – Shell design strength – Part 4: Calculation method for valve shells in metallic materials other than steel*

EN 12627, *Industrial valves – Butt welding ends for steel valves*

EN 13445-4, *Unfired pressure vessels – Part 4: Fabrication*

EN 14382:2005, *Safety devices for gas pressure regulating stations and installations – Gas safety shut-off devices for inlet pressures up to 100 bar*

EN 60534-1:1993, *Industrial-process control valves – Part 1: Control valve terminology and general considerations (IEC 60534-1:1987)*

EN 60534-2-1, *Industrial-process control valves – Part 2-1: Flow capacity – Sizing equations for fluid flow under installed conditions (IEC 60534-2-1:1998)*

EN 60534-2-3, *Industrial-process control valves – Part 2-3: Flow capacity – Test procedures (IEC 60534-2-3:1997)*

EN 60534-8-3, *Industrial-process control valves – Part 8-3: Noise considerations – Control valve aerodynamic noise prediction method (IEC 60534-8-3:2000)*

EN ISO 175:2000, *Plastics – Methods of test for the determination of the effects of immersion in liquid chemicals (ISO 175:1999)*

EN ISO 9606-2:2004, *Qualification test of welders – Fusion welding – Part 2: Aluminium and aluminium alloys (ISO 9606-2:2004)*

EN ISO 9606-3, *Qualification test of welders – Fusion welding – Part 3: Copper and copper alloys (ISO 9606-3:1999)*

EN ISO 9606-4, *Qualification test of welders – Fusion welding – Part 4: Nickel and nickel alloys (ISO 9606-4:1999)*

EN ISO 15607:2003, *Specification and qualification of welding procedures for metallic materials – General rules (ISO 15607:2003)*

EN ISO 15609-1:2005, *Specification and qualification of welding procedures for metallic materials – Welding procedure specification – Part 1: Arc welding (ISO 15609-1:2004)*

EN ISO 15610:2003, *Specification and qualification of welding procedures for metallic materials – Qualification based on tested welding consumables (ISO 15610:2003)*

EN ISO 15611:2003, *Specification and qualification of welding procedures for metallic materials – Qualification based on previous welding experience (ISO 15611:2003)*

EN ISO 15612:2004, *Specification and qualification of welding procedures for metallic materials – Qualification by adoption of a standard welding procedure (ISO 15612:2004)*

EN ISO 15613:2004, *Specification and qualification of welding procedures for metallic materials – Qualification based on pre-production welding test (ISO 15613:2004)*

EN ISO 15614-1:2004, *Specification and qualification of welding procedures for metallic materials – Welding procedure test – Part 1: Arc and gas welding of steels and arc welding of nickel and nickel alloys (ISO 15614-1:2004)*

EN ISO 15614-2:2005, *Specification and qualification of welding procedures for metallic materials – Welding procedure test – Part 2: Arc welding of aluminium and its alloys (ISO 15614-2:2005)* <sup>A1</sup>

EN ISO/IEC 17025:2000, *General requirements for the competence of testing and calibration laboratories (ISO/IEC 17025:1999)*

<sup>A1</sup> deleted text <sup>A1</sup>

ISO 1817, *Rubber, vulcanized – Determination of the effect of liquids*

ISO 3419, *Non-alloy and alloy steel butt-welding fittings*

ISO 5752, *Metal valves for use in flanged pipe systems – Face-to-face and centre-to-face dimensions*

ISO 7005(all parts), *Metallic flanges*

<sup>A1</sup> deleted text <sup>A1</sup>

MSS SP 55:1985, *Quality standard for steel castings for valves, flanges and fittings and other piping components (Visual method)*

### 3 Terms, definitions and symbols

<sup>A1</sup> For the purposes of this document, the following terms, definitions and symbols apply.

NOTE Annex I list all terms in alphabetic order for English language, the relevant translation in French and German language and the relevant sub-clause of this clause. <sup>A1</sup>

#### 3.1 <sup>A1</sup> General terms and definitions of types of gas pressure regulators <sup>A1</sup>

<sup>A1</sup> deleted text <sup>A1</sup>

##### 3.1.1

##### **gas pressure regulator**

device whose function is to maintain the value of the controlled variable <sup>A1</sup> (see 3.3.4.1) <sup>A1</sup> within its tolerance field irrespective of disturbance variables

##### 3.1.2

##### **direct acting gas pressure regulator**

regulator in which the net force required to move the control member is supplied directly by the controlled variable (see example in Figure 1)