

Digital addressable lighting interface - Part 333:
**Particular requirements for control devices – Manual
configuration (feature type 33)**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN IEC 62386-333:2018 sisaldab Euroopa standardi EN IEC 62386-333:2018 ingliskeelset teksti.	This Estonian standard EVS-EN IEC 62386-333:2018 consists of the English text of the European standard EN IEC 62386-333:2018.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 01.06.2018.	Date of Availability of the European standard is 01.06.2018.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.140.50, 29.140.99

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 29.140.50; 29.140.99

English Version

**Digital addressable lighting interface - Part 333: Particular
requirements for control devices - Manual configuration (feature
type 33)
(IEC 62386-333:2018)**

Interface d'éclairage adressable numérique - Partie 333 :
Exigences particulières pour les dispositifs de commande -
Configuration manuelle (type caractéristique 33)
(IEC 62386-333:2018)

Digital adressierbare Schnittstelle für die Beleuchtung - Teil
333: Besondere Anforderungen für Eingabegeräte -
Manuelle Konfiguration (Gerätetyp 33)
(IEC 62386-333:2018)

This European Standard was approved by CENELEC on 2018-05-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 34C/1267/CDV, future edition 1 of IEC 62386-333, prepared by IEC/TC 34 "Lamps and related equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62386-333:2018.

The following dates are fixed:

- latest date by which the document has to be (dop) 2019-02-15
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2021-05-15
standards conflicting with the
document have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62386-333:2018 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61347 (series)	NOTE	Harmonized as EN 61347 (series).
IEC 61347-1	NOTE	Harmonized as EN 61347-1.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62386-101	2014	Digital addressable lighting interface - Part 101: General requirements - System components	EN 62386-101	2014
+ A1 ¹	-		+ A1 ²	-
IEC 62386-103	2014	Digital addressable lighting interface - Part 103: General requirements - Control devices	EN 62386-103	2014
+ A1 ³	-		+ A1 ⁴	-

¹ Under preparation. Stage at the time of publication: IEC CCDV 62386-101/AMD1:2018.

² Under preparation. Stage at the time of publication: EN 62386-101:2014/prA1:2017.

³ Under preparation. Stage at the time of publication: IEC RFDIS 62386-103/AMD1:2018.

⁴ Under preparation. Stage at the time of publication: EN 62386-103:2014/prA1:2017.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	8
4 General.....	9
4.1 General.....	9
4.2 Version number	9
4.3 Insulation.....	9
5 Electrical specification.....	9
6 Interface power supply	9
7 Transmission protocol structure.....	9
7.1 General.....	9
7.2 Frame format for event messages.....	9
8 Timing	10
9 Method of operation.....	10
9.1 General.....	10
9.2 Feature type	10
9.3 Events	10
9.3.1 General	10
9.3.2 Priority use	10
9.3.3 Bus usage	10
9.3.4 Encoding	11
9.3.5 Event generation	11
9.3.6 Power interruption	12
9.3.7 Manual configuration affecting multiple variables	12
9.4 Configuring the feature	12
9.4.1 General	12
9.4.2 Manual capability.....	12
9.4.3 Enable/disable manual configuration	14
9.4.4 Querying any manual configuration enabled	16
9.4.5 Manual configuration behaviour.....	16
10 Declaration of variables	17
11 Definition of commands	18
11.1 General.....	18
11.2 Overview sheets	18
11.2.1 General	18
11.2.2 Standard commands	18
11.3 Event messages	20
11.3.1 General	20
11.3.2 Manual configuration event.....	20
11.4 Device control instructions	20
11.5 Device configuration instructions.....	20
11.5.1 General	20
11.5.2 RESET	20
11.6 Device queries	20

11.7	Instance control instructions	20
11.8	Instance configuration instructions	20
11.9	Instance queries	20
11.10	Special commands	20
11.11	Feature configuration instructions	20
11.11.1	General	20
11.11.2	SET MANUAL CONFIGURATION 103 (<i>DTR0</i>)	21
11.11.3	SET MANUAL CONFIGURATION 3xx (<i>DTR0</i>)	21
11.11.4	SET MANUAL CONFIGURATION FEATURE 3xx (<i>DTR0</i>)	21
11.12	Feature queries	21
11.12.1	General	21
11.12.2	QUERY MANUAL CONFIGURATION CAPABILITY 103	22
11.12.3	QUERY MANUAL CONFIGURATION CAPABILITY 3xx	22
11.12.4	QUERY MANUAL CONFIGURATION CAPABILITY FEATURE 3xx	22
11.12.5	QUERY MANUAL CONFIGURATION 103	22
11.12.6	QUERY MANUAL CONFIGURATION 3xx	22
11.12.7	QUERY MANUAL CONFIGURATION FEATURE 3xx	23
11.12.8	QUERY ANY MANUAL CONFIGURATION ENABLED	23
Bibliography		24
Figure 1 – IEC 62386 graphical overview		6
Table 1 – 24-bit event message frame encoding ‘manual configuration’		10
Table 2 – Event source information ‘manual configuration’		11
Table 3 – “ <i>manualCapabilityDevice</i> ” encoding		13
Table 4 – “ <i>manualCapabilityInstance103</i> ” encoding		13
Table 5 – “ <i>manualConfigDevice</i> ” encoding		14
Table 6 – “ <i>manualConfigInstance103</i> ” encoding		15
Table 7 – Declaration of additions and restrictions to existing device variables		17
Table 8 – Declaration of additions and restrictions to existing instance variables		18
Table 9 – Additional feature commands		19

INTRODUCTION

IEC 62386 contains several parts, referred to as series. The 1xx series includes the basic specifications. Part 101 contains general requirements for system components, Part 102 extends this information with general requirements for control gear and Part 103 extends it further with general requirements for control devices.

The 2xx parts extend the general requirements for control gear with lamp specific extensions (mainly for backward compatibility with Edition 1 of IEC 62386) and with control gear specific features.

The 3xx parts extend the general requirements for control devices with input device specific extensions describing the instance types as well as some common features that can be combined with multiple instance types.

This first edition of IEC 62386-333 is intended to be used in conjunction with IEC 62386-101:2014, IEC 62386-101:2014/AMD1:—, IEC 62386-103:2014, IEC 62386-103:2014/AMD1:— and the parts for control devices IEC 62386-3XX. The division of IEC 62386 into separately published parts provides for ease of future amendments and revisions. Additional requirements will be added as and when a need for them is recognized.

This document, and the other parts that make up IEC 62386, in referring to any of the clauses of IEC 62386-1XX, specifies the extent to which such a clause is applicable and the order in which the tests are to be performed; the parts also include additional requirements, as necessary.

The setup of the standards is graphically represented in Figure 1 below.




Figure 1 – IEC 62386 graphical overview

Where the requirements of any of the clauses of IEC 62386-1XX are referred to in this document by the sentence "The requirements of IEC 62386-1XX, Clause "n" apply", this sentence is to be interpreted as meaning that all requirements of the clause in question of part 1XX apply, except any which are clearly inapplicable.

The standardization of the control interface for control devices is intended to achieve compatible co-existence and multi-master operation between electronic control gear and lighting control devices, below the level of building management systems. This document describes a method of implementing manual configuration for control devices.

All numbers used in this document are decimal numbers unless otherwise noted. Hexadecimal numbers are given in the format 0xVV, where VV is the value. Binary numbers are given in the format XXXXXXXXb or in the format XXXX XXXX, where X is 0 or 1; "x" in binary numbers means "don't care".

The following typographic expressions are used:

Variables: "*variableName*" or "*variableName*[3:0]", giving only bits 3 to 0 of "*variableName*".

Range of values: [lowest, highest]

Command: "COMMAND NAME".