

Gas detectors - Electrical apparatus for the detection of carbon monoxide in domestic premises - Part 1: Test methods and performance requirements

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50291-1:2018 sisaldab Euroopa standardi EN 50291-1:2018 ja selle paranduse AC:2021 ingliskeelset teksti.	This Estonian standard EVS-EN 50291-1:2018 consists of the English text of the European standard EN 50291-1:2018 and its corrigendum AC:2021.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 27.04.2018.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation. Date of Availability of the European standard is 27.04.2018.
Parandusega AC lisatud või muudetud teksti algus ja lõpp on tekstis tähistatud sümbolitega   . Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The start and finish of text introduced or altered by corrigendum AC is indicated in the text by tags   . The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.320

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Gas detectors - Electrical apparatus for the detection of carbon monoxide in domestic premises - Part 1: Test methods and performance requirements

Détecteurs de gaz - Appareils électriques pour la détection de monoxyde de carbone dans les locaux à usage domestique - Partie 1 : Méthodes d'essai et exigences de performances

Gaswarngeräte - Elektrische Geräte für die Detektion von Kohlenmonoxid in Wohnhäusern - Teil 1: Prüfverfahren und Anforderungen an das Betriebsverhalten

This European Standard was approved by CENELEC on 2018-02-26. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	7
1 Scope	8
2 Normative references	8
3 Terms and definitions	9
4 Symbols and abbreviations	11
5 Design requirements	11
5.1 General requirements	11
5.2 Construction	12
5.3 Visual indicators	12
5.4 Alarms	13
5.5 End-of-life	13
5.5.1 General	13
5.5.2 Prediction of end-of-life	13
5.5.3 Inbuilt testing of end-of-life	14
5.5.4 End of life fault warnings	14
5.6 Fault warnings	14
5.7 Alarm silence facility (optional)	14
5.8 Fault warning silence facility	15
5.9 Transmittable output signal (applicable for type A apparatus only)	15
5.10 Software-controlled apparatus	15
5.11 Labelling	15
5.12 Requirements for the use of batteries	16
5.12.1 Battery low voltage warning	16
5.12.2 Battery capacity	16
5.12.3 Battery reversal	16
5.12.4 Battery connections	17
5.12.5 Battery removal feature	17
5.13 Inter-connectable apparatus	17
5.14 Back-up power source	17
5.14.1 General	17
5.14.2 Monitoring of back-up power source	18
6 Test and performance requirements	18
6.1 General requirements for tests	18
6.1.1 Test samples for type testing	18
6.1.2 Preparation of samples	19
6.1.3 Use of mask for testing	19
6.1.4 Test chamber	19
6.1.5 Unpowered storage	19
6.2 Normal conditions for tests	19
6.2.1 General	19
6.2.2 Test gases for alarm testing	19
6.2.3 Test gases for specified tests	20
6.2.4 Speed of air and test gas	20
6.2.5 Power supply	20
6.2.6 Temperature	20
6.2.7 Humidity	20
6.2.8 Pressure	20
6.3 Test methods and performance requirements	20
6.3.1 General	20

6.3.2	CO gas test.....	20
6.3.3	Transmittable output signal	21
6.3.4	Alarm conditions	21
6.3.5	Alarm during warm-up time.....	22
6.3.6	Response and recovery to a high CO volume ratio	22
6.3.7	Temperature effects	22
6.3.8	Humidity effects.....	23
6.3.9	Air velocity test.....	23
6.3.10	Supply voltage variations (mains powered apparatus only)	23
6.3.11	Electromagnetic compatibility	23
6.3.12	Response to mixtures of carbon monoxide and other gases.....	23
6.3.13	Effects of other gases	24
6.3.14	Long term stability	25
6.3.15	Drop test.....	25
6.3.16	Alarm sound level.....	25
6.3.17	Battery fault warning.....	26
6.3.18	Battery capacity.....	27
6.3.19	Battery reversal	27
6.3.20	Battery connections with flexible leads only.....	28
6.3.21	Inter-connectable apparatus	28
6.3.22	Back-up power source	29
6.3.23	Stability in high humidity (non- condensing) test.....	29
6.3.24	Stability to low humidity test.....	29
7	Apparatus using radio links	30
7.1	General	30
7.1.1	RF range and reproducibility tests	30
7.1.2	Failure of radio link	30
7.1.3	Identification codes.....	30
7.1.4	Environmental requirements.....	30
7.2	Radio link tests	30
7.2.1	RF Range.....	30
7.2.2	Failure of radio link tests	31
7.2.3	Identification codes verification tests	31
7.2.4	Environmental tests	31
8	User instructions	32
9	Packaging.....	33
Annex A	(informative) Extended stability test – Sample protocol	34
A.1	General requirements	34
A.2	Test	34
A.3	Performance requirement.....	34
Annex B	(informative) Calculation of the expected battery service life	35
B.1	General requirements	35
B.2	Example.....	35
B.2.1	Capacity required for 1 year operation in milli Ampere hours (mAh).....	35
B.2.2	Capacity required for 4 min alarm	35
B.2.3	Capacity required for 30 days low battery beeping	35
B.2.4	Carbon Monoxide Alarm Voltage Operating Range.....	36
B.2.5	Battery Data	36
B.2.6	Expected Service Life	36

Annex C (informative) Visual and audible fault indication sequences	37
Annex D (informative) A-deviations	38
Annex E (informative) Test arrangement schematics.....	39
Annex F (informative) Additional requirements for units displaying low (warning) CO concentrations	40
F.1 General.....	40
F.2 Requirements.....	40
Bibliography	41

European foreword

This document (EN 50291-1:2018) has been prepared by Technical Committee CLC/TC 216 “Gas detectors”, the secretariat of which is held by BSI.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2019-02-26
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2021-02-26

This document supersedes EN 50291-1:2010.

The main technical changes compared to the previous edition EN 50291-1:2010 are:

- End of Life indicator has been made mandatory and must include an audible and visible warning;
- Guidance has been added for assessing battery capacity and expected life;
- Requirements for mains powered alarms with back-up supply have been added;
- The number of potential interference gases has been increased;
- Tests have been added for an optional alarm silence facility;
- Requirements for the audible alarm and associated red visual signal have been clarified; low battery, fault and End-of-life audible and visual warnings are given in an informative annex;
- An informative annex has been added for apparatus displaying low (Warning) CO levels;
- Requirements have been added for apparatus using radio links;
- The sound output alarm requirement has been increased in line with the EN 14604 smoke alarm requirements.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

1 Scope

This European Standard specifies general requirements for the construction, testing and performance of electrically operated carbon monoxide gas detection apparatus, designed for continuous operation in domestic premises. The objective is to detect defective fossil fuel or solid fuel appliances so that they can be repaired or replaced. The function of the standard is not to monitor low levels of CO for health purposes. (Annex F gives recommendations for units displaying low (warning) CO concentrations). The apparatus may be mains-powered or battery-powered. Such apparatus is intended to warn of an acute level of CO, enabling the occupant to react before being exposed to significant risk.

Additional requirements for apparatus to be used in recreational vehicles and similar premises are specified in EN 50291-2.

NOTE 1 For caravan holiday homes EN 50291-1 applies.

This European Standard specifies two types of apparatus, these are:

- type A – to provide a visual and audible alarm and an executive action in the form of a transmittable output signal that can be used to actuate directly or indirectly a ventilation or other ancillary device;
- type B – to provide a visual and audible alarm only.

NOTE 2 Both type A and type B apparatus can be interconnected.

This European Standard excludes apparatus for:

- the detection of combustible gases, other than carbon monoxide itself (see EN 50194-1);
- the detection of CO in industrial installations (see EN 45544-1, EN 45544-2 and EN 45544-3) or commercial premises;
- CO measurement for smoke and fire detection;
- CO measurement in car parks and tunnels.

NOTE 3 See EN 50545-1.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50270, *Electromagnetic compatibility — Electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen*

EN 50271:2010, *Electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen — Requirements and tests for apparatus using software and/or digital technologies*

EN 50292, *Electrical apparatus for the detection of carbon monoxide in domestic premises, caravans and boats — Guide on the selection, installation, use and maintenance*

EN 60335-1:2012, *Household and similar electrical appliances — Safety — Part 1: General requirements (IEC 60335-1:2010, modified)*