

**Cable trunking systems and cable ducting systems for electrical installations -- Part 2-2: Particular requirements for cable trunking systems and cable ducting systems intended for mounting underfloor, flushfloor, or onfloor**

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 50085-2-2:2008 sisaldab Euroopa standardi EN 50085-2-2:2008 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 05.12.2008 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 05.11.2008.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 50085-2-2:2008 consists of the English text of the European standard EN 50085-2-2:2008.

This standard is ratified with the order of Estonian Centre for Standardisation dated 05.12.2008 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 05.11.2008.

The standard is available from Estonian standardisation organisation.

ICS 29.120.10

**Võtmesõnad:**

### Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:  
Aru 10 Tallinn 10317 Eesti; [www.evs.ee](http://www.evs.ee); Telefon: 605 5050; E-post: [info@evs.ee](mailto:info@evs.ee)

**Cable trunking systems and cable ducting systems  
for electrical installations -  
Part 2-2: Particular requirements for cable trunking systems  
and cable ducting systems intended for mounting underfloor,  
flushfloor, or onfloor**

Systèmes de goulottes  
et systèmes de conduits-profilés  
pour installations électriques -  
Partie 2-2: Règles particulières  
pour les systèmes de goulottes  
et systèmes de conduits-profilés  
prévus pour être montés en sous-sol,  
encastrés dans le sol, ou sur le sol

Elektroinstallationskanalsysteme  
für elektrische Installationen -  
Teil 2-2: Besondere Anforderungen  
für Elektroinstallationskanalsysteme  
für die Montage unterboden,  
bodenbündig, oder aufboden

This European Standard was approved by CENELEC on 2008-10-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 213, Cable Management Systems.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50085-2-2 on 2008-10-01.

The following dates were fixed:

- latest date by which the EN has to be implemented  
at national level by publication of an identical  
national standard or by endorsement (dop) 2009-10-01
- latest date by which the national standards conflicting  
with the EN have to be withdrawn (dow) 2011-10-01

This European Standard is a system standard for cable management products used for electro-technical purposes. It relates to the Council Directives on the approximation of laws, regulations and administrative provisions of the Member States relating to Low Voltage Directive 2006/95/EC through consideration of the essential requirements of this directive.

This European Standard is supported by separate standards to which references are made.

This Part 2-2 is to be used in conjunction with EN 50085-1:2005 “Cable trunking systems and cable ducting systems for electrical installations - Part 1: General requirements”.

This Part 2-2 supplements or modifies the corresponding clauses of EN 50085-1:2005. Where a particular clause or subclause of Part 1 is not mentioned in this Part 2, that clause or subclause of Part 1 applies as far as it is reasonable. Where this Part 2 states “addition” or “replacement”, the relevant text of Part 1 is to be adapted accordingly.

NOTE The following numbering system is used:

- subclauses, tables and figures that are additional to those in Part 1 are numbered starting from 101;
- additional annexes are lettered AA, BB, etc.

---

## Contents

	Page
<b>1 Scope</b> .....	<b>4</b>
<b>2 Normative references</b> .....	<b>4</b>
<b>3 Definitions</b> .....	<b>4</b>
<b>4 General requirements</b> .....	<b>5</b>
<b>5 General conditions for tests</b> .....	<b>5</b>
<b>6 Classification</b> .....	<b>5</b>
<b>7 Marking and documentation</b> .....	<b>6</b>
<b>8 Dimensions</b> .....	<b>6</b>
<b>9 Construction</b> .....	<b>6</b>
<b>10 Mechanical properties</b> .....	<b>8</b>
<b>11 Electrical properties</b> .....	<b>12</b>
<b>12 Thermal properties</b> .....	<b>12</b>
<b>13 Fire hazard</b> .....	<b>12</b>
<b>14 External influences</b> .....	<b>12</b>
<b>15 Electromagnetic compatibility</b> .....	<b>13</b>
<b>Annex A (informative) Types of Cable Trunking Systems (CTS) and Cable Ducting Systems (CDS)</b> ....	<b>27</b>
<b>Annex B (informative) A-deviations</b> .....	<b>28</b>
<b>Annex C (normative) CTS/CDS IK code</b> .....	<b>28</b>
<b>Annex AA (normative) Mechanical load tests</b> .....	<b>29</b>
<b>Bibliography</b> .....	<b>31</b>
<b>Figures</b>	
Figure 101 – Types and application of CTS/CDS for underfloor, flushfloor or onfloor installations .....	14
Figure 102 – Examples of trunking and ducting installations .....	15
Figure 103 – Example of underfloor embedded CDS according to 3.101 .....	16
Figure 104 – Example of flushfloor CTS according to 3.102.....	17
Figure 105 – Example of onfloor CTS according to 3.103.....	18
Figure 106 – Principles for arrangement .....	19
Figure 107 – Examples for arrangement.....	19
Figure 108 – Load test set-up for CTS/CDS in accordance with 10.5.103.....	23
Figure 109 – Load test set-up for CTS/CDS in accordance with 10.5.104.....	26
<b>Table</b>	
Table AA.1 – Mechanical load tests .....	29

## 1 Scope

### **Replacement:**

This European Standard specifies requirements and tests for cable trunking systems (CTS) and cable ducting systems (CDS) intended for the accommodation, and where necessary for the electrically protective separation, of insulated conductors, cables and possibly other electrical equipment in electrical and/or communication systems installations. The maximum voltage of these installations is 1 000 V a.c. and 1 500 V d.c.

These systems are intended for mounting underfloor, flushfloor or onfloor.

This standard does not apply to CTS/CDS which are intended to be fixed to the wall and supported by the floor.

This standard does not apply to conduit systems, cable tray systems, cable ladder systems, power track systems or equipment covered by other standards.

This standard shall be used in conjunction with EN 50085-1:2005, Cable trunking systems and cable ducting systems for electrical installations – Part 1: General requirements, which is referred to in this document as Part 1.

## 2 Normative references

This clause of Part 1 is applicable except as follows:

**Add** the following normative references:

EN 60068-2-60	1996	Environmental testing – Part 2: Tests - Test Ke: Flowing mixed gas corrosion test (IEC 60068-2-60:1995)
EN 60068-2-75	1997	Environmental testing – Part 2-75: Tests - Test Eh: Hammer tests (IEC 60068-2-75:1997)

## 3 Definitions

This clause of Part 1 is applicable except as follows:

### **3.1 Replace** the note by:

NOTE Different types of CTS are shown in Figure 101 and explained in Clause A.2.

### **3.2 Replace** the note by:

NOTE Different types of CDS are shown in Figure 101 and explained in Clause A.2.

### **3.3 Add:**

f) service unit

**Replace** the note by:

NOTE A system does not necessarily include all system components a) to f). Different combinations of system components may be used.