

**Elektripaigaldiste kaablirennid ja kaablitorud. Osa 2-3:
Erinõuded soontega kaablitorudele, mis on mõeldud
paigaldamiseks korpusesse**

Cable trunking systems and cable ducting systems for
electrical installations - Part 2-3: Particular requirements for
slotted cable trunking systems intended for installation in
cabinets

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 50085-2-3:2010 sisaldab Euroopa standardi EN 50085-2-3:2010 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.04.2010 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 19.03.2010.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 50085-2-3:2010 consists of the English text of the European standard EN 50085-2-3:2010.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.04.2010 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 19.03.2010.

The standard is available from Estonian standardisation organisation.

ICS 29.120.10

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

English version

**Cable trunking systems and cable ducting systems
for electrical installations -
Part 2-3: Particular requirements for slotted cable trunking
systems intended for installation in cabinets**

Systèmes de goulottes et systèmes
de conduits-profilés pour installations
électriques -
Partie 2-3: Règles particulières
pour les systèmes de goulottes
de câblage pour installation
dans les armoires

Elektroinstallationskanalsysteme
für elektrische Installationen -
Teil 2-3: Besondere Anforderungen
an Verdrahtungskanäle zum Einbau
in Schaltschränke

This European Standard was approved by CENELEC on 2010-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 213, Cable management systems. It was submitted to the formal vote and was approved by CENELEC as EN 50085-2-3 on 2010-03-01.

This document supersedes EN 50085-2-3:1999 and is aligned on EN 50085-1:2005.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2011-03-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2013-03-01

This European Standard is a system standard for cable management products used for electro-technical purposes. It relates to the Council Directive on the approximation of laws, regulations and administrative provisions of the Member States relating to Low Voltage (Directive 2006/95/EC) through consideration of the essential requirements of this directive.

This European Standard is supported by separate standards to which references are made.

This Part 2-3 is to be used in conjunction with EN 50085-1:2005, "*Cable trunking systems and cable ducting systems for electrical installations – Part 1: General requirements*".

This Part 2-3 supplements or modifies the corresponding clauses of EN 50085-1:2005. Where a particular clause or subclause of Part 1 is not mentioned in this Part 2, that clause or subclause applies as far as it is reasonable. Where this Part 2 states "addition", "modification" or "replacement" the relevant text of Part 1 is to be adapted accordingly.

NOTE The following numbering system is used:

- subclauses, tables and figures that are additional to those in Part 1 are numbered starting from 101;
 - additional annexes are lettered AA, BB, etc.
-

Contents

1	Scope	4
2	Normative references	4
3	Definitions	4
4	General requirements.....	5
5	General conditions for tests.....	5
6	Classification	6
7	Marking and documentation	6
8	Dimensions.....	6
9	Construction	7
10	Mechanical properties	7
11	Electrical properties	8
12	Thermal properties	9
13	Fire hazard	9
14	External influences	10
15	Electromagnetic compatibility.....	10
	Annex A (informative) Types of cable trunking systems (CTS) and cable ducting systems (CDS)	16
	Annex B (informative) A-deviations	16
	Annex AA (normative) Compliance checks to be carried out for slotted cable trunking systems intended for installation in cabinets complying with EN 50085-2-3:1999.....	16
	Bibliography	17

Figures

Figure 101 – Examples of pattern of fixing holes in the base of the slotted trunking length.....	11
Figure 102 – Examples of sizes for the fixing holes.....	12
Figure 103 – Fixing distances for cable support test of 10.2.....	13
Figure 104 – Arrangements for cable support test of 10.2.....	14
Figure 105 – Arrangement for flame test of 13.1.3	15

1 Scope

Replacement:

This European Standard specifies requirements and tests for cable trunking systems (CTS) and cable ducting systems (CDS) intended for the accommodation, and where necessary for the electrically protective separation, of insulated conductors, cables and possibly other electrical equipment in electrical and/or communication systems installations. The maximum voltage of these installations is 1 000 V a.c. and 1 500 V d.c.

Slotted cable trunking systems are intended for mounting inside cabinets in electrical and/or communication system installations.

This European Standard does not apply to conduit systems, cable tray systems, cable ladder systems, power track systems or equipment covered by other standards.

This European Standard shall be used in conjunction with EN 50085-1:2005 “*Cable trunking systems and cable ducting systems for electrical installations – Part 1: General requirements*” which is referred to in this document as Part 1. Wherever reference is made in this European Standard to EN 50085-1:2005 this does not apply to cable ducting systems.

2 Normative references

Replacement:

EN 50085-1	2005	Cable trunking systems and cable ducting systems for electrical installations – Part 1: General requirements
EN 50085-2-3	1999	Cable trunking systems and cable ducting systems for electrical installations – Part 2-3: Particular requirements for slotted cable trunking systems intended for installation in cabinets
EN 60695-11-5	2005	Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance (IEC 60695-11-5:2004)
HD 383 S2	1986 ¹⁾	Conductors of insulated cables – First supplement: Guide to the dimensional limits of circular conductors (IEC 60228:1978, mod. + IEC 60228A:1982, mod.)

3 Definitions

For the purposes of this document, the terms and definitions of Part 1 apply except as follows.

Addition:

3.101

slotted cable trunking system

system comprising a slotted trunking length and possibly other slotted cable trunking system components for the accommodation and laying in of insulated conductors or cables intended for use in a cabinet or similar

¹⁾ Superseded by EN 60228:2005, *Conductors of insulated cables* (IEC 60228:2004).