

**Raudteelased rakendused. Püsipaigaldised.
Elektertranspordi kontaktliinid**

Railway applications - Fixed installations - Electric traction
overhead contact lines

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 50119:2009 sisaldab Euroopa standardi EN 50119:2009 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.10.2009 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 30.09.2009.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 50119:2009 consists of the English text of the European standard EN 50119:2009.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.10.2009 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 30.09.2009.

The standard is available from Estonian standardisation organisation.

ICS 29.280

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

English version

**Railway applications -
Fixed installations -
Electric traction overhead contact lines**

Applications ferroviaires -
Installations fixes -
Lignes aériennes de contact
pour la traction électrique

Bahnanwendungen -
Ortsfeste Anlagen -
Oberleitungen
für den elektrischen Zugbetrieb

This European Standard was approved by CENELEC on 2009-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by SC 9XC, Electric supply and earthing systems for public transport equipment and ancillary apparatus (Fixed installations), of Technical Committee CENELEC TC 9X, Electrical and electronic applications for railways.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50119 on 2009-04-01.

This European Standard supersedes EN 50119:2001.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2010-04-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | – |

References to definitions in IEC 60050-811 in Clause 3 are included for user reference and in some cases may update or modify the current definition.

National Standards implementing EN 50119:

The National Standards implementing EN 50119 will comprise the full text of the Eurocode (including any annexes), as published by CENELEC, which may be preceded by a national title page and national foreword, and may be followed by a National Annex.

A National Annex, if included, may contain information on those parameters or statements in EN 50119 which are not normative, e.g.

- values where alternative values or informative values only are given in the standard,
- country specific data (e.g. geographical, climatic, etc.), e.g. ice loads or temperature limits,
- the procedure to be used where alternative procedures are given in the standard.

It may also contain

- decisions on the use of informative annexes, and
- references to non-contradictory complementary information to assist the user to apply the standard.

The National Annex shall not alter any provisions of the European Standard.

Contents

	Page
1 Scope	6
2 Normative references	6
3 Terms, definitions, symbols and abbreviated terms	9
3.1 Systems	9
3.2 Conductors	10
3.3 Electrical	11
3.4 Geometrical	11
3.5 Foundations	12
3.6 Symbols and abbreviated terms	13
4 Fundamental design data	15
4.1 General	15
4.2 Line characteristics	15
4.3 Electrical power system design	15
4.4 Vehicle characteristics	16
4.5 Current collectors	16
4.6 Environmental conditions	16
4.7 Design life	16
5 System requirements	16
5.1 Design of electrical system	16
5.2 Design of current collection systems	19
5.3 Mechanical design of contact wire loads	22
5.4 Mechanical design of catenary wire loads	23
5.5 Mechanical design of other stranded conductor loads	25
5.6 Mechanical design of solid wire loads	25
5.7 Mechanical design of ropes of non-conducting materials	25
5.8 Suspension systems	26
5.9 Tensioning systems	26
5.10 Geometry of overhead equipment	26
5.11 Contact line arrangement above turnouts and crossings	29
5.12 Overlap arrangements	30
5.13 Specific requirements for overhead contact lines for trolleybus systems	30
5.14 Tolerances and limits	32
6 Structures	33
6.1 Basis of design	33
6.2 Actions on overhead contact lines	36
6.3 Types of structures and related load cases	43
6.4 Design of cross-span supports and structures	47
6.5 Foundations	50
7 Component requirements	58
7.1 General	58
7.2 Supporting assemblies	58
7.3 Contact wire	58
7.4 Other conductors and ropes	58
7.5 Tensioning devices	59
7.6 Mechanical midpoints	59
7.7 Droppers	60
7.8 Clamps and line fittings	60
7.9 Electrical connections	61
7.10 Insulators	61
7.11 Sectioning devices	61
7.12 Disconnectors and drives	62
7.13 Protection devices	62
7.14 Specific components for trolleybus systems	62

8	Testing	63
8.1	General	63
8.2	Support assemblies	63
8.3	Contact wires	73
8.4	Other conductors	73
8.5	Tensioning devices	74
8.6	Mechanical midpoints	75
8.7	Droppers	76
8.8	Clamps, splices and other fittings	78
8.9	Electrical connections	78
8.10	Insulators	79
8.11	Sectioning devices	79
8.12	Disconnectors and drives	81
8.13	Surge protection devices	81
8.14	Specific components for trolleybus systems	81
8.15	System test	81
9	Minimum documentation	82
9.1	General	82
9.2	System specification	83
9.3	Basic design	83
9.4	Installation design	83
9.5	Installation and maintenance	83
Annex A	(informative) Current carrying capacity of conductors	84
Annex B	(informative) Structural details	85
Annex C	(informative) Information on geotechnical soil investigation and soil characteristics	86
Bibliography	88

Figures

Figure 1	— Relationship between contact wire heights and pantograph operating position	29
Figure 2	— Position of return wire in relation to right-of-way	31
Figure 3	— Wind action on lattice steel structures	40
Figure 4	— Definition of drag factors for double channel structure	41
Figure 5	— Description of dimensions and minimum conductor lengths	70
Figure 6	— Potential measuring points at a connecting clamp and a butt joining clamp	71
Figure 7	— Potential measuring points at a T-type infeed terminal	71
Figure 8	— Example of a tensioning device measurement test	75
Figure 9	— Example of a dropper test cycle	77
Figure 10	— Example of a dropper tension test assembly	78
Figure 11	— Example of a test cycle for an electrical connection	79

Tables

Table 1 — Temperature limits for material mechanical properties.....	17
Table 2 — Electrical clearances	18
Table 3 — Clearance between differing phases.....	19
Table 4 — Contact force.....	21
Table 5 — Factor K_{temp} for contact wires	22
Table 6 — Factor $K_{icewind}$ for contact wires	23
Table 7 — Factor K_{temp} for stranded conductors	24
Table 8 — Factor K_{wind} for stranded conductors.....	24
Table 9 — Factor K_{ice} for stranded conductors.....	24
Table 10 — Factor K_{radius} for ropes of non-conducting materials.....	26
Table 11 — Contact wire gradients	27
Table 12 — Important parameters to assist in the definition of tolerances and limits	33
Table 13 — Recommended values for factor C_{str} for different structure types	41
Table 14 — Summary of load cases to be considered for each type of structures	46
Table 15 — Summary of partial factors for actions	47
Table 16 — Recommended values for partial factors γ_M for steel material	48
Table 17 — Recommended values for partial factors γ_M for concrete structures.....	48
Table 18 — Recommended values for partial factors γ_M for foundations	54
Table 19 — Values for shear and compressive stress in case of anchoring of steel members in concrete	56
Table 20 — Tightening torques M_t for regularly used bolts	65
Table 21 — Examples of bolt connections	65
Table 22 — Assignment of the strength of bolt and nut	66
Table 23 — Conversion factor for tightening torques	66
Table 24 — Minimum conductor lengths	70
Table A.1 — Continuous current-carrying capacity of conductors and contact wires.....	84
Table B.1 — Recommended dimensions of connections and edge distances of jointing components	85
Table C.1 — Geotechnical characteristic parameters of some standard soils according to EN 50341-1:2001, Annex N	87

1 Scope

This European Standard applies to electric traction overhead contact line systems in heavy railways, light railways, trolley busses and industrial railways of public and private operators.

It applies to new installations of overhead contact line systems and for the complete reconstruction of existing overhead contact line systems.

This standard contains the requirements and tests for the design of overhead contact lines, requirements for structures and their structural calculations and verifications as well as the requirements and tests for the design of assemblies and individual parts.

This standard does not provide requirements for conductor rail systems where the conductor rails are located adjacent to the running rails.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 206-1, *Concrete – Part 1: Specification, performance, production and conformity*

EN 485-1, *Aluminium and aluminium alloys – Sheet, strip and plate – Part 1: Technical conditions for inspection and delivery*

EN 755-1, *Aluminium and aluminium alloys- Extruded rod/bar, tube and profiles – Part 1: Technical conditions for inspection and delivery*

EN 755-2, *Aluminium and aluminium alloys – Extruded rod/bar, tube and profiles – Part 2: Mechanical properties*

EN 1536, *Execution of special geotechnical work – Bored piles*

EN 1537, *Execution of special geotechnical work – Ground anchors*

EN 1991-1-4:2005, *Eurocode 1: Actions on structures – Part 1-4: General actions – Wind actions*

ENV 1991-2-4:1995, *Eurocode 1: Basis of design and actions on structures – Part 2-4: Actions on structures – Wind actions*

EN 1992 (all parts), *Eurocode 2 – Design of concrete structures*

EN 1993 (all parts), *Eurocode 3: Design of steel structures*

EN 1993-1-1:2005, *Eurocode 3: Design of steel structures – Part 1-1: General rules and rules for buildings*

EN 1995 (all parts), *Eurocode 5: Design of timber structures*

EN 1997-1:2004, *Eurocode 7: Geotechnical design – Part 1: General rules*

EN 1997-2:2007, *Eurocode 7: Geotechnical design – Part 2: Ground investigation and testing*

EN 1998 (all parts), *Eurocode 8: Design of structures for earthquake resistance*

EN 1999 (all parts), *Eurocode 9: Design of aluminium structures*

EN 10025 (all parts), *Hot rolled products of structural steels*

- EN 10149 (all parts), *Hot-rolled flat products made of high yield strength steels for cold forming*
- EN 10164, *Steel products with improved deformation properties perpendicular to the surface of the product – Technical delivery conditions*
- EN 10210 (all parts), *Hot finished structural hollow sections of non-alloy and fine grain steels*
- EN 12510, *Wood poles for overhead lines – Strength grading criteria*
- EN 12699, *Execution of special geotechnical work – Displacement piles*
- EN 12843, *Precast concrete products – Masts and poles*
- EN 20898-2, *Mechanical properties of fasteners – Part 2: Nuts with specified proof load values – Coarse thread (ISO 898-2)*
- EN 50121-2, *Railway applications – Electromagnetic compatibility – Part 2: Emission of the whole railway system to the outside world*
- EN 50122 (all parts) ¹⁾, *Railway applications – Fixed installations – Electrical safety, earthing and bonding*
- EN 50123 (all parts), *Railway applications – Fixed installations – D.C. switchgear*
- EN 50124 (all parts), *Railway applications – Insulation coordination*
- EN 50125-2, *Railway applications – Environmental conditions for equipment – Part 2: Fixed electrical installations*
- EN 50149, *Railway applications – Fixed installations – Electric traction – Copper and copper alloy grooved contact wires*
- EN 50151, *Railway applications – Fixed installations – Electric traction – Special requirements for composite insulators*
- EN 50152-2, *Railway applications – Fixed installations – Particular requirements for a.c. switchgear – Part 2: Single-phase disconnectors, earthing switches and switches with U_n above 1 kV*
- EN 50163, *Railway applications – Supply voltages of traction systems*
- EN 50182, *Conductors for overhead lines – Round wire concentric lay stranded conductors*
- EN 50183, *Conductors for overhead lines – Aluminium-magnesium-silicon alloy wires*
- EN 50189, *Conductors for overhead lines – Zinc coated steel wires*
- EN 50206-1:1998, *Railway applications – Rolling stock – Pantographs: Characteristics and tests – Part 1: Pantographs for main line vehicles*
- EN 50206-2:1999, *Railway applications – Rolling stock – Pantographs: Characteristics and tests – Part 2: Pantographs for metros and light rail vehicles*
- EN 50317, *Railway applications – Current collection systems – Requirements for and validation of measurements of the dynamic interaction between pantograph and overhead contact line*
- EN 50318, *Railway applications – Current collection systems – Validation of simulation of the dynamic interaction between pantograph and overhead contact line*

¹⁾ At draft stage.

EN 50326, *Conductors for overhead lines – Characteristics of greases*

EN 50341-1:2001, *Overhead electrical lines exceeding AC 45 kV – Part 1: General requirements – Common specifications*

EN 50345, *Railway applications – Fixed installations – Electric traction – Insulating synthetic rope assemblies for support of overhead contact lines*

EN 50367:2006, *Railway applications – Current collection systems – Technical criteria for the interaction between pantograph and overhead line (to achieve free access)*

EN 60071 (all parts), *Insulation co-ordination* (IEC 60071, all parts)

EN 60099 (all parts), *Surge arresters* (IEC 60099, all parts, mod.)

EN 60168, *Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1 kV* (IEC 60168)

EN 60265-1, *High-voltage switches – Part 1: Switches for rated voltages above 1 kV and less than 52 kV* (IEC 60265-1)

EN 60305, *Insulators for overhead lines with a nominal voltage above 1 kV – Ceramic or glass insulator units for a.c. systems – Characteristics of insulator units of the cap and pin type* (IEC 60305)

EN 60383 (all parts), *Insulators for overhead lines with a nominal voltage above 1 kV* (IEC 60383, all parts)

EN 60433, *Insulators for overhead lines with a nominal voltage above 1 kV – Ceramic insulators for a.c. systems – Characteristics of insulator units of the long rod type* (IEC 60433)

EN 60529, *Degrees of protection provided by enclosures (IP Code)* (IEC 60529)

EN 60660, *Insulators – Tests on indoor post insulators of organic material for systems with nominal voltages greater than 1 kV up to but not including 300 kV* (IEC 60660)

EN 60672 (all parts), *Ceramic and glass insulating materials* (IEC 60672, all parts)

EN 60889, *Hard-drawn aluminium wire for overhead line conductors* (IEC 60889)

EN 60947-1, *Low-voltage switchgear and controlgear – Part 1: General rules* (IEC 60947-1)

EN 61109, *Insulators for overhead lines - Composite suspension and tension insulators for a.c. systems with a nominal voltage > 1 000 V - Definitions, test methods and acceptance criteria* (IEC 61109)

EN 61232, *Aluminium-clad steel wires for electrical purposes* (IEC 61232, mod.)

EN 61284:1997, *Overhead lines – Requirements and tests for fittings* (IEC 61284:1997)

EN 61325, *Insulators for overhead lines with a nominal voltage above 1 kV – Ceramic or glass insulator units for d.c. systems – Definitions, test methods and acceptance criteria* (IEC 61325)

EN 61773, *Overhead lines – Testing of foundations for structures* (IEC 61773)

EN 61952, *Insulators for overhead lines - Composite line post insulators for A.C. systems with a nominal voltage > 1 000 V - Definitions, test methods and acceptance criteria* (IEC 61952)

EN 62271-102:2002, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches* (IEC 62271-102:2001 + corrigendum April 2002 + corrigendum May 2003)

EN ISO 898-1:1999, *Mechanical properties of fasteners made of carbon steel and alloy steel – Part 1: Bolts, screws and studs* (ISO 898-1:1999)

EN ISO 1461:1999, *Hot dip galvanized coatings on fabricated iron and steel articles – Specifications and test methods* (ISO 1461:1999)

HD 578, *Characteristics of indoor and outdoor post insulators for systems with nominal voltages greater than 1 kV* (IEC 60273)

IEC 60050-811, *International Electrotechnical Vocabulary (IEV) – Chapter 811: Electric traction*

IEC/TR 61245, *Artificial pollution tests on high-voltage insulators to be used on d.c. systems*

3 Terms, definitions, symbols and abbreviated terms

For the purposes of this document, the terms and definitions given in IEC 60050-811 and the following apply.

3.1 Systems

3.1.1

contact line system

support network for supplying electrical energy from substations to electrically powered traction units, which covers overhead contact line systems and conductor rail systems; the electrical limits of the system are the feeding point and the contact point to the current collector

NOTE The mechanical system may comprise

- the contact line,
- structures and foundations,
- supports and any components supporting or registering the conductors,
- head and cross spans,
- tensioning devices,
- along-track feeders, reinforcing feeders, and other lines like earth wires and return conductors as far as they are supported from contact line system structures,
- any other equipment necessary for operating the contact line,
- conductors connected permanently to the contact line for supply of other electrical equipment such as lights, signal operation, point control and point heating.

3.1.2

contact line

conductor system for supplying traction units with electrical energy via current-collection equipment

NOTE This includes all current-collecting conductors and conducting rails or bars, including the following:

- reinforcing feeders;
- cross-track feeders;
- disconnectors;
- section insulators;
- over-voltage protection devices;
- supports that are not insulated from the conductors;
- insulators connected to live parts;

but excluding other conductors, such as the following:

- along-track feeders;
- earth wires and return conductors.