Kaablite ühtsed tulekatsetusmeetodid. Katsed kaablitest materjalide põlemisel eralduvatele gaasidele. Osa 2-1: Protseduurid. Halogeenhappegaasi koguse kindlaksmääramine

Common test methods for cables under fire conditions - Tests on gases evolved during combustion of materials from cables - Part 2-1:Procedures - Determination of the amount of halogen acid gas



# **EESTI STANDARDI EESSÕNA**

# **NATIONAL FOREWORD**

Käesolev Eesti standard EVS-EN 50267-2-1:2001 sisaldab Euroopa standardi EN 50267-2-1:1998 ingliskeelset teksti.

Käesolev dokument on jõustatud 19.06.2001 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 50267-2-1:2001 consists of the English text of the European standard EN 50267-2-1:1998.

This document is endorsed on 19.06.2001 with the notification being published in the official publication of the Estonian national standardisation organisation.

The standard is available from Estonian standardisation organisation.

#### Käsitlusala:

This part 2 of EN 50267 specifies the procedures for the determination of the amount of halogen acid gas, other than hydroflouric acid, evovled during the combustion of compunds based on halogeneated polymers and compunds containing halogenated additives taken from cable constructions.

### Scope:

This part 2 of EN 50267 specifies the procedures for the determination of the amount of halogen acid gas, other than hydroflouric acid, evovled during the combustion of compunds based on halogeneated polymers and compunds containing halogenated additives taken from cable constructions.

ICS 13.220.40, 29.060.20

**Võtmesõnad:** acidity, burning gases, combustion products, combustion tests, corrosive gases, corrosivity, determination, electrical cables, electrical installations, fire tests, procedure, testing conditions

# EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 50267-2-1

June 1998

ICS 13.220.40; 29.060.20

Descriptors: Electrical installation, electrical cables, fire tests, combustion tests, combustion products, burning gases, corrosive gases, determination, acidity, corrosivity, testing conditions, procedure

English version

Common test methods for cables under fire conditions
Tests on gases evolved during combustion of materials from cables
Part 2-1: Procedures - Determination of the amount of halogen acid gas

Méthodes d'essai communes aux câbles soumis au feu - Essais sur les gaz émis lors de la combustion d'un matériau prélevé sur un câble

Partie 2-1: Procédures - Détermination de la quantité de gaz acides halogénés

Allgemeine Prüfverfahren für das Verhalten von Kabeln und isolierten Leitungen im Brandfall - Prüfung der bei der Verbrennung der Werkstoffe von Kabeln und isolierten Leitungen entstehenden Gase Teil 2-1: Prüfverfahren - Bestimmung

des Gehaltes an Halogenwasserstoffsäure

This European Standard was approved by CENELEC on 1998-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

# **CENELEC**

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

<sup>© 1998</sup> CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

#### **FOREWORD**

This European Standard was prepared by the Technical Committee CENELEC TC20, Electric Cables.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 50267-2-1 on 1998-04-01.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 1999-03-01
- latest date by which national standards conflicting with the EN have to be withdrawn (dow) 2000-03-01

Annexes designated "normative" are part of the body of the standard. Annexes designated "informative" are given for information only. In this standard annex A is informative. There is no normative annex.

# **CONTENTS**

		Page
1.	Scope	4
2.	Normative references	4
3.	Definition	4
4.	Test apparatus	4
5.	Procedure	5
	<ul> <li>5.1 General principle</li> <li>5.2 Samples</li> <li>5.3 Conditioning of the samples</li> <li>5.4 Combustion</li> </ul>	5 5 5 5
6.	Determination of halogen acid content	6
	X A: Performance requirements (Informative)	7
		5

#### 1. Scope

EN 50267-2-1 specifies the procedure for the determination of the amount of halogen acid gas, other than hydrofluoric acid, evolved during the combustion of compounds based on halogenated polymers, and compounds containing halogenated additives, taken from cable constructions.

For reasons of accuracy this method is not recommended for use where the amount of halogen acid evolved is less than 5 mg/g of the sample taken.

This method is not suitable for defining compounds or materials described as 'zero-halogen' or 'halogen-free'. For such compounds or materials, and all compounds or materials containing less than 5 mg/g halogen acid equivalent, it is recommended to use the method specified in EN 50267-2-2.

#### 2. Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

EN 50267-1: Common test methods for cables under fire conditions. Tests on gases evolved during the combustion of materials from cables. Part 1: Apparatus.

EN 60695-4: Fire hazard testing: Part 4: Terminology concerning fire test.

Note: IEC 60695 is in the course of re-numbering its Parts and Sections. This will also affect the equivalent ENs.

#### 3. Definition

For the purposes of EN 50267-2-1 the following definition applies. The definition is taken from EN 60695-4.

3.1 **Combustion**: Exothermic reaction of a substance with an oxidizer with emission of effluent, generally accompanied by flames and/or glowing and/or emission of smoke.

## 4. Test apparatus

The apparatus used shall be that specified in EN 50267-1.