

Pump system energy assessment (ISO/ASME
14414:2019)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 14414:2019 sisaldab Euroopa standardi EN ISO 14414:2019 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 14414:2019 consists of the English text of the European standard EN ISO 14414:2019.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 27.02.2019.	Date of Availability of the European standard is 27.02.2019.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 23.080

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Pump system energy assessment (ISO/ASME 14414:2019)

Évaluation énergétique des systèmes de pompage
(ISO/ASME 14414:2019)

Energetische Bewertung von Pumpensystemen
(ISO/ASME 14414:2019)

This European Standard was approved by CEN on 27 December 2018.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

This document (EN ISO 14414:2019) has been prepared by Technical Committee ISO/TC 115 "Pumps" in collaboration with Technical Committee CEN/TC 197 "Pumps" the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2019, and conflicting national standards shall be withdrawn at the latest by August 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 14414:2015.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO/ASME 14414:2019 has been approved by CEN as EN ISO 14414:2019 without any modification.

Contents

Page

Foreword	v
Introduction	vii
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Identification of the assessment team, authority and functions	2
4.1 Identification of assessment team functions	2
4.2 Assessment team structure, leadership and competency	3
4.3 Facility management support	3
4.4 Communications	3
4.5 Access to facilities, personnel and information	4
4.6 Assessment objectives, scope and boundaries	4
4.7 Action plan	4
4.7.1 General	4
4.7.2 Assessment scheduling	5
4.8 Initial data collection and evaluation	5
4.8.1 General	5
4.8.2 Initial facility specialist interviews	5
4.8.3 Energy project history	6
4.8.4 Energy cost	6
4.8.5 Initial system data	6
4.9 Objective check	6
5 Conducting the assessment	6
5.1 Assessment levels	6
5.1.1 General	6
5.1.2 Level 1 assessments	7
5.1.3 Level 2 assessments	8
5.1.4 Level 3 assessments	8
5.2 Walk through	9
5.3 Understanding system functional requirements	10
5.4 Determining system boundaries and system energy demand	10
5.5 Information needed to assess the efficiency of a pumping system	10
5.5.1 General	10
5.5.2 Electrical motor/drive information	10
5.5.3 Pump information	11
5.5.4 Liquid properties information	12
5.5.5 Detailed system data	12
5.5.6 Measured data	13
5.6 Data collection	14
5.6.1 System information	14
5.6.2 Measurement of pump and motor operating data	14
5.6.3 Pressure	14
5.6.4 Flow	14
5.6.5 Input power	15
5.7 Cross validation	15
5.8 Wrap-up meeting and presentation of initial findings and recommendations	15
6 Reporting and documentation	16
6.1 Final assessment report	16
6.2 Data for third party review	16
6.3 Review of final report by assessment team members	16
Annex A (normative) Report contents	17

Annex B (informative) Recommendations on efficient system operation and energy reduction — Examples	21
Annex C (informative) Expertise, experience and competencies	39
Annex D (informative) Recommended guidelines for analysis software	42
Annex E (informative) Example of pre-screening worksheet	44
Annex F (informative) Specific energy consumption	46
Annex G (informative) Pumping system parasitic power	50
Annex H (informative) Example of pumping system efficiency indicator	53
Bibliography	56

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 115, *Pumps*, in collaboration with ASME EA Standards Committee — *Industrial System Energy Assessment*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

This second edition cancels and replaces the first edition (ISO 14414:2015), which has been technically revised. It also incorporates the Amendment ISO 14414:2015/Amd.1:2016. The main changes compared to the previous edition are as follows:

- [4.2](#) has been slightly modified;
- [Table 2](#) has been modified to add descriptions of “histogram” and “duration” diagrams;
- [5.6.4](#) has been redrafted;
- the term “specific energy” has been replaced by “specific energy consumption”;
- [Formulae G.1, G.2 and G.4](#) have been corrected to align with ISO 17769-1;
- the bibliography has been modified;
- the document has been editorially revised.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the standard was balanced to ensure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve”, “rate”, or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to ensure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this standard.

ASME accepts responsibility for only those interpretations of designated documents issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals. ASME will not issue written interpretations of this edition of this standard.

ISO/ASME 14414 was approved as an American National Standard by the American National Standards Institute on 2015-02-06.

Introduction

Pumping systems account for a significant portion of a facility's energy consumption in many industries. In the majority of pumping systems, the energy added to the working liquid by the pump is much greater than is required by the process. The excess energy added to the system (e.g. due to throttled control valve) increases heat, noise and vibration but also increases the system's maintenance costs. Oversized pumps will cause excessive energy within a system. Increasing the size of the components within the system such as pipes, valves and heat exchangers can, however, result in lower energy consumption.

This document provides a method to assess pump systems, to identify and quantify pump system energy consumption reduction opportunities and reliability improvement opportunities. It gives a common definition for what constitutes an assessment for both users and providers of assessment services. Its objective is to provide clarity for these types of services which have been variously described as energy assessments, energy audits, energy surveys and energy studies.

In all cases, systems (energy-using logical groups of equipment organized to perform a specific function) are analysed through various techniques such as measurement, resulting in identification, documentation and prioritization of energy performance improvement opportunities.

When contracting for assessment services, facility personnel can use this document to define and communicate their desired scope of assessment activity to third party contractors or consultants.

This document is expected to contribute to decreased energy consumption and consequently to decreased carbon footprint.

This document includes the required assessment report content in [Annex A](#). It gives examples of efficient system operation and energy reduction opportunities in [Annex B](#), information on competencies and experiences welcomed to perform audit in [Annex C](#), guidelines for analysis software in [Annex D](#), a typical example of pre-screening worksheet in [Annex E](#), information on specific energy consumption in [Annex F](#), information on the concept of parasitic power in [Annex G](#) and examples of pumping system efficiency indicator in [Annex H](#).

This document is developed within the framework of ISO 50001, ISO 50002 and ISO 50003.

Pump system energy assessment

1 Scope

This document sets the requirements for conducting and reporting the results of a pumping system energy assessment (hereafter referenced as “assessment”) that considers the entire pumping system, from energy inputs to the work performed as the result of these inputs.

The objective of a pumping system energy assessment is to determine the current energy consumption of an existing system and identify ways to improve system efficiency.

These requirements consist of

- organizing and conducting an assessment,
- analysing the data from the assessment, and
- reporting and documenting assessment findings.

This document is designed to be applied, to open and closed loop pumping systems typically used at industrial, institutional, commercial, and municipal facilities, when requested.

This document is focused on assessing electrically-driven pumping systems, which are dominant in most facilities, but is also applicable with other types of drivers, such as steam turbines and engines. The document does not

- a) specify how to design a pumping system,
- b) give detailed qualifications and expertise required of the person using the International Standard although provides a list of body of knowledge in [Annex C](#),
- c) address the training or certification of persons,
- d) specify how to implement the recommendations developed during the assessment, but does include requirements for an action plan,
- e) specify how to measure and validate the energy savings that result from implementing assessment recommendations,
- f) specify how to make measurements and how to calibrate test equipment used during the assessment,
- g) specify how to estimate the implementation cost or conduct financial analysis for recommendations developed during the assessment,
- h) specify specific steps required for safe operation of equipment during the assessment. The facility personnel in charge of normal operation of the equipment are responsible for ensuring that it is operated safely during the data collection phase of the assessment,
- i) address issues of intellectual property, security, confidentiality, and safety.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 17769-1, *Liquid pumps and installation — General terms, definitions, quantities, letter symbols and units — Part 1: Liquid pumps*

ISO 17769-2, *Liquid pumps and installation — General terms, definitions, quantities, letter symbols and units — Part 2: Pumping system*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 17769-1, ISO 17769-2 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1 system energy demand

minimum amount of energy which a pumping system in a specified process requires

3.2 components

individual items of equipment within a system

EXAMPLE Pump, motor, drive, valve, heat exchanger.

3.3 hydraulic power pump power output

power imparted to the liquid by the pump

3.4 electrical power input

power required to support the pumping system operation

3.5 specific energy consumption

energy consumed to move a certain volume of liquid through the system

3.6 parasitic power

power imparted to the shaft of a pump and not used to move the fluid through the system

4 Identification of the assessment team, authority and functions

4.1 Identification of assessment team functions

The assessment team composed of knowledgeable personnel shall have members that are assigned responsibility and authority to carry out the following functions.

- Resource allocation, in order to:
 - allocate funding and resources necessary to plan and execute the assessment;
 - exercise final decision making authority on resources;