

**Analoog- ja digitaalkommunikatsioonis ja -
juhtimises kasutatavad mitmeelemendilised
metallkaablid. Osa 7: Seadistus- ja juhtimiskaablite
liigitus**

Multi-element metallic cables used in analogue and
digital communication and control Part 7: Sectional
specification for instrumentation and control cables

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 50288-7:2005 sisaldab Euroopa standardi EN 50288-7:2005 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 28.10.2005 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 30.09.2005.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 50288-7:2005 consists of the English text of the European standard EN 50288-7:2005.

This standard is ratified with the order of Estonian Centre for Standardisation dated 28.10.2005 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 30.09.2005.

The standard is available from Estonian standardisation organisation.

ICS 33.120.10

Võtmesõnad:

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

**Multi-element metallic cables used
in analogue and digital communication and control
Part 7: Sectional specification
for instrumentation and control cables**

Câbles métalliques à éléments multiples
utilisés pour les transmissions et les
commandes analogiques et numériques
Partie 7: Spécification intermédiaire
pour les câbles d'instrumentation
et de contrôle

Mehradrige metallische Daten-
und Kontrollkabel für analoge
und digitale Übertragung
Teil 7: Rahmenspezifikation
für Instrumenten- und Kontrollkabel

This European Standard was approved by CENELEC on 2005-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard was prepared by SC 46XC, Multicore, Multipair and Quad Data communication cables, of Technical Committee CENELEC TC 46X, Communication cables.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 50288-7 on 2005-04-01.

This Part 7 is to be used in conjunction with EN 50288-1.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2006-04-01
 - latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2008-04-01
-

Contents

1	Scope.....	5
2	Normative references.....	5
3	Definitions, symbols and abbreviations	6
4	Cable construction	6
4.1	Conductor	6
4.2	Insulation	7
4.3	Cable elements.....	7
4.4	Identification of cabling elements.....	8
4.5	Screening of cabling elements.....	8
4.6	Cable make-up	8
4.7	Filling compound.....	8
4.8	Interstitial fillers.....	8
4.9	Screening of the cable core	8
4.10	Moisture barriers.....	9
4.11	Protective wrappings.....	9
4.12	Inner sheath.....	10
4.13	Bedding layers	10
4.14	Metallic protection	10
4.15	Integral suspension strand.....	11
4.16	Outer sheathing	11
4.17	Fauna protection.....	11
4.18	Chemical and/or environmental protection	11
4.18.1	Lead sheath	12
4.18.2	Multi-layer sheath.....	12
5	Test methods and requirements for completed cables.....	12
5.1	Electrical tests.....	13
5.1.1	Low frequency and d.c. electrical measurements.....	13
5.2	Mechanical tests	13
5.3	Environmental tests	14
5.4	Fire performance test methods	14
	Annex A (normative) Insulation thickness and concentricity - Selection of samples and evaluation of results.....	15
	Annex B (normative) Copper braid screening	16
	Annex C (normative) Determination of cable dimensions	17
	Annex D (informative) Thermocouple extension and compensating conductors.....	22

Table 1 – Minimum insulation thickness	7
Table B.1 – Braid wire diameter.....	16
Table C.1 – Steps to determine fictitious cable diameter	17
Table C.2 – Conductor diameters	18
Table C.3 – Lay up factors	19
Table C.4 – Crush factors.....	19
Table C.5 – Bedding radial thickness	20
Table C.6 – Round armour wire.....	20
Table C.7 – Tape armour	20
Table C.8 – Braid armour wire size.....	21
Table D.1 – Extension cables	22
Table D.2 – Compensating cables.....	22

This document is a preview generated by EVS

1 Scope

This sectional specification covers multi-element cables suitable for connecting instruments and control systems for analogue or digital signal transmission. They may or may not be screened and optionally may incorporate armouring and/or moisture or environmental protection layers.

The cables shall have a mechanically robust construction and electrical transmission handling properties. The electrical, mechanical, transmission and environmental performance characteristics of the cables, related to their reference test methods are detailed.

This sectional specification is to be read in conjunction with EN 50288-1, which contains the essential provisions for its application.

Cables covered by this specification have maximum rated voltages of 90 V, 300 V and 500 V a.c.

These cables shall not be connected directly to mains electricity supply or other low impedance sources. Multi-element cables for use in analogue, digital and control circuits are not designed to be used for power supply.

These cables should be installed in accordance with the applicable local and national regulations.

Cables intended to have limited circuit integrity in a fire are not covered by this specification, but they are however under consideration for future editions.

There may be occasions when cables are required to have higher operating temperature ratings than those provided by using materials specified by the EN 50290 series. Suitable alternative materials are under consideration.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>
EN 10218-1	-	Steel wire and wire products – General – Part 1: Test methods
EN 10244-2	-	Steel wire and wire products – Non-ferrous metallic coatings on steel wire – Part 2: Zinc or zinc alloy coatings
EN 10257-1	-	Zinc or zinc alloy coated non-alloy steel wire for armouring either power cables or telecommunications cables – Part 1: Land cables
EN 50289	Series	Communication cables - Specifications for test methods
EN 50290	Series	Communication cables
EN 50307	-	Lead and lead alloy sheath and sleeves of electric cables

EN 60708	-	Low-frequency cables with polyolefin insulation and moisture barrier polyolefin sheath (IEC 60708)
EN 60811-1-1	-	Insulating and sheathing materials of electric and optical cables – Common test methods – Part 1-1: General application – Measurement of thickness and overall dimensions – Tests for determining the mechanical properties (IEC 60811-1-1)
HD 383 S2	-	Conductors of insulated cables First supplement: Guide to the dimensional limits of circular conductors (IEC 60228 + IEC 60228A, mod.)
HD 446.3 S1	-	Thermocouples - Part 3: Extension and compensating cables – tolerances and identification system (IEC 60584-3, mod.)
IEC 60189-2	-	Low-frequency cables and wires with PVC insulation and PVC sheath - Part 2: Cables in pairs, triples, quads and quintuples for inside installations

3 Definitions, symbols and abbreviations

For the purposes of this European Standard the definitions of EN 50288-1 apply in addition to the following:

3.1

foil

a metal tape laminated to a plastic tape

4 Cable construction

4.1 Conductor

Except for thermocouple extension and compensating cables, with conductors as described in Annex D, conductors shall be solid, stranded or flexible plain or metal coated copper in accordance with Class 1, 2 or 5 of HD 383 in the range of 0,5 mm² to 2,5 mm². For multi-core cables the maximum conductor resistance shall be as HD 383, and for finished multi-pair, multi-triple and multi-quad cables the maximum resistance of HD 383 shall be increased by 2 %.

Conductor joints shall be as EN 50288-1.

Stranded and flexible conductors shall consist of wires circular in cross section assembled, without insulation between them, by concentric stranding or by bunching.

When the installed length of cable results in a high conductor resistance, larger conductor sizes can be used.