

**Hearing aids - Part 6: Characteristics of electrical input
circuits for hearing aids**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 60118-6:2002 sisaldab Euroopa standardi EN 60118-6:1999 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 18.12.2002 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 10.08.1999.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 60118-6:2002 consists of the English text of the European standard EN 60118-6:1999.

This standard is ratified with the order of Estonian Centre for Standardisation dated 18.12.2002 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 10.08.1999.

The standard is available from Estonian standardisation organisation.

ICS 17.140.50

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

English version

Hearing aids
Part 6: Characteristics of electrical input circuits for hearing aids
(IEC 60118-6:1999)

Appareils de correction auditive
Partie 6: Caractéristiques des circuits
d'entrée électriques des appareils de
correction auditive
(CEI 60118-6:1999)

Hörgeräte
Teil 6: Eigenschaften elektrischer
Eingänge von Hörgeräten
(IEC 60118-6:1999)

This European Standard was approved by CENELEC on 1999-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 29/430/FDIS, future amendment to IEC 60118-6, prepared by IEC TC 29, Electroacoustics, was submitted to the IEC-CENELEC parallel vote.

The text of this document, together with that of IEC 60118-6:1984 was approved by CENELEC as EN 60118-6 on 1999-08-01.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2000-05-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2002-08-01

Annexes designated "normative" are part of the body of the standard.

In this standard, annex ZA is normative.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60118-6:1999 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE: When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60065 (mod)	1998	Audio, video and similar electronic apparatus - Safety requirements	EN 60065 + corr. June	1998 1999
IEC 60118-0	1983	Hearing aids Part 0: Measurement of electroacoustical characteristics	EN 60118-0	1993
A1	1994		A1	1994
IEC 60118-12	1996	Part 12: Dimensions of electrical connector systems	EN 60118-12	1996

**NORME
INTERNATIONALE
INTERNATIONAL
STANDARD**

**CEI
IEC**

60118-6

Deuxième édition
Second edition
1999-06

Appareils de correction auditive –

Partie 6:

**Caractéristiques des circuits d'entrée électriques
des appareils de correction auditive**

Hearing aids –

Part 6:

**Characteristics of electrical input circuits
for hearing aids**



Numéro de référence
Reference number
CEI/IEC 60118-6:1999

Numéros des publications

Depuis le 1er janvier 1997, les publications de la CEI sont numérotées à partir de 60000.

Publications consolidées

Les versions consolidées de certaines publications de la CEI incorporant les amendements sont disponibles. Par exemple, les numéros d'édition 1.0, 1.1 et 1.2 indiquent respectivement la publication de base, la publication de base incorporant l'amendement 1, et la publication de base incorporant les amendements 1 et 2.

Validité de la présente publication

Le contenu technique des publications de la CEI est constamment revu par la CEI afin qu'il reflète l'état actuel de la technique.

Des renseignements relatifs à la date de reconfirmation de la publication sont disponibles dans le Catalogue de la CEI.

Les renseignements relatifs à des questions à l'étude et des travaux en cours entrepris par le comité technique qui a établi cette publication, ainsi que la liste des publications établies, se trouvent dans les documents ci-dessous:

- **«Site web» de la CEI***
- **Catalogue des publications de la CEI**
Publié annuellement et mis à jour régulièrement
(Catalogue en ligne)*
- **Bulletin de la CEI**
Disponible à la fois au «site web» de la CEI* et comme périodique imprimé

Terminologie, symboles graphiques et littéraux

En ce qui concerne la terminologie générale, le lecteur se reportera à la CEI 60050: *Vocabulaire Electrotechnique International* (VEI).

Pour les symboles graphiques, les symboles littéraux et les signes d'usage général approuvés par la CEI, le lecteur consultera la CEI 60027: *Symboles littéraux à utiliser en électrotechnique*, la CEI 60417: *Symboles graphiques utilisables sur le matériel. Index, relevé et compilation des feuilles individuelles*, et la CEI 60617: *Symboles graphiques pour schémas*.

* Voir adresse «site web» sur la page de titre.

Numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series.

Consolidated publications

Consolidated versions of some IEC publications including amendments are available. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Validity of this publication

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology.

Information relating to the date of the reconfirmation of the publication is available in the IEC catalogue.

Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is to be found at the following IEC sources:

- **IEC web site***
- **Catalogue of IEC publications**
Published yearly with regular updates
(On-line catalogue)*
- **IEC Bulletin**
Available both at the IEC web site* and as a printed periodical

Terminology, graphical and letter symbols

For general terminology, readers are referred to IEC 60050: *International Electrotechnical Vocabulary* (IEV).

For graphical symbols, and letter symbols and signs approved by the IEC for general use, readers are referred to publications IEC 60027: *Letter symbols to be used in electrical technology*, IEC 60417: *Graphical symbols for use on equipment. Index, survey and compilation of the single sheets* and IEC 60617: *Graphical symbols for diagrams*.

* See web site address on title page.

**NORME
INTERNATIONALE
INTERNATIONAL
STANDARD**

**CEI
IEC**

60118-6

Deuxième édition
Second edition
1999-06

Appareils de correction auditive –

Partie 6:

**Caractéristiques des circuits d'entrée électriques
des appareils de correction auditive**

Hearing aids –

Part 6:

**Characteristics of electrical input circuits
for hearing aids**

© IEC 1999 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photo-copie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission
Telefax: +41 22 919 0300

3, rue de Varembe, Geneva, Switzerland
e-mail: inmail@iec.ch IEC web site: <http://www.iec.ch>



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

E

Pour prix, voir catalogue en vigueur
For price, see current catalogue

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

APPAREILS DE CORRECTION AUDITIVE –

Partie 6: Caractéristiques des circuits d'entrée électriques des appareils de correction auditive

AVANT-PROPOS

- 1) La CEI (Commission Electrotechnique Internationale) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI, entre autres activités, publie des Normes internationales. Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible un accord international sur les sujets étudiés, étant donné que les Comités nationaux intéressés sont représentés dans chaque comité d'études.
- 3) Les documents produits se présentent sous la forme de recommandations internationales. Ils sont publiés comme normes, rapports techniques ou guides et agréés comme tels par les Comités nationaux.
- 4) Dans le but d'encourager l'unification internationale, les Comités nationaux de la CEI s'engagent à appliquer de façon transparente, dans toute la mesure possible, les Normes internationales de la CEI dans leurs normes nationales et régionales. Toute divergence entre la norme de la CEI et la norme nationale ou régionale correspondante doit être indiquée en termes clairs dans cette dernière.
- 5) La CEI n'a fixé aucune procédure concernant le marquage comme indication d'approbation et sa responsabilité n'est pas engagée quand un matériel est déclaré conforme à l'une de ses normes.
- 6) L'attention est attirée sur le fait que certains des éléments de la présente Norme internationale peuvent faire l'objet de droits de propriété intellectuelle ou de droits analogues. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de propriété et de ne pas avoir signalé leur existence.

La Norme internationale CEI 60118-6 a été établie par le comité d'études 29 de la CEI: Electroacoustique.

Cette deuxième édition annule et remplace la première édition parue en 1984.

Le texte de cette norme est issu des documents suivants:

FDIS	Rapport de vote
29/430/FDIS	29/434/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette norme.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HEARING AIDS –

**Part 6: Characteristics of electrical input circuits
for hearing aids**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60118-6 has been prepared by IEC technical committee 29: Electroacoustics.

This second edition cancels and replaces the first edition published in 1984.

The text of this standard is based on the following documents:

FDIS	Report on voting
29/430/FDIS	29/434/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

INTRODUCTION

Un appareil de correction auditive individuel est un dispositif qui amplifie le son et qui est normalement porté par un malentendant. Habituellement, les entrées de tels appareils sont acoustiques (microphone) ou électromagnétiques (bobine d'induction captrice).

Cependant, il peut être nécessaire pour les besoins d'enseignement par exemple, de connecter électriquement l'appareil de correction auditive à la sortie électrique d'une source extérieure de signal, telle qu'un récepteur radiophonique à modulation de fréquence, un magnétophone, un dispositif infrarouge ou un microphone extérieur. Les caractéristiques requises pour une telle entrée sont données dans la présente Norme internationale.

This document is a preview generated by EVS

INTRODUCTION

A personal hearing aid is a device which amplifies sound and is normally worn by a person whose hearing is impaired. The usual inputs to such an aid are acoustic through the microphone, or electro-magnetic through the induction pick-up coil.

However, there is a need, for example for educational purposes, for an electrical connection between the hearing aid and the electrical output of a signal source, such as a radio FM system, tape recorder, infra-red system or external microphone. The required characteristics for such an input are given in this International Standard.

This document is a preview generated by EVS

APPAREILS DE CORRECTION AUDITIVE –

Partie 6: Caractéristiques des circuits d'entrée électriques des appareils de correction auditive

1 Domaine d'application

La présente partie de la CEI 60118 donne des spécifications concernant les caractéristiques électriques et la sécurité pour une entrée électrique extérieure d'un appareil de correction auditive individuel, afin de s'assurer de sa compatibilité avec les sources extérieures de signaux électriques ou électroacoustiques. Dans cette norme, l'appareil de correction auditive peut comprendre un adaptateur (socle audio) qui incorpore les systèmes de connexion décrits dans la CEI 60118-12.

2 Références normatives

Les documents normatifs suivants contiennent des dispositions qui, par suite de la référence qui y est faite, constituent des dispositions valables pour la présente partie de la CEI 60118. Pour les références datées, les amendements ultérieurs ou les révisions de ces publications ne s'appliquent pas. Toutefois, les parties prenantes aux accords fondés sur la présente partie de la CEI 60118 sont invitées à rechercher la possibilité d'appliquer les éditions les plus récentes des documents normatifs indiqués ci-après. Pour les références non datées, la dernière édition du document normatif en référence s'applique. Les membres de la CEI et de l'ISO possèdent le registre des Normes internationales en vigueur.

CEI 60065, *Appareils audio, vidéo et appareils électroniques analogues – Exigences de sécurité*

CEI 60118-0, *Appareils de correction auditive – Partie 0: Méthodes de mesure des caractéristiques électroacoustiques*
Amendement 1

CEI 60118-12, *Appareils de correction auditive – Partie 12: Dimensions des connecteurs électriques*

3 Caractéristiques électriques

3.1 Impédance d'entrée

Le module de l'impédance présentée entre les bornes d'entrée du signal doit être au moins de 2 000 Ω dans la gamme de fréquences comprise entre 200 Hz et 10 kHz, et doit être spécifié par le constructeur.

HEARING AIDS –

Part 6: Characteristics of electrical input circuits for hearing aids

1 Scope

This part of IEC 60118 specifies the electrical and safety characteristics of a circuit for an external electrical input to a personal hearing aid in order to ensure compatibility with external electrical or electroacoustic signal sources. In this standard, the hearing aid may include an adaptor (audio shoe) which incorporates connector systems described in IEC 60118-12.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of IEC 60118. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of IEC 60118 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 60065, *Audio video and similar electronic apparatus – Safety requirements*

IEC 60118-0, *Hearing aids – Part 0: Measurement of electroacoustical characteristics*
Amendment 1

IEC 60118-12, *Hearing aids – Part 12: Dimensions of electrical connector systems*

3 Electrical characteristics

3.1 Input impedance

The modulus of the impedance at the signal input terminal shall be at least 2 000 Ω in the frequency range 200 Hz to 10 kHz and shall be specified by the manufacturer.