

**Pistikud, pistikupesad ja
pistikühendused tööstuslikuks
kasutuseks. Osa 1: Üldnõuded**

Plugs, socket-outlets and couplers for industrial
purposes - Part 1: General requirements

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 60309-1:2001 sisaldab Euroopa standardi EN 60309-1:1999 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 19.06.2001 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 60309-1:2001 consists of the English text of the European standard EN 60309-1:1999.</p> <p>This document is endorsed on 19.06.2001 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p>Käsitlusala: Applies to plugs and socket-outlets, cable couplers and appliance couplers, with a rated operating voltage not exceeding 690 V d.c. or a.c., 500 Hz a.c. and a rated current not exceeding 250 A, primarily intended for industrial use, either indoors or outdoors when the ambient temperature does not normally exceed 40° C</p>	<p>Scope: Applies to plugs and socket-outlets, cable couplers and appliance couplers, with a rated operating voltage not exceeding 690 V d.c. or a.c., 500 Hz a.c. and a rated current not exceeding 250 A, primarily intended for industrial use, either indoors or outdoors when the ambient temperature does not normally exceed 40° C</p>
--	--

ICS 29.120.30

Võtmesõnad: appliance coupler, cable coupler, construction, general requirement, industrial use, low-voltage equipment, plug and socket-outlet, rating, test

English version

Plugs, socket-outlets and couplers for industrial purposes
Part 1: General requirements
(IEC 60309-1:1999)

Prises de courant pour usages
industriels
Partie 1: Règles générales
(CEI 60309-1:1999)

Stecker, Steckdosen und Kupplungen
für industrielle Anwendung
Teil 1: Allgemeine Festlegungen
(IEC 60309-1:1999)

This European Standard was approved by CENELEC on 1999-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 23H/88/FDIS, future edition 4 of IEC 60309-1, prepared by SC 23H, Industrial plugs and socket outlets, of IEC TC 23, Electrical accessories, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60309-1 on 1999-04-01.

This European Standard supersedes EN 60309-1:1997.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2000-01-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2002-04-01

Annexes designated "normative" are part of the body of the standard.
In this standard, annexes A and ZA are normative.
Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60309-1:1999 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE: When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050(441)	1984	International Electrotechnical Vocabulary (IEV) Chapter 441: Switchgear, controlgear and fuses	-	-
IEC 60083	1997	Plugs and socket-outlets for domestic and similar general use standardized in member countries of IEC	-	-
IEC 60112	1979	Method for determining the comparative and the proof tracking indices of solid insulating materials under moist conditions	HD 214 S2	1980
IEC 60227 (mod)	series	Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V	HD 21	series
IEC 60228 + IEC 60228A (mod)	1978 1982	Conductors of insulated cables First supplement: Guide to the dimensional limits of circular conductors	HD 383 S2 + A1 + A2	1986 1989 1993
IEC 60245-4 (mod)	1994	Rubber insulated cables of rated voltages up to and including 450/750 V Part 4: Cords and flexible cables	HD 22.4 S3 + A1	1995 1999
IEC 60269-1	1986	Low-voltage fuses Part 1: General requirements	EN 60269-1 ¹⁾	1989
IEC 60269-2	1986	Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application)	EN 60269-2	1995
IEC 60320 (mod) series		Appliance couplers for household and similar general purposes	EN 60320	series
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr. May	1991 1993

1) EN 60269-1 is superseded by EN 60269-1:1998, which is based on IEC 60269-1:1998.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60664-1 (mod)	1992	Insulation coordination for equipment within low-voltage systems Part 1: Principles, requirements and tests	HD 625.1 S1 + corr. November 1996	1996 1996
IEC 60695-2-1	1994	Fire hazard testing Part 2: Test methods - Section 1	EN 60695-2-1	1996
IEC 60947-3 + corr. December 1991 (mod)	1990	Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	EN 60947-3 ²⁾ + corr. June 1997	1992 1997

2) EN 60947-3 is superseded by EN 60947-3:1999, which is based on IEC 60947-3:1999.

INTERNATIONAL STANDARD

IEC
60309-1

Edition 4.1
2005-12

Edition 4:1999 consolidated with amendment 1:2005

Plugs, socket-outlets and couplers for industrial purposes –

Part 1: General requirements

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 60309-1:1999+A1:2005(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC
60309-1

Edition 4.1
2005-12

Edition 4:1999 consolidated with amendment 1:2005

Plugs, socket-outlets and couplers for industrial purposes –

Part 1: General requirements

© IEC 2005 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XD**

For price, see current catalogue

CONTENTS

FOREWORD	7
INTRODUCTION	11
1 Scope	13
2 Definitions	13
3 Normative references	21
4 General	23
5 Standard ratings	25
6 Classification	27
7 Marking	29
8 Dimensions	35
9 Protection against electric shock	37
10 Provision for earthing	37
11 Terminals and terminations	43
12 Interlocks	67
13 Resistance to ageing of rubber and thermoplastic material	67
14 General construction	69
15 Construction of socket-outlets	71
16 Construction of plugs and connectors	73
17 Construction of appliance inlets	77
18 Degrees of protection	79
19 Insulation resistance and dielectric strength	81
20 Breaking capacity	83
21 Normal operation	87
22 Temperature rise	89
23 Flexible cables and their connection	93
24 Mechanical strength	103
25 Screws, current-carrying parts and connections	109
26 Creepage distances, clearances and distances through sealing compound	115
27 Resistance to heat, fire and tracking	117
28 Corrosion and resistance to rusting	121
29 Conditional short-circuit current withstand test	123
30 Electromagnetic compatibility	127
Annex A (normative) Guidance and description of test apparatus	167
Annex B (informative) List of the clause numbers that require re-testing	183

Figure 1 – Diagram showing the use of the accessories	129
Figure 2 – Standard test finger.....	131
Figure 3 – Spray apparatus.....	133
Figure 4 – Splash apparatus	135
Figure 5 – Circuit diagrams for breaking capacity and normal operation tests	137
Figure 6 – Apparatus for testing the cable anchorage	139
Figure 7 – Impact-test apparatus	141
Figure 8 – Arrangement for mechanical strength test for plugs and connectors	141
Figure 9 – Apparatus for flexing test	143
Figure 10 – Ball-pressure apparatus	143
Figure 11a – Test apparatus (example).....	145
Figure 11b – Glow-wire and position of the thermocouple	147
Figure 12 – Arrangement and dimensions of the electrodes for the tracking test	149
Figure 13 – Gauges for testing insertability of round unprepared conductors having the maximum specified cross-section.....	151
Figure 14 – Examples of terminals	153
Figure 15 – Equipment test arrangement	157
Figure 16 – Diagram of the test circuit for the verification of short-circuit current withstand of a two-pole equipment on a single-phase a.c. or d.c.	159
Figure 17 – Diagram of the test circuit for the verification of short-circuit current withstand of a three-pole equipment	161
Figure 18 – Diagram of the test circuit for the verification of short-circuit current withstand of a four-pole equipment	163
Figure 19 – Information for the bending test.....	165
Figure A.1 – Impact test fixture – Pendulum assembly.....	171
Figure A.2 – Impact test fixture – Pendulum masses – Quantity: 4	175
Figure A.3 – Impact test fixture – Pendulum shaft end	177
Figure A.4 – Impact test fixture – Pendulum anvil	177
Figure A.5 – Impact test fixture – Pendulum shaft	179
Figure A.6 – Impact text fixture – Pendulum pivot	179
Figure A.7 – Impact test apparatus – Back and mounting plates	181

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PLUGS, SOCKET-OUTLETS AND COUPLERS
FOR INDUSTRIAL PURPOSES –****Part 1: General requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60309-1 has been prepared by subcommittee 23H: Industrial plugs and socket-outlets, of IEC technical committee 23: Electrical accessories.

This consolidated version of IEC 60309-1 is based on the fourth (1999) [documents 23H/88/FDIS and 23H/91/RVD] and its amendment 1 (2005) [documents 23H/174/FDIS and 23H/182/RVD].

It bears the edition number 4.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

Annex A forms an integral part of this standard.

Annex B is for information only.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

International Standard IEC 60309 is divided into several parts:

Part 1: General requirements, comprising clauses of a general character.

Subsequent parts: Particular requirements dealing with particular types. The clauses of these particular requirements supplement or modify the corresponding clauses in part 1. Where the text of subsequent parts indicates an "addition" to or a "replacement" of the relevant requirement, test specification or explanation of part 1, these changes are made to the relevant text of part 1, which then becomes part of the standard. Where no change is necessary, the words "This clause of part 1 is applicable" are used.

PLUGS, SOCKET-OUTLETS AND COUPLERS FOR INDUSTRIAL PURPOSES –

Part 1: General requirements

1 Scope

This standard applies to plugs and socket-outlets, cable couplers and appliance couplers, with a rated operating voltage not exceeding 690 V d.c. or a.c. and 500 Hz a.c., and a rated current not exceeding 250 A, primarily intended for industrial use, either indoors or outdoors.

The list of preferred ratings is not intended to exclude other ratings.

This standard applies to plugs and socket-outlets, cable couplers and appliance couplers, hereinafter referred to as accessories, for use when the ambient temperature is normally within the range of $-25\text{ }^{\circ}\text{C}$ to $+40\text{ }^{\circ}\text{C}$. These accessories are intended to be connected to cables of copper or copper alloy only.

This standard applies to accessories with screwless type terminals or insulation piercing terminals, with a rated current up to and including 16 A for Series I and 20 A for Series II.

The use of these accessories on building sites and for agricultural, commercial and domestic applications is not precluded.

Socket-outlets or appliance inlets incorporated in or fixed to electrical equipment are within the scope of this standard. This standard also applies to accessories intended to be used in extra-low voltage installations.

This standard does not apply to accessories primarily intended for domestic and similar general purposes.

In locations where special conditions prevail, for example on board ship or where explosions are liable to occur, additional requirements may be necessary.

2 Definitions

Where the terms voltage and current are used, they imply the d.c. or the a.c. r.m.s. values.

For the purpose of this part of IEC 60309, the following definitions apply.

The application of accessories is shown in Figure 1.

2.1

plug and socket-outlet

a means enabling the connection at will of a flexible cable to fixed wiring. It consists of two parts:

2.1.1**socket-outlet**

the part intended to be installed with the fixed wiring or incorporated in equipment.

A socket-outlet may also be incorporated in the output circuit of an isolating transformer

2.1.2**plug**

the part integral with or intended to be attached directly to one flexible cable connected to the equipment or to a connector

2.2**cable coupler**

a means enabling the connection at will of two flexible cables. It consists of two parts:

2.2.1**connector**

the part integral with or intended to be attached to one flexible cable connected to the supply

NOTE In general, a connector has the same contact arrangement as a socket-outlet.

2.2.2**plug**

the part integral with or intended to be attached to one flexible cable connected to the equipment or to a connector

NOTE The plug of a cable coupler is identical to the plug of a "plug and socket-outlet".

2.3**appliance coupler**

a means enabling the connection at will of a flexible cable to the equipment. It consists of two parts:

2.3.1**connector**

the part integral with, or intended to be attached to, one flexible cable connected to the supply

NOTE In general, the connector of an appliance coupler is identical to the connector of a cable coupler.

2.3.2**appliance inlet**

the part incorporated in, or fixed to, the equipment or intended to be fixed to it

NOTE In general, an appliance inlet has the same contact arrangement as a plug.

2.4**rewirable plug or connector**

an accessory so constructed that the flexible cable can be replaced

2.5**non-rewirable plug or connector**

an accessory so constructed that the flexible cable cannot be separated from the accessory without making it permanently useless

2.6**mechanical switching device**

a switching device designed to close and open one or more electric circuits by means of separable contacts

2.7**switched socket-outlet**

a socket-outlet with an associated switching device to disconnect the supply from the socket-outlet contacts

2.8**integral switching device**

a mechanical switching device constructed as a part of an accessory covered by this standard

2.9**interlock**

a device, either electrical or mechanical, which prevents the contacts of a plug from becoming live before it is in proper engagement with a socket-outlet or connector, and which either prevents the plug from being withdrawn while its contacts are live or makes the contacts dead before separation

2.10**retaining device**

a mechanical arrangement which holds a plug or connector in position when it is in proper engagement, and prevents its unintentional withdrawal

2.11**rated current**

the current assigned to the accessory by the manufacturer

2.12**insulation voltage**

the voltage assigned to the accessory by the manufacturer and to which dielectric tests, clearances and creepage distances are referred

2.13**rated operating voltage**

the nominal voltage of the supply for which the accessory is intended to be used

2.14**basic insulation**

the insulation necessary for the proper functioning of the accessory and for basic protection against electric shock

2.15**supplementary insulation (protective insulation)**

an independent insulation provided in addition to the basic insulation, in order to ensure protection against electric shock in the event of a failure of the basic insulation

2.16**double insulation**

insulation comprising both basic insulation and supplementary insulation

2.17**reinforced insulation**

an improved basic insulation with such mechanical and electrical qualities that it provides the same degree of protection against electric shock as double insulation

2.18**terminal**

a conductive part provided for the connection of a conductor to an accessory

2.18.1**pillar terminal**

a terminal in which the conductor is inserted into a hole or cavity, where it is clamped under the shank of the screw or screws. The clamping pressure may be applied directly by the shank of the screw or through an intermediate clamping member to which pressure is applied by the shank of the screw (see Figure 14a)

2.18.2**screw terminal**

a terminal in which the conductor is clamped under the head of the screw. The clamping pressure may be applied directly by the head of the screw or through an intermediate part, such as a washer, clamping plate or anti-spread device (see Figures 14b and 14c)

2.18.3**stud terminal**

a terminal in which the conductor is clamped under a nut. The clamping pressure may be applied directly by a suitably shaped nut or through an intermediate part, such as a washer, clamping plate or anti-spread device (see Figure 14d)

2.18.4**saddle terminal**

a terminal in which the conductor is clamped under a saddle by means of two or more screws or nuts (see Figure 14e)

2.18.5**lug terminal**

a screw terminal or a stud terminal, designed for clamping a cable lug or bar by means of a screw or nut (see Figure 14f)

2.18.6**mantle terminal**

a terminal in which the conductor is clamped against the base of a slot in a threaded stud by means of a nut. The conductor is clamped against the base of the slot by a suitably shaped washer under the nut, by a central peg if the nut is a cap nut, or by equally effective means for transmitting the pressure from the nut to the conductor within the slot (see Figure 14g)

2.18.7**screwless type terminal**

a terminal for the connection and subsequent disconnection of one or more conductors, the connection being made, directly or indirectly, by other means than screws

NOTE Examples of screwless type terminals are given in Figure 14h.

2.18.8**insulation piercing terminal****IPT**

a terminal for the connection and subsequent disconnection of one or more conductors, the connection being made by piercing, boring through, cutting through, removing, displacing or making ineffective in some other manner the insulation of the conductor(s) without previous stripping

NOTE 1 The removal of the sheath of the cable, if necessary, is not considered as a previous stripping.

NOTE 2 Examples of IPT are given in Figure 14i.

2.19**clamping unit**

the part of a terminal necessary for the clamping and the electrical connection of the conductor

2.20**conditional short-circuit current**

the prospective current that an accessory, protected by a specified short-circuit protective device, can satisfactorily withstand for the total operating time of that device under specified conditions of use and behaviour

NOTE This definition differs from IEC 441-17-20 by broadening the concept of current-limiting device into a short-circuit protective device, the function of which is not only to limit the current.

2.21**cap**

a part separated or attached, which may be used to provide the degree of protection of a plug or appliance inlet when it is not engaged with a socket-outlet or connector

2.22**lid**

a means to ensure the degree of protection on a socket-outlet or a connector

3 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-441:1984, *International Electrotechnical Vocabulary (IEV) – Chapter 441: Switchgear, controlgear and fuses*

IEC 60083:1997, *Plugs and socket-outlets for domestic and similar general use standardized in member countries of IEC*

IEC 60112:1979, *Method for determining the comparative and the proof tracking indices of solid insulating materials under moist conditions*

IEC 60227, (all parts) *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60228:1978, *Conductors of insulated cables*

IEC 60245-4:1994, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 4: Cords and flexible cables*

IEC 60269-1:1986, *Low-voltage fuses – Part 1: General requirements*

IEC 60269-2:1986, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Sections I to III*

IEC 60320, (all parts) *Appliance couplers for household and similar general purposes*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*

IEC 60664-1:1992, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60695-2-1:1994, *Fire hazard testing – Part 2: Test methods*

IEC 60947-3:1990, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

ISO 2081, *Metallic coatings – Electroplated coatings of zinc on iron or steel*

ISO 2093, *Electroplated coatings of tin – Specification and test methods*

ISO 1456, *Metallic coatings – Electrodeposited coatings of nickel plus chromium and of copper plus nickel plus chromium*

4 General

4.1 General requirements

Accessories shall be so designed and constructed that in normal use their performance is reliable and without danger to the user or surroundings.

Unless otherwise stated, the normal use environment in which the devices complying with this standard are normally used is pollution degree 3 according to IEC 60664-1.

If other pollution degrees are needed, creepage and clearance distances have to be in accordance with IEC 60664-1. The comparative tracking index (CTI) value shall be evaluated in accordance with IEC 60112.

Combinations of plugs, socket-outlets, appliance inlets and connectors that are intended for use together shall comply with the requirements of this standard and the relevant standard sheet, if any.

In general, compliance is checked by carrying out all the tests specified.

4.2 General notes on tests

4.2.1 Tests according to this standard are type tests. If a part of an accessory has previously passed tests for a given degree of severity, the relevant type tests shall not be repeated if the severity is not greater. When a part or a component is incorporated in a device or accessory according to IEC 60309 standard, and if this part or component meets an appropriate IEC standard, then no further test(s) or requirement(s) shall be required for this part or component, unless it is being used in a way significantly different from the intent of its own standard.